

Indian Point 3  
Nuclear Power Plant  
P.O. Box 215  
Buchanan, New York 10511  
914 736.8001



Robert J. Barrett  
Site Executive Officer

June 19, 1997  
IPN-97-079

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555


SUBJECT: Indian Point 3 Nuclear Power Plant  
Docket No. 50-286  
License No. DPR-64  
Licensee Event Report # 97-007-00  
**Past Operation of the Service Water Discharge Throttle Valves SWN 35-1  
and SWN 35-2 May Have Placed the Plant Outside Design Basis due to  
Human Error**

Dear Sir:

The attached Licensee Event Report (LER) 97-007-00 is hereby submitted as required by 10 CFR 50.73. This event is of the type defined in 10 CFR 50.73 (a)(2)(ii)(B).

Also, attached are the commitments made by the Authority in this LER.

Very truly yours,

  
For Robert J. Barrett  
Site Executive Officer  
Indian Point 3 Nuclear Power Plant

Attachment

cc: See next page

9706250448 970619  
PDR ADOCK 05000286  
S PDR



TE22/11

cc: Hubert J. Miller  
Regional Administrator  
Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406-1415

INPO Record Center  
700 Galleria Parkway  
Atlanta, Georgia 30339-5957

U.S. Nuclear Regulatory Commission  
Resident Inspectors' Office  
Indian Point 3 Nuclear Power Plant

COMMITMENT LIST

Number	Commitment	Due
IPN-97-079-01	A supplemental LER will be forwarded to the NRC if additional investigations find a significant difference in the root cause from those determined by the preliminary assessment. This supplement, if necessary, will be submitted prior to startup.	Prior to startup
IPN-97-079-02	Procedures will be revised prior to start-up to ensure the minimum closure limits based on river water temperature and minimum flow requirements to support CCW during recirculation.	Prior to startup
IPN-97-079-03	Upon conclusion of the cause determination, the appropriate extent of condition review of EOPs will be determined prior to plant start-up.	Prior to startup