

Indian Point 3
Nuclear Power Plant
P.O. Box 215
Buchanan, New York 10511
914 736.8001



Robert J. Barrett
Site Executive Officer

July 18, 1997
IPN-97-094

U.S. Nuclear Regulatory Commission
ATTN: Document Control Center
Washington, D.C. 20555

SUBJECT: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
License No. DPR-64
Licensee Event Report # 97-010-00

**Less Than The Required Number of Emergency Diesel Generators
Were Operable Due to Loss of Ventilation Resulting From An
Inadvertent Operation of a Carbon Dioxide System; A Condition
Prohibited By Technical Specifications**

Dir Sir:

The attached Licensee Event Report (LER) 97-010-00 is submitted as required by 10 CFR 50.73. This event is of the type defined in 10 CFR 50.73 (a)(2)(i)(B) and 10 CFR 50.72(a)(2)(vii).

Also attached are the commitments made by the Authority in this LER.

Very truly yours,


Robert J. Barrett
Site Executive Officer
Indian Point 3 Nuclear Power Plant

Attachment

cc: See next page

9707300010 970718
PDR ADDCK 05000286
S PDR



IE001

080004

cc: Mr. Hubert J. Miller
Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406-1415

INPO Record Center
700 Galleria Parkway
Atlanta, Georgia 30339-5957

U.S. Nuclear Regulatory Commission
Resident Inspectors' Office
Indian Point 3 Nuclear Power Plant

List of Commitments

Number	Commitment	Due
IPN-97-094-01	Engineering will complete an evaluation of this event to determine the appropriate corrective action as well as to complete the safety significance analysis.	September 12, 1997
IPN-97-094-02	This LER will be supplemented to provide the identified corrective action as well as to complete the safety significance of this event.	October 12, 1997
IPN-97-094-03	A case study will be developed by the Training Department and added to the 1997 Engineering Support Personnel continuing training on performing failure and effects analysis for plant modifications including a discussion on LER 97-010.	December 19, 1997