

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-286
UNIT NAME INDIAN POINT NO. 3
DATE 07-01-97
COMPLETED BY T. Orlando
TELEPHONE (914) 736-8340
IPN-97-096
ATTACHMENT I
PAGE 3 of 4

REPORT MONTH June 1997

NO.	DATE	TYPE 1	DURATION (HOURS)	REASON 2	METHOD OF SHUTTING DOWN REACTOR 3	LICENSEE EVENT REPORT #	SYSTEM CODE 4	COMPONENT CODE 5	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
2	970514	F	54.65	A	2	97-005	IB	INSTRU I	MANUALL TRIPPED THE REACTOR DUE TO A MAIN TURBINE RUNBACK
3	970517	S	720	C	4	N/A	ZZ	ZZZZZZ	CONTINUED NORMAL REACTOR SHUTDOWN AND COMMENCED SCHEDULED CYCLE 9/10 REFUELING OUTAGE.

1
F: Forced
S: Scheduled

2
Reason:
A- Equipment
B- Maintenance or Test
C- Refueling
D- Regulatory Restriction
E- Operator Training & Licensee Examination
F- Administrative
G- Operational Error
H- Other (Explain)

3
Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Other (Explain)

4
Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File
(NUREG - 0161)

5
Exhibit 1 -
Same Source

9707280100 970717
PDR ADOCK 05000286
R PDR