

PDR



May 1, 1987

Mr. M. Carrington, Project Manager
 Office of Nuclear Reactor Regulation
 U.S. Nuclear Regulatory Commission
 Washington, D.C. 20555

TRANSMITTAL OF FINAL REPORT, "CONFORMANCE TO GENERIC LETTER 83-28,
 ITEM 2.2.2--VENDOR INTERFACE PROGRAMS FOR ALL OTHER SAFETY-RELATED
 COMPONENTS: INDIAN POINT -3," EGG-NTA-7594, APRIL 1987 (FIN D6001) -
 EWR-104-87

Ref: NRC Form 189, "Evaluation of Conformance to Generic Letter 83-28 For
 ORs (Project 2)" (D6001)

Dear Mr. Carrington:

Transmitted herewith is the above subject report.

The report documents INEL's evaluation of the licensee actions in response
 to NRC Generic Letter 83-28, Item 2.2.2--Vendor Interface Programs for All
 Other Safety-Related Components. Based on the licensee submittals, we
 conclude that the plant conforms to the generic letter on this item,
 except for the lack of licensee interface with the vendors of
 safety-related equipment (other than the NSSS supplier).

Very truly yours,

E. W. Roberts, Manager
 NRC Headquarters Support

ACU:gp

Enclosure:
 As Stated

cc: G. L. Jones, DOE-ID
 D. Lasher, SICB (2)
 J. O. Zane, EG&G Idaho, Inc. (w/o Encl.)

8706300870 870501
 PDR ADDCK 05000286
 PDR
 P
 EG&G Idaho, Inc. 11428 Rockville Pike Suite 410 Rockville, MD 20852