Nuclear Plant: IP3 ☑ JAF □ PAGE 1 OF 4

. •

	CALC. NOIP3-CALC-S	I-01772	REV	ISION 0		
	CALCULATION IS: PRE	LIMINA	RY FINAL _>	<u>(</u>		
		<u>NAME</u>	ана стана 1970 - Стана 1971 - Стана Стана Стана 1971 - Стана Стана Стана Стана Стана 1971 - Стана Стана Стана Стана Стана 1971 - Стана	SIGNATURE		DATE
	PREPARER:	<u>P.C. X</u>	ie	PXF		<u>2/11/96</u>
	CHECKER:	A.D.Ha	arrison	(Recorder P L	Herrison	ے <u>2/1<i>1</i>/96</u>
	(DESIGN) VERIFIED/NA	<u>F.W. N</u>	lartsen	Tyle W Mart	2011	<u>2/21/96</u>
	APPROVED:	<u>K. Eslir</u>	nger	filly hhm	<u>.</u>	2/11/96
			· ·			13 MA
	ORIGINATOR:	<u>NYPA</u>	or <u>other</u> c	<b>)</b>		-7
	SYSTEM NO./NAME	<u>SI-MO</u>	V-1835A Pressur	e Locking Analysis		
			<u></u>	FORINFO	IRMAI	
				ON		
				STRUCTUR		/^
		_DISCIP	GL-95-07		NO N.	/Δ
	PROBLEM / OBJECTIVI	<u>E / METI</u>	HOD			
	Assess actuator capab	ility vers	sus requirements	under pressure loci	kina condit	ions.
			· · · · · · · · · · · · · · · · · · ·			
	<u>DESIGN BASIS / ASSU</u>		L		بر	
	Valve Factor = .5, De	graded	Voltage, Stem F	riction Coefficient	= .2	
	SUMMARY / CONCLUS	SIONS			. •	
	Actuator is capable of	operatin	g under postulat	ed conditions.		
	THIS CALC SUPERSED	ES OR \	OIDS CALC. NO	).		
	DISTRIBUTION: C = CO	NTROLL	ED I = INFO	<u>.</u>		
	NAME		DEPT	LOC	С	1
	K. Eslinger		DSE	IP3	X	N7A
	E. MARTSEN		PEP	WPO		X
	9609030283 960821	<b>.</b>				
· _		86 R				
	SI	1	· · · · · · · · · · · · · · · · · · ·		FUEIN	
	CAT I				FR 9 A 10	
	52-B-019	8				
FILE				By		
COMP.	FRINTOUS LOU:			,		

PAGE 2 OF 4

# COMPONENTS

MAJOR EQUIPMENT	PIPE NO.	VALVE NO.	SUPT. NO	INST.NO.	PENE. NO.
N/A	N/A	SI-MOV-1835A	N/A	N/A	N/A
	-				
	,				
·					

### **RELATED DOCUMENTS**

NYPA COM-RPT-0002

IP3-RPT-MULT-1763

IP3-CALC-SI-01057

IP3-RPT-MULT-01279

# **RELATED DRAWINGS**

NONE		· · · · · · · · · · · · · · · · · · ·		
				· ·
	· · · · · · · · · · · · · · · · · · ·			•
				· .
		· · · · · · · · · · · · · · · · · · ·		
			· ·	· · · · · · · · · · · · · · · · · · ·
· ·	<u>,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,</u>	· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·	

SECURITY: (Y/N) \_\_\_\_N

COMPUTER PRINTOUT: (Y/N) \_\_\_\_

N

New York Power Authority Calculation No. \_ IP3-CALC-SI-01772 Revision No. 0 Page \_\_\_\_\_ 3 Project: Generic Letter 95-07 of Λ Computed by: Philip C. Xie ( Date: 2/11/96 Subject: SI-MOV-1835A Check by: Andrea D. Harrison 2014 Date: 2/11/96 Pressure Locking Analysis **P1** (IP3-RPT-MULT-01763) =21 **P1** Upstream Pressure at valve inlet, psig PB =1622 (IP3-RPT-MULT-01763) PB Bonnet Cavity Pressure, psig P2 =900 (IP3-RPT-MULT-01763) **P2** Downstream Pressure at valve outlet, psig VF =0.5 (NYPA COM-RPT-0002) VF Valve Factor AS =12.965 (IP3-CALC-SI-01057) AS Seat Area, in<sup>2</sup> SA =2.074 (IP3-CALC-SI-01057) Stem Area, in<sup>2</sup> SA PL<sub>assumed</sub> = 2500 (IP3-CALC-SI-01057) Packing Load, lbs PL. MCUV<sub>open</sub> = 10,099 (IP3-CALC-SI-01057) MCUV..... Motor Capability, lbs (Degraded Voltage) T<sub>degraded voltage</sub> = 173.7(IP3-CALC-SI-01057) Capability at Degraded Voltage, ft-lbs T<sub>degre</sub> PL<sub>actual</sub> = 800 (MOVATS Test Date 9/14/94) Packing Load, lbs PL. SF<sub>actual</sub>=0.0115 (IP3-RPT-MULT-01279) Stem Factor SFacturel **Opening Thrust Requirement Determination:**  $Thrust_{max} = [(PB-P1)+(PB-P2)](AS)(VF)-(SA)(PB)+(PL)$  $Thrust_{max} = [(1622-21)+(1622-900)](12.965)(0.5)-(2.074)(1622)+(2500) = 14,195 lbs$ Opening Thrust Requirement with actual packing load: Thrust<sub>men</sub> =  $[(PB-P1)+(PB-P2)](AS)(VF)-(SA)(PB)+(PL_{actual})$ = [(1622-21)+(1622-900)](12.965)(0.5)-(2.074)(1622)+(800) = 12,495 lbs Thrust Margin % Definition: (Capability-Requirement) x 100 Margin 🗉 Requirment (10,099 - <u>12,495) x 100</u> = -19% 12.495 This margin is unacceptable and is based on over-conservative assumptions, as actual stem factor can be used to assess current installed margin ( see next page).



#### New York Power

Authority Calculation No. <u>IP3-CALC-SI-01772</u>

Project: <u>Generic Letter 95-07</u>

Subject: SI-MOV-1835A

Pressure Locking Analysis

Revision No	. (	0		
Page	4	of	4	
Computed by:	Philip C.	Date:	2/13/96	
Check by: <u>A</u>	ndrea D. Ha	rrison Do	Date: 2/13	96

Actuator Capability under actual Stem Factor and Degraded Voltage:

*New Capability* =  $\frac{173.7}{0.0115}$  = 15,104

#### Therefore:

If the actual Stem Factor is used and degraded voltage is assumed, the margin is

 $MARGIN = \frac{(15,104 - 12,495) \times 100}{12,495} = 21\%$ 

### Conclusion:

The opening thrust capability at degraded motor terminal voltage of the subject actuator is 15,104 lbsf. This proves that the actuator has moderate margin (21%) over the opening requirements postulated in the pressure locking/thermal binding report (IP3-RPT-MULT-01763). The Stem Factor of Thrust<sub>open</sub> calculation is 0.0115, as determined in IP3-RPT-MULT-01279.



⊠ · IP3 □ · JAF

DESIGN VERIFICATION COVERSHEET page 1 of 1

Verification of:

Document Title:

SI-MOU-1835 A PRESSURE LOCKING ANACYSE

Document Number:

Subject:

GL 95-07

IP3-CALC-SI-01772

Modification/Task Number (if applicable):

QA Category:

Review Required	Discipline	Review Complete (initial of reviewer)
	ELECTRICAL	
	MECHANICAL	
	INSTRUMENT & CONTROL	
-	CIVIL/ STRUCTURAL	
	FIRE PROTECTION	
·	SIMULATOR	
		· · · · · · · · · · · · · · · · · · ·





		· · ·		J AF	Design	VERIFICA	FION CHEC page 1 c
DENTIFICAT	NON:				DIS	SCIPLINE:	
Docum (print title)	ent Title: <u>57-170</u>	100-1835 A. P.	RESSORE LOLK	INE ANDIS		ELEC [] MECH []	I&C Fire Prote
Doc. Nu QA Cate	mber: <u>IP3-CA</u> igory: <u> </u>	12C-SI-01	ZZZ Doc. Revi	sion:		C/S [] Other	Simulator
METHOD OF	VERIFICATION:						
N De	sign Review	[] Alternat	e Calculations	[] Qualif	cation 1	est	
Selecte	ed Verifier:	FILE D MART	TEN PEP nent_phone ext	WPO GY	<i>ç9</i>		
#		Des All questions	i <b>gn Verification (</b> shall be explained	Juestionnaire d in the space p	provided.		
1. Wer	e the inputs correct	t and incorporated	into the design?				
Explanation:	YES-ALL	INPUTS A	RE TAKEN	FRAM.	Arra	WED REP	EREN UZ
3. Does xplanation:	the proposed desig $\mathcal{N}/\mathcal{A}$	gn incorporate lice	nse Commitmen	ts?			
3. Does	the proposed design M/A	gn incorporate lice	nse Commitmen	ts?			
3. Does Explanation: 4. Are a nece comp	the proposed design M/A assumptions necess ssary, are the assumptioned?	gn incorporate lice sary to perform th mptions identified	nse Commitmen e design activity a for subsequent r	ts? Idequately desi everifications v	cribed and then the d	d reasonable: detailed desig	Where n activities a
3. Does xplanation: 4. Are a nece comp xplanation:	the proposed design M/A assumptions necess ssary, are the assumpted? VES	gn incorporate lice sary to perform th mptions identified	e design activity a	ts? Indequately designed everifications v	cribed and then the c	d reasonable: detailed desig	Where In activities a
<ul> <li>3. Does</li> <li>xplanation:</li> <li>4. Are a necession</li> <li>xplanation:</li> <li>5. Are times</li> </ul>	the proposed design MA assumptions necess ssary, are the assumpted? MES he appropriate qua	Ity and quality ass	e design activity a for subsequent r	ts? Indequately designed evenifications v CACC ents specified?	cribed and then the c	d reasonable: detailed desig	Where In activities a
<ul> <li>3. Does</li> <li>xplanation:</li> <li>4. Are a necession</li> <li>xplanation:</li> <li>5. Are to the second seco</li></ul>	the proposed design MA assumptions necession ssary, are the assumpted? VES he appropriate qua VES	Ity and quality assisted	e design activity a for subsequent r	ts? Indequately designed everifications v CACC ents specified?	cribed and then the c e.g., safe	d reasonable: detailed desig	Where In activities a on?
<ul> <li>3. Does</li> <li>xplanation:</li> <li>4. Are a necession</li> <li>xplanation:</li> <li>5. Are to identify the second se</li></ul>	the proposed design MA assumptions necession ssary, are the assumption pleted? VES the appropriate qua VES the applicable codes ified and are their n	Ity and quality asso control of the sequirements for difference of the second s	e design activity a for subsequent r	ts? Idequately designed everifications v CACC ents specified?	cribed and then the c e.g., safe	d reasonable detailed desig ty classificati d addenda pr	Where In activities a on?
<ul> <li>3. Does</li> <li>xplanation:</li> <li>4. Are a necestronic</li> <li>xplanation:</li> <li>5. Are to identify the second second</li></ul>	the proposed design M/A assumptions necessistary, are the assumptions necessistary, are the assumption of the assumpti	Ity and quality asso control of the standards and re equirements for de	e design activity a for subsequent r	ts? Indequately desirevenifications v CACC ents specified? ments including	cribed and then the o e.g., safe	d reasonable: detailed desig	Where In activities a on?
<ul> <li>3. Does</li> <li>xplanation:</li> <li>4. Are a necestronic</li> <li>xplanation:</li> <li>5. Are the identities</li> <li>6. Are the identities</li> </ul>	the proposed design MA assumptions necession ssary, are the assumpted? VES he appropriate qua VES he applicable codes ified and are their normality	gn incorporate lice sary to perform th mptions identified SIZE PC lity and quality asso - CATZ s, standards and re equirements for do	e design activity a for subsequent r	ts? Indequately desc everifications v CACC ents specified? ments including	cribed and then the o e.g., safe	d reasonable: detailed desig	Where n activities a on?

DCM-4

l

ATTACHMENT 4.2

evy York Power Luthority DESIGN VERIFICATION CHECKLIST page 2 of 4 **Design Verification Guestionnairs** All questions shall be explained in the space provided 7. Have applicable construction and operating experience been considered? Explanation: YES-SUPPORTS This Ga 6691-07 review N Considers RPra DEFIENCE Have the design interface requirements for mechanical, electrical/ISC, and civil/structural engineering been 8. satisfied? Explanation: 9. Was the appropriate design method used? VFS uses standard industry methods **Explanation:** THE 1.a 100 IOK. Is the output reasonable compared to inputs? 10. YES Explanation: T HP reguired forces are reasonable Are the specified parts, equipment and processes properly suited for the fire protection Appendix R, QA, and 11. EQ classifications required for the application? A **Explanation:** Are the specified materials compatible with each other and the design environmental conditions to which the 12. material will be exposed? Explanation: Have personnel requirements and limitations for maintenance, testing, and inspection been satisfied? 13. Explanation: Are accessibility, maintenance, repair, and inservice inspection requirements for the plant including the plant 14. conditions under which these will be performed been considered? **Explanation:** Has adequate accessibility been provided to perform the in-service inspection expected to be required during 15. the plant life? Explanation:

ew York Power withority **DESIGN VERIFICATION CHECKLIST** page 3 of 4 **Design Verification Guestionneire** All questions shall be explained in the space provided Has the design property considered radiation exposure to the public and plant personnel? (ALARA/ cobalt 16. reduction) Explanation: Are the acceptance criteria incorporated in the design documents sufficient to allow verification that design 17. requirements have satisfactorily accomplished? Explanation: VES The conclusion is reacha direct narluc Have adequate pre-operational and subsequent periodic test requirements been appropriately specified? 18. Explanation: Are adequate handling, storage, cleaning and shipping requirements specified? 19. Explanation: 20. Are adequate identification requirements specified? Explanation: Are the conclusions drawn in the Safety Evaluation fully supported by adequate discussion in the test or Safety 21. **Evaluation itself?** Explanation: Are necessary procedural changes specified, and are responsibilities for such changes clearly delineated? 22. Explanation: Are requirements for record preparation, review, approval, retention, etc., adequately specified? 23. In a ccordance Explanation: WITH COLC Procedure COR erocess. Have supplemental reviews by other engineering disciplines (seismic, electrical, etc.) been performed on the 24. integrated design package? tem Engineer hos reviewed PLTB scenerios. Explanation: Have the drawings, sketches, calculations, etc., included in the integrated design package been reviewed? 25. Explanation: کمہ تیے

ATTACHMENT 4.2

New York Power Authority **DESIGN VERIFICATION CHECKLIST** page 4 of 4 **Design Verification Questionnaire** All questions shall be explained in the space provided Have reviews been performed to identify any effect on the Check Valve Maintenance Program? 26. **Explanation:** 27. Does the design for check valves meet the intents of INPO SOER 86-03? Explanation: 28. Is the plant reference simulator physical and functional fidelity affected and it's design change been factored into the cost? **Explanation:** 29. Are all references listed (including design calculation/analysis) that were used as part of the design review? YES -SEE CALC PE 3 Explanation: **REMARKS/COMMENTS: Design Verification** 2/13/96 **Complete:**