Indian Point 3 **Nuclear Power Plant** P.O. Box 215 Buchanan, New York 10511 914 736.8001



August 24, 1994 IPN-94-108

U.S. Nuclear Regulatory Commission **ATTN: Document Control Desk** Mail Stop PI-137 Washington, D.C. 20555

SUBJECT: Indian Point 3 Nuclear Power Plant Docket No. 50-286 License No. DPR-64 Effluent and Waste Disposal Semi-Annual Report for The Period January 1, 1994 through June 30, 1994

Dear Sir:

Enclosed is the Semi-Annual Report of Radioactivity in Solid Wastes and Releases of Radioactive Material in Liquid and Gaseous Effluents for Indian Point 3 as required by Section 5.3.3.1 of the Environmental Technical Specifications. The enclosed report covers the period January 1, 1994 through June 30, 1994 for Indian Point 3 and would include those releases from Indian Point 2 resulting from processing liquid waste from Indian Point 3 if this pathway was utilized. During this reporting period, no waste was transferred from Unit 3 to Unit 2.

Very truly yours,

. M. Hill **Resident Manager** Indian Point 3 Nuclear Power Plant

Attachment

cc: See next page

**Resident Manager** 

L. M. Hill

Docket No. 50-286 IPN-94-108 Page 2 of 2

Mr. Thomas T. Martin Regional Administrator Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, Pennsylvania 19406-1415

> U.S. Nuclear Regulatory Commission Resident Inspectors' Office Indian Point 3 Nuclear Power Plant

cc:



Effluent and Waste Disposal

#### Semi-Annual Report

January 1, 1994 - June 30, 1994

#### Facility

r .

Indian Point 3

Licensee

New York Power Authority

This information is provided in accordance with the requirements of Regulatory Guide 1.21. The numbered sections of this report reference corresponding sections of the subject Regulatory Guide, pages 1.21-10 to 12. The Authority is making no commitments in this submittal.

#### A. <u>Supplemental Information</u>

#### 1. <u>Regulatory Limits</u>

Indian Point 3 is presently subject to limits on radioactive waste releases that are set forth in sections 2.3.1, 2.3.2, 2.3.3, 2.4.1, 2.4.2, 2.4.3 and 2.4.4 of Appendix B to Docket No. 50-286 entitled "Environmental Technical Specification Requirements Part II Radiological Environmental" (ETSR). The percentages of the technical specification limits reported in Tables 1A and 2A are the percent of the quarterly limits specified in the ETSR. If more than one limit applies to the release, the most restrictive limit is reported.

#### 2. <u>Maximum Permissible Concentration</u>

#### a) <u>Fission and Activation Gases</u>

The quarterly dose resulting from release of fission and activation gases is calculated in accordance with the methodology stated in the Offsite Dose Calculation Manual (ODCM). The specific isotopes listed in Table 1C are used to determine the effective dose factors for the time period.

#### b/c) Iodines, Tritium and Particulates

The quarterly organ dose limit for Iodine 131, tritium and particulates with half-lives greater than eight days is calculated in accordance with the methodology stated in the ODCM.

d) <u>Liquid Effluents</u>

The quarterly dose limit for liquid isotopic releases is calculated in accordance with the methodology stated in the ODCM. The concentration limit for noble gases dissolved in liquid releases is calculated based upon a maximum permissible concentration of 2.00E-4 uCi/ml as required by section 2.3.1.A of the ETSR.



#### 3. <u>Average Energy</u>

The average energies  $(\overline{E})$  of the radionuclide mixture in releases of fission and activation gases were as follows:

1st Quarter  $E_{\beta} = 0.00E-00$  Mev/dis  $E\gamma = 0.00E-00$  Mev/dis 2nd Quarter  $E_{\beta} = 0.00E-00$  Mev/dis  $E\gamma = 0.00E-00$  Mev/dis

There were no Noble Gas releases in the first and second quarter, 1994, due to the extended shutdown of the facility.

#### 4. <u>Measurements and Approximations of Total Radioactivity</u>

#### a) <u>Fission and Activation Gases</u>

Analysis of effluent gases has been performed in compliance with the requirements of Table 3.4-1 of the ETSR. In the case of isolated tanks (batch release) the total activity discharged is based on an isotopic analysis of each batch with the volume of gas in the batch corrected to standard temperature and pressure.

Vapor containment purge discharges that are less than 150 hours/quarter in duration have been treated as batch releases and Vapor Containment pressure relief discharges have been treated as continuous releases (> 500 hrs/year and as defined in NUREG 0133, Section 3.3). At least one complete isotopic concentration analysis of containment air is performed monthly. This analysis is used in conjunction with a process monitor to obtain the isotopic mixture and quantification of each pressure relief. Isotopic analyses for each vapor containment purge are taken prior to and during the purge. This information is combined with the volume of air in each discharge to calculate the quantity of activity released from these discharges.

The continuous building discharges are based on weekly samples of ventilation air for isotopic content. This information is combined with total air volume discharged and the process radiation monitor readings to determine the quantity of activity from continuous discharges.

#### b/c) <u>Iodines and Particulates</u>

Iodine-131 and particulate releases are quantified by collecting a continuous sample of ventilation air on a TEDA impregnated, activated charcoal cartridge and a glass-fiber filter paper. These samples are changed weekly as required in Table 3.4-1 of the ETSR and the concentration of isotopes found by analysis of these samples is combined with the volume of air discharged during the sampling period to calculate the quantity of activity discharged.





For other iodine isotopes the concentration of each isotope is determined monthly on a 24-hour sample. The concentration of the isotopes found by analysis is combined with the volume of air discharged during the sampling period to calculate the quantity of activity discharged.

#### d) <u>Liquid Effluents</u>

A sample of each batch discharge is taken and an isotopic analysis is performed in compliance with requirements specified in Table 3.3-1 of the ETSR. This isotopic concentration data is combined with the information on volume discharged to determine the amount of each isotope discharged.

Proportional composite samples of continuous discharges are taken and analyzed in compliance with Table 3.3-1 of the ETSR. This concentration data is combined with the volume discharged to calculate the total activity discharged.

100/

#### 5. <u>Batch Releases</u>

#### a) Liquid

<u>lst Quarter</u>	Zna Quarter
Number of Batch Releases 11	14
Total Time Period Batch Releases (Min) 1347	2268
Maximum " " " " 160	275
Average " " " " " 122	162
Minimum " " " " 81	125
Average Stream Flow (cfs) Note: *	Note: *

Note:\*

This information is obtained from the Department of the Interior, U.S. Geological Survey, for the Hudson River. Due to the delays in obtaining this data from the governmental agency, flows will be submitted as they become available.

#### b) Gaseous

Number o	of Bat	tch Rele	eases				0	0
Total	Time	Period	Batch	Release	s	(Min.)	N/A	N/A
Maximum	**	11		n	n	88	N/A	N/A
Average	**	11	n	"	11	87	N/A	N/A
Minimum	11	11	11	11	11	61	N/A	N/A



#### 6. <u>Abnormal Releases</u>

- a) <u>Liquid</u> None
- b) <u>Gaseous</u> None

#### 7. <u>Radiological Environmental Technical Specifications</u>

The Radiological Environmental Technical Specifications require reporting of prolonged outages of effluent monitoring equipment (Sections 2.1.C and 2.2.B) and significant changes in the land use census, Radiological Environmental Monitoring Program (REMP), or exceeding the total curie content limitations in outdoor tanks (Sections 2.8.A, 2.8.B, 2.7.C and 2.3.4.B).

During this reporting period, the following Technical Specification Effluent Monitoring equipment was out of service (OOS) for periods greater than 30 consecutive days:

Radiation Monitor	Days OOS	Reason for out of service condition
R-16A/B	37 days	During planned maintenance on a sample delivery valve (SWN-51-1), an additional failed isolation valve (SWN-51-5) was discovered, requiring parts for corrective maintenance.
R-19	50 days	Vendor 10CFR21 issue involving monitor's microprocessor, followed by a refueling calibration failure requiring trouble- shooting, repair, and re-performance of the refueling calibration test.
R-59	81 days	Vendor 10CFR21 issue involving monitor's microprocessor, followed by a discovered insufficient sample flow problem requiring continued troubleshooting.
Waste Gas O <sub>2</sub> Analyzer	181 days	This portion of the explosive gas monitoring system was out of service for a planned upgrade (MOD # 94-3-011WGA) due to obsolete failed equipment no longer supported by the vendor. The modification was completed June 30, 1994.
Waste Gas H <sub>2</sub> Analyzer	44 days	The $H_2$ instrument was out of service for the modification described above, but only during the interval required to perform the actual system upgrade.



Indian Point 3 EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT

۰.

. .

• 4

۳.

**B. GASEOUS EFFLUENTS** 

FIRST AND SECOND QUARTERS, 1994

#### TABLE 1A

.

• •

۰.

•

#### EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (Jan - Jun 1994)

#### GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

		UNIT	QUARTER 1st	QUARTER 2nd	EST. TOTAL ERROR %
A.	Fission & Activation Gases				
1. 2. 3.	Total Release Average release rate for period Percent of technical spec. limit	Ci uCi/sec %	0.00E+00 0.00E+00 0.00E+00	0.00E+00 0.00E+00 0.00E+00	N/A
B. 1. 2.	Iodines Total Iodine - 131 Average release rate for period	Ci uCi/sec	0.00E-00 0.00E-00	0.00E-00 0.00E-00	N/A
C.	Particulates				
1. 2. 3.	Total release with T⅓ >8 days Average release rate for period Gross alpha radioactivity	Ci uCi/sec Ci	1.04E-06 1.34E-07 <3.29E-07	1.00E-07 1.27E-08 <3.03E-07	2.50E+01
D.	Tritium				
1. 2.	Total release Average release rate for period	Ci uCi/sec	2.59E-01 3.33E-02	2.27E-01 2.89E-02	2.50E+01
E.	Percent of Tech Spec Limit Iodines, Particulate with $T^{\frac{1}{2}} > 8$ days, & Tritium	સ	5.93E-04	4.68E-04	2.50E+01

Doc

Docket No. 50-286 IPN-94-108

#### TABLE 1C EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (Jan - Jun 1994) GASEOUS EFFLUENTS-GROUND RELEASES

			CONTINUC	OUS MODE	BATCH	MODE
<u>Nucli</u>	des Released	<u>Unit</u>	lst Quarter	2nd Quarter	1st Quarter	2nd Quarter
1)	Fission Gases					
	Krypton (Kr) 85m	Ci				
	Krypton (Kr) 85	Ci				
	Krypton (Kr) 87	Ci				
	Krypton (Kr) 88	Ci				
	Xenon (Xe) 131m	Ci				
	Xenon (Xe) 133m	Ci				
	Xenon (Xe) 133	Ci				
	Xenon (Xe) 135m	Ci				
	Xenon (Xe) 135	Ci				
	Xenon (Xe) 138	Ci				
	Argon (Ar) 41	Ci				
TOTAL	FOR PERIOD	Ci	0.00E-00	0.00E-00	0.00E-00	0.00E-00
·					0.002 00	<u> </u>
2)	Iodines					
	Iodine (I) 131	Ci				
	Iodine (I) 133	Ci				
	Iodine (I) 135	Ci				

TOTAL FOR PERIOD Ci 0.00E-00 0.00E-00

## TABLE 1CEFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (Jan - Jun 1994)GASEOUS EFFLUENTS - GROUND RELEASES

٠.

. .

4

• · 、

					CONTINUO	US MODE	BATCH	MODE
<u>Nucli</u>	<u>des Release</u>	ed		Unit	<u>1st Quarter</u>	2nd Quarter	<u>lst Quarter</u>	2nd Quarter
3)	Particulat	ces						
	Antimony	(Sb)	125	Ci				
	Barium	(Ba)	133	Ci				
	Cadmium	(Cd)	109	Ci				
	Cerium	(Ce)	139	Ci				
	Cerium	(Ce)	141	Ci				
	Cerium	(Ce)	144	Ci				
	Cesium	(Cs)	134	Ci				
	Cesium	(Cs)	137	Ci	1.04E-06	1.00-07		
	Cobalt	(Co)	57	Ci				
	Cobalt	(Co)	58	Ci				
	Cobalt	(Co)	60	Ci				
	Chromium	(Cr)	51	Ci				
	Niobium	(Nb)	95	Ci				
	Strontium	(Sr)	89	Ci				
	Strontium	(Sr)	90	Ci				
	Tin	(Sn)	113	Ci				
TOTAL				Ci	1.04E-06	1.00E-07		



Indian Point 3 EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT

۰.

۰.

•

۰.

C. LIQUID EFFLUENTS

FIRST AND SECOND QUARTERS, 1994

#### TABLE 2A

۰.

6

•• .

#### EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (Jan - Jun 1994)

#### LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

	UNITS	QUARTER 1st	QUARTER 2nd	EST. TOTAL ERROR %
A. Fission and activation products				
<ol> <li>Total release (not including tritium gases, alpha)</li> </ol>	, Ci	2.29E-02	2.19E-02	2.50E+01
<ol> <li>Average diluted concentration during period</li> </ol>	uCi/ml	1.59E-10	1.30E-10	
B. Tritium				
1. Total release	Ci	2.05E-00	9.17E-01	2.50E+01
2. Average diluted concentration during period	uCi/ml	1.42E-08	5.46E-09	
C. Dissolved and entrained gases				
1. Total release	Ci	0.00E-00	0.00E-00	N/A
2. Average diluted concentration during period	uCi/ml	0.00E-00	0.00E-00	
D. Gross alpha radioactivity				
1. Total release	Ci	<1.23E-05	<1.77E-05	2.50E+01
E. Volume of waste released (prior to dilution)	liters	3.07E+05	4.28E+05	1.00E+01
F. Volume of dilution water used during period	liters	1.44E+11	1.68E+11	1.00E+01
G. Percent of liquid effluent limit	8	5.62E-02	4.36E-02	2.50E+01

\_

Docket No. 50-286

IPN-94-108

i.

TABLE 2B										
LIQUID	EFFLUENT	AND	WASTE	DISPOSAL	SEMI - ANNUAL	REPORT	(Jan	-	Jun	<u>1994)</u>

٠.

•

• •

.

••

			CONTINUC	OUS MODE	BATCH MODE		
<u>Nuclides</u>	Released	Unit	<u>lst Quarter</u>	2nd Quarter	<u>lst Quarter</u>	2nd Quarter	
Antimony	(Sb) 124 ·	Ci			3.28E-05		
Antimony	(Sb) 125	Ci			4.59E-04	2.04E-04	
Cobalt	(Co) 57	Ci			7.54E-06	4.75E-06	
Cobalt	(Co) 58	Ci			3.77E-04	8.14E-05	
Cobalt	(Co) 60	Ci			5.36E-03	6.43E-03	
Iron	(Fe) 55	Ci			8.05E-03	7.60E-03	
Manganes	e (Mn) 54	Ci			3.07E-04	3.94E-04	
Nickel	(Ni) 63	Ci			8.29E-03	7.18E-03	
TOTAL FO	R PERIOD		0.00E-00	0.00E-00	2.29E-02	2.19E-02	

		CONTINU	OUS MODE	BAT	CH MODE
Nuclides	Unit	<u>lst Quarter</u>	2nd Quarter	<u>lst Quarter</u>	2nd Quarter
TOTAL DISSOLVED AND					
ENTRAINED GASES	Ci	0.00E-00	0.00E-00	0.00E-00	0.00E-00



Indian Point 3 EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT

• •

D. SOLID WASTE FIRST AND SECOND QUARTERS, 1994



# TABLE 3EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORTJanuary 1 - June 30, 1994SOLID WASTE SHIPMENTS

#### A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (Not irradiated fuel)

· ·		6 Month H	Period		Est. Total
<u>1. Type of Waste</u>	Unit	Class A	Class B	Class C	Error, %
a. Spent resins, filter	m <sup>3</sup>	4.5E+0	0		
sludges, etc.	Ci	1.3E+0	0	0	<u>±25</u>
b. Dry compressible, contam.	m <sup>3</sup>	5.6E+0	0	0	
equipment for burial	Ci	4.4E-3	0	0	<u>±25</u>
c. Irradiated Components	m <sup>3</sup>	0	0	0	
	Ci	0	0	0	N/A
d. Other: Dry compressible,	m <sup>3</sup>	5.0E+1	0	0	
contaminated equip. for volume reduction at	Ci	4.6E-2	0	0	±25
2. Estimate of major nuclide	composi	tion (by ty	vpe of wast	te)	· · · · · ·

		Resin	Dry Burial	Dry Vol. Red
NUCLIDE	<u>UNIT</u>	<u>CLASS A</u>	CLASS A	CLASS A
H-3	£	1.6	0.1	0.1
C-14	æ	4.7	2.3	2.4
Mn-54	8	0.2	1.6	1.6
Fe-55	£	42.5	54.3	54.4
Co-58	S	-	2.8	2.5
Co-60	æ	22.4	28.1	28.2
Ni-59	ક	0.1	0.2	0.2
Ni-63	£	16.6	-	<b>-</b> '
Sb-125	8	1.4	1.1	1.1
Cs-134	8	4.6	1.9	1.9
Cs-137	æ	5.7	7.5	7.6

Percentages of nuclides and total activities are based on a combination of direct measurements and scaling for non-gamma emitting nuclides.

#### 3. Solid Waste Disposition

<u>Number of Shipments</u>	<u>Mode of Transport</u>	<u>Destination</u>		
1	Truck	Barnwell, SC		
1	Truck	SEG, Oak Ridge TN:		
		for volume reduction.		

#### 4. Containers Shipped

	<u>Class A</u>		<u>Class B</u>		<u>Class C</u>	
<u>Container</u>	Number	<u>Solid. Media</u>	Number	Solid. Media	Number	Solid Media
For Burial:						
Poly HIC	1	None	0	N/A	0	N/A
Drums	0	N/A	0	N/A	0	N/A
Steel Liner	: 0	N/A	0	N/A	0	N/A
Crates	2	None	0	N/A	0	N/A
 For Volume		*				
Reduction:						
SeaLand Cor	nt. 1	N/A	0	N/A	0	N/A
Crates	5	N/A	0	N/A	0	N/A



Indian Point 3 EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT

• •

• •

• ' .

E. RADIOLOGICAL IMPACT ON MAN

FIRST AND SECOND QUARTERS, 1994

(not required to be submitted during this reporting period)



### Indian Point 3 EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT

#### F. METEOROLOGICAL DATA

#### FIRST AND SECOND QUARTERS, 1994

(not required to be submitted during this reporting period)



#### Indian Point 3

.

#### EFFLUENT AND WASTE DISPOSAL

#### SEMI-ANNUAL REPORT

G. OFFSITE DOSE CALCULATION MANUAL OR PROCESS CONTROL MANUAL CHANGES

FIRST AND SECOND QUARTERS, 1994

(There were no revisions to the ODCM or PCP during this reporting period)