

50-3

MAR 19 1985

Docket Nos. 50-03
50-247

Consolidated Edison Company
of New York, Inc.
ATTN: Mr. John D. O'Toole
Vice President - Nuclear
Engineering & Quality Assurance
4 Irving Place
New York, New York 10003

Gentlemen:

Reference: Letter dated November 28, 1984, John D. O'Toole to
Stuart Cohen

This is in response to your November 28, 1984, letter concerning Emer-
gency Notification and Health Physics Network telecommunication systems
for the Indian Point Alternate Emergency Operation Facility.

As a general rule, the NRC does not require installation of these
systems in the AEOF, provided that arrangements have been made with the
local phone company such that services can be installed in a matter of
hours in the event of an incident.

If you have additional concerns about this matter, please contact Mr.
Charles G. Amato of my staff at (215) 337-5125.

Sincerely,

Original Signed By:

Walt Pasciak

for:

Thomas T. Martin, Director
Division of Radiation Safety
and Safeguards

cc: C. W. Jackson, Vice President, Nuclear Power
M. Selman, Vice President, Nuclear Power
M. Blatt, Director, Regulatory Affairs
W. D. Hamlin, Assistant to Resident Manager
F. Matra, Resident Construction Manager
R. L. Spring, Nuclear Licensing Engineer
Thomas J. Farrelly, Esquire
K. Burke, General Manager, Administrative Services
Brent L. Brandenburg, Assistant General Counsel
Director, Power Division
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of New York

8503260414 850319
PDR ADOCK 05000003
PDR
F

OFFICIAL RECORD COPY

EB1
11

bcc:
Region I Docket Room (with concurrences)
~~Senior Operations Officer (w/o encls)~~
DRP Section Chief
S. Cohen, ADM
K. Perkins, IE

Ames
RI:DRSS
Gaul/gcb:djh
3/11/85

Amato
RI:DRSS
Amato
3/11/85

UW
RI:DRSS
Harpster
3/13/85

Bellamy
RI:DRSS
Bellamy
3/18/85

Martin
RI:DRSS
Martin
3/14/85

OFFICIAL RECORD COPY

LTRTOCONEDHPNENS - 0002.0.0
01/08/85