

March 1, 2010

Dr. Barry Klein, Vice Chancellor for Research
and Interim Reactor Director
Office of the Chancellor
University of California, Davis
One Shields Avenue
Davis, CA 95616-8558

SUBJECT: UNIVERSITY OF CALIFORNIA, DAVIS/MCCLELLAN NUCLEAR RADIATION
CENTER - NRC INSPECTION REPORT NO. 50-607/2010-201

Dear Dr. Klein:

On February 1-4, 2010, the U.S. Nuclear Regulatory Commission (NRC, the Commission) completed an inspection at the University of California, Davis/McClellan Nuclear Radiation Center (Inspection Report No. 50-607/2010-201). The enclosed report documents the inspection results, which were discussed on February 4, 2010, with Mr. Walter Steingass, Reactor Supervisor, and Mr. David Reap, Radiation Safety Officer.

The inspection examined activities conducted under your license as they relate to safety and compliance with the Commission's rules and regulations and with the conditions of your license. The inspector reviewed selected procedures and records, observed activities, and interviewed personnel. Based on the results of this inspection, no findings of significance were identified. No response to this letter is required.

In accordance with Title 10 of the *Code of Federal Regulations*, Section 2.390, "Public inspections, exemptions, and requests for withholding," a copy of this letter, its enclosure, and your response (if any) will be available electronically for public inspection in the NRC Public Document Room or from the NRC's document system (Agencywide Documents Access and Management System (ADAMS)). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Should you have any questions concerning this inspection, please contact Craig Bassett at (404) 358-6515 or by electronic mail at Craig.Bassett@nrc.gov.

Sincerely,

/RA by Patrick Isaac Acting For/
Johnny H. Eads, Jr., Chief
Research and Test Reactors Oversight Branch
Division of Policy and Rulemaking
Office of Nuclear Reactor Regulation

Docket No.: 50-607
License No.: R-130

Enclosure: NRC Inspection Report No. 50-607/2010-201
cc w/encl: Please see next page

University of California, Davis/McClellan Nuclear Radiation Center

Docket No.: 50-607

cc:

Mr. David Reap, Radiation Safety Officer
5335 Price Avenue, Bldg. 258
McClellan AFB, CA 95652-2504

Mr. Walter Steingass, Reactor Supervisor
5335 Price Avenue, Bldg. 258
McClellan AFB, CA 95652-2504

California Energy Commission
1516 Ninth Street, MS-34
Sacramento, CA 95814

Test, Research, and Training
Reactor Newsletter
University of Florida
202 Nuclear Sciences Center
Gainesville, FL 32611

March 1, 2010

Dr. Barry Klein, Vice Chancellor for Research
and Interim Reactor Director
Office of the Chancellor
University of California, Davis
One Shields Avenue
Davis, CA 95616-8558

SUBJECT: UNIVERSITY OF CALIFORNIA, DAVIS/MCCLELLAN NUCLEAR RADIATION
CENTER - NRC INSPECTION REPORT NO. 50-607/2010-201

Dear Dr. Klein:

On February 1-4, 2010, the U.S. Nuclear Regulatory Commission (NRC, the Commission) completed an inspection at the University of California, Davis/McClellan Nuclear Radiation Center (Inspection Report No. 50-607/2010-201). The enclosed report documents the inspection results, which were discussed on February 4, 2010, with Mr. Walter Steingass, Reactor Supervisor, and Mr. David Reap, Radiation Safety Officer.

The inspection examined activities conducted under your license as they relate to safety and compliance with the Commission's rules and regulations and with the conditions of your license. The inspector reviewed selected procedures and records, observed activities, and interviewed personnel. Based on the results of this inspection, no findings of significance were identified. No response to this letter is required.

In accordance with Title 10 of the *Code of Federal Regulations*, Section 2.390, "Public inspections, exemptions, and requests for withholding," a copy of this letter, its enclosure, and your response (if any) will be available electronically for public inspection in the NRC Public Document Room or from the NRC's document system (Agencywide Documents Access and Management System (ADAMS)). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Should you have any questions concerning this inspection, please contact Craig Bassett at (404) 358-6515 or by electronic mail at Craig.Bassett@nrc.gov.

Sincerely,
/RA by Patrick Isaac Acting For/
Johnny H. Eads, Jr., Chief
Research and Test Reactors Oversight Branch
Division of Policy and Rulemaking
Office of Nuclear Reactor Regulation

Docket No.: 50-607
License No.: R-130
Enclosure: NRC Inspection Report No. 50-607/2010-201
cc w/encl.: Please see next page

DISTRIBUTION:

PUBLIC PRTB r/f RidsNrrDprPrta Resource RidsNrrDprPrtb Resource
MNorris (MS T3B46M) MCompton (Ltr only O5-A4) GLappert, NRR
AAdams, NRR

ACCESSION NO.: ML100541155 *concurrence via e-mail **TEMPLATE #:** NRC-002

OFFICE	PROB:RI *	PRPB:LA	PROB:BC
NAME	CBassett	GLappert	JEads (Pisaac for)
DATE	2/9/2010	3/1/2010	3/1/2010

OFFICIAL RECORD COPY

U. S. NUCLEAR REGULATORY COMMISSION
OFFICE OF NUCLEAR REACTOR REGULATION

Docket No: 50-607

Report No: 50-607/2010-201

Licensee: University of California, Davis

Facility: McClellan Nuclear Radiation Center

Location: McClellan Park
Sacramento, California

Dates: February 1-4, 2010

Inspector: Craig Bassett

Approved by: Johnny H. Eads, Jr., Chief
Research and Test Reactors Oversight Branch
Division of Policy and Rulemaking
Office of Nuclear Reactor Regulation

EXECUTIVE SUMMARY

University of California, Davis
McClellan Nuclear Radiation Center
Report No: 50-607/2010-201

The primary focus of this routine, announced inspection was the onsite review of selected aspects of the University of California, Davis (the licensee's) 2 Megawatt (MW) Class I research and test reactor safety program including: 1) organization and staffing, 2) review and audit and design change functions, 3) reactor operations, 4) operator requalification, 5) maintenance and surveillance, 6) fuel handling, 7) experiments, 8) procedures and procedural control, and 9) emergency preparedness since the last U.S. Nuclear Regulatory Commission (NRC) inspection of these areas. The licensee's program was acceptably directed toward the protection of public health and safety and in compliance with NRC requirements. No violations or deviations were identified.

Organization and staffing

- The organizational structure and staffing had not changed since the last inspection and were generally consistent with Technical Specification requirements.

Review and Audit and Design Change Functions

- The Nuclear Safety Committee was meeting semiannually and reviewing the topics outlined in the Technical Specifications and conducting annual audits of facility programs as required.
- The review, evaluation, and documentation of changes to the facility satisfied NRC requirements.

Reactor Operations

- Reactor operations were conducted in accordance with procedure and the appropriate logs were being maintained.
- Because of the age of the core, the licensee had only limited operational capacity.

Operator Requalification

- Operator requalification was conducted as required by the Requalification Program and the program was being maintained up-to-date.
- Medical examinations were being completed for each operator biennially as required.

Maintenance and Surveillance

- The Preventive Maintenance Program was being used to effectively accomplish the various maintenance and required surveillance activities at the facility.

Fuel Handling

- Fuel movements and inspections were conducted in accordance with Technical Specification and procedural requirements.

Experiments

- The program for reviewing and conducting experiments satisfied procedural and Technical Specification requirements.

Procedures

- The procedure review, revision, control, and implementation program satisfied Technical Specification requirements.

Emergency Preparedness

- The emergency preparedness program was conducted in accordance with the Emergency Plan.
- Emergency response equipment was being maintained and alarms were being tested as required.
- The Memorandum of Understanding between the County of Sacramento and McClellan Park and the one between the facility and the University of California, Davis Medical Center were being maintained.
- Emergency drills were being conducted annually as required by the Emergency Plan.
- Emergency preparedness training for Senior Reactor Operator personnel was being completed through the Requalification Program.

REPORT DETAILS

Summary of Plant Status

The University of California, Davis (the licensee's) two megawatt (2 MW) Class I TRIGA Mark-II research and test reactor continued to be operated in support of neutron radiography, medical isotope production, neutron tomography, and sample/product irradiation. During the inspection, the reactor was operated several hours per day to support neutron radiography.

1. Organization and Staffing

a. Inspection Scope (Inspection Procedure [IP] 69006)

The inspector reviewed the following regarding the University of California, Davis/McClellan Nuclear Radiation Center (UCD/MNRC) organization, staffing, and staff responsibilities to ensure that the requirements of License Amendment No. 6 (which included Technical Specification (TS) Section 6.1, Revision (Rev.) Number (No.) 13) dated November 25, 2003, were being met:

- Management responsibilities
- Qualifications of facility personnel
- Current UCD/MNRC organizational structure
- Staffing requirements for safe operation of the research reactor facility
- Facility Procedure UCD/MNRC-0004-DOC-13, "Technical Specifications for the University of California, Davis/McClellan Nuclear Radiation Center (UCD/MNRC)," Rev. 13, approval dated March 28, 2003
- Facility Procedure UCD/MNRC-0045-DOC, "Quality Assurance Program for McClellan Nuclear Radiation Center (MNRC)," Rev. 1, approval dated November 22, 1999
- University of California, Davis/McClellan Nuclear Radiation Center 2007 Annual Report, submitted to the NRC on June 13, 2008
- University of California, Davis/McClellan Nuclear Radiation Center 2008 Annual Report, submitted to the U. S. Nuclear Regulatory Commission (NRC) on June 17, 2009
- American Nuclear Society Standard (ANS/ANSI) 15.4 - 1988, "Selection and Training of Personnel for Research Reactor," approved June 9, 1988

b. Observations and Findings

During a previous NRC inspection of facility staffing in January 2008, it was noted that the reactor operations staff consisted of five licensed Senior Reactor Operators (SROs). The inspector noted that this had not changed and that all of the SROs continued to serve in other capacities at the facility. One SRO was the Reactor Supervisor, another was the Building Manager, one SRO was the Radiography Supervisor, one was a qualified radiographer, and the other had been designated as the facility Radiation Safety Officer. From a review of records and interviews with the staff, the inspector determined that the staff members satisfied the training and experience requirements associated with their respective positions.

It was noted that, in addition to the two radiographers noted above, there was one other individual employed at the facility who was a qualified radiographer. The inspector also found that all facility operations personnel had received additional training in radiation protection survey techniques and instrumentation as well. Staffing appeared to be adequate for the current level of operation but any increase in workload would necessitate an increase in the number of staff to provide for safe operation of the facility.

The inspector noted that the licensee had completed work on a TS change that would bring the organizational structure specified in the TS into agreement with actual conditions at the facility (see Section 10 below). This change had been sent to the Chairman of the Nuclear Safety Committee for review prior to being submitted to the NRC.

c. Conclusions

The licensee's organization and staffing remain in general compliance with the requirements specified in TS Section 6.

2. Review and Audit and Design Change Functions

a. Inspection Scope (IP 69007)

To verify that the required reviews and audits were being completed by the licensee and to ensure that facility changes were reviewed and approved as required by TS Section 6.2, the inspector reviewed selected aspects of:

- Annual Audits conducted in 2008 and 2009
- Nuclear Safety Committee (NSC) meeting minutes for December 2008 through the present
- UCD/MNRC Facility Modification Notebook containing Facility Modification Log Forms
- Selected Facility Modification Installation Authorization Forms and the associated Facility Modification Checklist Forms processed during 2008 and 2009
- Facility Procedure UCD/MNRC-0043-DOC, "Facility Modification Procedure," Rev. 4, approval dated January 8, 2008
- Facility Procedure UCD/MNRC-0045-DOC, "Quality Assurance Program for McClellan Nuclear Radiation Center (MNRC)," Rev. 1, approval dated November 22, 1999
- University of California, Davis/McClellan Nuclear Radiation Center 2007 Annual Report, submitted to the NRC on June 13, 2008
- University of California, Davis/McClellan Nuclear Radiation Center 2008 Annual Report, submitted to the NRC on June 17, 2009
- Charter of the Nuclear Safety Committee (NSC) for the University of California, Davis/McClellan Nuclear Radiation Center (UCD/MNRC), Rev. 3, approval by the Chair of the NSC dated January 25, 2010

b. Observations and Findings

(1) Review and Audit Functions

Composition of the NSC and qualifications of NSC members were as specified in TS 6.2.1. Minutes of NSC meetings demonstrated that the committee met semiannually as required by TS 6.2.2 and provided the reviews and oversight specified in TS 6.2.3. Through records review the inspector determined that safety reviews were conducted by the NSC or a designated representative. Topics of those reviews were as required by the TS and provided sufficient guidance, direction, and oversight to ensure acceptable use of the reactor.

The inspector noted that the annual audit for 2008 was adequate and reviewed the activities specified in TS 6.2.4 including various aspects of the reactor facility operations and programs. It was noted that the audit had been completed by the Chair of the NSC in August of that year. The audit appeared to be adequate and included recommendations concerning the use of some radiation monitoring equipment and an independent review of the proposed use of a new type of fuel at the facility. An independent review had subsequently been completed and verified the results of an "in-house" review of the new type of fuel. The 2009 facility audit had also been conducted by the Chair of the NSC and was completed December 21, 2009. However, a report documenting the results of the audit was not available during the time of the inspection. The audit will be reviewed during a future inspection.

(2) Design Change Functions

To satisfy the regulatory requirements stipulated in Section 50.59 of Title 10 of the *Code of Federal Regulations*, "Changes, tests, and experiments," the licensee had implemented Facility Procedure UCD/MNRC-0043-DOC, "Facility Modification Procedure." The procedure was developed to address activities that affected changes to the facility as described in the Safety Analysis Report (SAR), changes to MNRC procedures, and changes to, or development of, tests or experiments not described in the SAR. The procedure adequately incorporated criteria provided by the regulations with additional requirements mandated by local conditions.

The inspector verified that, as required by procedure, all proposed facility modifications were presented to a Modification Review Committee (MRC) for screening and classification. The MRC classified the modifications (mods) as Class I, Class II, or Class III. Class I mods were those requiring extensive changes that would involve a change to the TS or the SAR and would require NRC approval. Class II mods were those that resulted in a basic configuration change of a facility system or equipment but would not require a change to the TS or SAR. Class III mods were those that did not result in a basic configuration change and would not change form, fit, or function of the system under consideration.

The various proposed mods at the facility and the supporting documentation were compiled into modification packages. These were then processed through and controlled by the Reactor Supervisor. In addition to the MRC screening, the packages were required to be reviewed by the Reactor Supervisor and a Health Physics representative and then approved by the Facility Director. All Class I and II changes and modifications were required to be reviewed and approved by the NSC.

The inspector reviewed selected Facility Modification Installation Authorization Forms and the associated Facility Modification Checklist forms processed during 2008, 2009, and to-date in 2010. The completed forms showed that the proposed modifications were acceptably reviewed in accordance with the procedure. It was noted that all the modifications proposed recently were designated as Class III and therefore no 50.59 evaluations were required to be completed. As a result, none of the changes or modifications was determined to constitute a safety question or concern and none required a license or TS amendment. The only item(s) required for each of the latest changes was a design drawing change or the development of a new procedure.

b. Conclusions

The NSC was meeting semiannually and reviewing the topics outlined in the TS and conducting annual audits of facility programs as required. The design change program satisfied NRC requirements.

3. Reactor Operations

a. Inspection Scope (IP 69006)

To verify that the licensee was operating the reactor and conducting operations in accordance with TS Section 3 and procedural requirements, the inspector reviewed selected portions of the following:

- Various UCD/MNRC Startup Checklist Forms for 2009 and to-date in 2010
- Selected UCD/MNRC Shutdown Checklist Forms for 2009 and to-date in 2010
- Various UCD/MNRC Facility Rounds Log Forms for 2009 and to-date in 2010
- Selected UCD/MNRC Operations Log Pages from Log Book No. 122 through Log Book No. 127
- Facility Procedure UCD/MNRC-0016-DOC, "UCD/MNRC Operating Instructions" Rev. 11, approval dated January 16, 2002
- Facility Procedure UCD/MNRC-0073-DOC, "UCD/MNRC Reactor Control Room Computer Operating Instructions" Rev. 3, approval dated June 27, 2006

- University of California, Davis/McClellan Nuclear Radiation Center 2007 Annual Report submitted to the NRC June 13, 2008
- University of California, Davis/McClellan Nuclear Radiation Center 2008 Annual Report, submitted to the NRC on June 17, 2009

b. Observations and Findings

(1) Routine Operations

The inspector reviewed selected UCD/MNRC Startup and Shutdown forms, Rounds Log sheets, and Operations Log entries dating from 2009 through the date of this inspection. The operating logs and checklists were complete and provided an acceptable indication of operational activities. The logs and checklists showed that operational conditions and parameters were consistent with license and TS requirements and that TS operational limits had not been exceeded. The logs were also used to record problems with equipment resulting in "call backs" (when licensee personnel had to return to the facility after hours to respond to an alarm) and to record abnormal events or anomalies. Emergency shutdowns and inadvertent scrams were also noted in the logs. These were then documented in the licensee's Monthly Reports and reported in Annual Reports submitted to the NRC.

The inspector observed facility activities on various occasions during the week including routine reactor operations and the handling of items that were being radiographed. The operations and item handling were conducted in accordance with the applicable procedures and the actions were documented in the required logs. The inspector was also able to observe a reactor startup and/or a reactor shutdown on two separate occasions during the inspection. These activities were completed according to procedure and the appropriate checklists and logs were filled out as well.

(2) Limited Operational Capacity

During the review of the daily operations of the facility, it was noted that normal reactor operations up to 2 MW were authorized by the facility license, the TS, and the SAR. As a result of fuel burnup over the years, the licensee had made adjustments to the operating schedule and typically operated at no more than 1 MW on a daily basis. Because of this, some experiments required more time to complete. Although additional new fuel has been manufactured, none has been delivered to the facility to date.

c. Conclusions

UCD/MNRC reactor operations were conducted in accordance with procedure and the appropriate logs were being maintained. Because of the age of the core, the licensee had limited operational capacity.

4. Operator Requalification

a. Inspection Scope (IP 69003)

To verify that the licensee was complying with TS Section 6.1.4 and the facility Operator Training and Requalification Program, the inspector reviewed selected aspects of:

- Status of active operator licenses
- Selected operator physical evaluation records for the past three years
- Training Schedule for Maintenance of Qualifications for SROs for the 2008-2010 requalification cycle
- Operator active duty status documented on MNRC Personnel Reactivity Manipulations and Active Duty Performance Record forms for 2008 and 2009 and to date in 2010
- Operator training and lecture attendance records for 2008 through 2010 documented on MNRC Training Attendance Record forms
- Selected records for 2008 and 2009 documented on UCD/MNRC Reactor Facility annual Operating Test for Senior Reactor Operators and Reactor Operators Forms and MNRC Senior Reactor Operator Requalification Written Examination Forms
- Facility Procedure UCD/MNRC-0009-DOC, "Selection and Training Plan for Reactor Personnel," Rev. 4, approval dated January 18, 2000
- University of California, Davis/McClellan Nuclear Radiation Center 2007 Annual Report submitted to the NRC June 13, 2008
- University of California, Davis/McClellan Nuclear Radiation Center 2008 Annual Report, submitted to the NRC on June 17, 2009
- ANS/ANSI Standard 15.4-1988, "Selection and Training of Personnel for Research Reactors," approved June 9, 1988

b. Observations and Findings

As noted above, there were five qualified SROs on staff at the facility. The inspector verified that all operators' licenses were current. As of the date of the inspection, there was no one officially designated as "in training" to become a Reactor Operator.

The inspector noted that the Requalification Program was being implemented and maintained as required. MNRC Personnel Reactivity Manipulations and Active Duty Performance Records and logs showed that operators were maintaining active duty status as required. A review of the logs and records also showed that training was being conducted in accordance with the approved requalification and training program. Procedure reviews and examinations had been documented as required. Records of quarterly reactor operations, reactivity manipulations, other operations activities, and Reactor Supervisor activities were being maintained. Records indicating the completion of annual operations tests and supervisory observations were also being maintained as required. Biennial written examinations were being completed by the operators as required as well.

During the inspection it was noted that three operators' licenses were due to expire in the July/August time frame of 2010. The licensee was aware of this and was preparing the applicable license renewal application packages which were to be forwarded to the NRC in early summer.

In addition, the inspector noted that all operators were receiving the biennial medical examinations required by the program in accordance with ANS/ANSI 15.4-1988.

c. Conclusions

Operator requalification was being completed and being maintained up-to-date as required by the Requalification Program.

5. Maintenance and Surveillance

a. Inspection Scope (IP 69006, 69010)

To verify that the licensee was meeting the requirements of their Preventive Maintenance Program and complying with TS Section 4, the inspector reviewed selected aspects of:

- UCD/MNRC Reactivity Tables
- Danger/Caution Tag Issue Forms and log
- Selected UCD/MNRC Control Rod Calibration Forms for 2009
- Various UCD/MNRC Calorimetric Power Calibration Forms for 2009
- Selected UCD/MNRC Reactor Shutdown Margin Data Sheets for 2009
- Selected UCD/MNRC Work Order Tracking Sheets for 2009 and 2010
- Various UCD/MNRC Operations Log pages from Log Book No. 122 through Log Book No. 127
- UCD/MNRC Preventive Maintenance Schedule for the Month of January 2010
- Preventive Maintenance Program database maintained on the Control Room computer which included entries denoting equipment history
- McClellan Nuclear Radiation Center Preventive Maintenance System - Twelve Month Schedule for the period from March 2009 through February 2010
- Selected MNRC Work Order forms documenting various completed and pending maintenance tasks
- Facility Procedure UCD/MNRC-0007-DOC, "Maintenance Procedures," Rev. 5, approval dated November 23, 2005
- Facility Procedure UCD/MNRC-0030-DOC, "MNRC Tag-Out Procedure," Rev. 5, approval dated January 24, 2007
- Operation and Maintenance Manual (OMM) procedures including:
 - Facility Procedure UCD/MNRC-0012-OMM 5110, "Primary Cooling System," Rev. 5, approval dated November 12, 1999
 - Facility Procedure UCD/MNRC-0013-OMM 5140, "Control Rod Drives," Rev. 4, approval dated November 3, 2000

- Facility Procedure UCD/MNRC-0019-OMM 5220, "Fuel Handling Tools," Rev. 4, approval dated January 12, 2009
- Facility Procedure UCD/MNRC-0036-OMM 5510, "MNRC Pneumatic Transfer System," Rev. 4, approval dated May 3, 2000
- Facility Procedure UCD/MNRC-0038-OMM 5330, "Nuclear Instrumentation," Rev. 1, approval dated November 18, 2008
- Facility Procedure UCD/MNRC-0039-OMM 5420, "Personnel Shield and Radiography Shutter," Rev. 3, approval dated January 11, 2008
- Facility Procedure UCD/MNRC-0061-OMM 5310, "Control System Console," Rev. 1, approval dated September 17, 2008
- Facility Procedure UCD/MNRC-0063-OMM 5340, "Reactor Protection System," Rev. 1, approval dated November 14, 2008
- Facility Procedure UCD/MNRC-0071-OMM 5160, "Emergency Core Cooling System," Rev. 0, approval dated June 29, 1998
- University of California, Davis/McClellan Nuclear Radiation Center 2007 Annual Report submitted to the NRC June 13, 2008
- University of California, Davis/McClellan Nuclear Radiation Center 2008 Annual Report, submitted to the NRC on June 17, 2009

b. Observations and Findings

The inspector reviewed the Preventive Maintenance Program that the licensee had developed to schedule and track maintenance activities. The program was maintained on an EXCEL database system and was designed to ensure that all maintenance activities were completed as required. It was also used to ensure that post maintenance testing was conducted and that the entire process was documented appropriately. In addition, the database was also set up to enable the licensee to maintain equipment histories for the various systems, components, and instruments in the program.

The inspector noted that periodic TS-required surveillance activities such as tests, checks, verifications, and calibrations were scheduled through the Preventive Maintenance Program as well. The program was designed to generate a work schedule for facility personnel. Weekly, monthly, and annual schedules were available as needed. The work schedules listed all the maintenance and surveillance activities that needed to be completed during the specified time interval.

The Preventive Maintenance Program not only produced weekly/monthly work schedules, but was set up to generate MNRC Work Orders (MWOs). The MWOs were used to complete the maintenance and/or surveillance activities. Most work was completed on Mondays during the routine scheduled reactor shutdown. It was noted that the MWOs were assigned to a lead SRO who was responsible to ensure that the work was performed and the results were recorded on the MWO. The data from each MWO was typically entered into the computerized tracking system by the Building Manager. The inspector reviewed selected data recorded in the database and on the MWOs for various TS required surveillances. The records indicated that the required tests, checks, verifications, and calibrations had been completed on schedule and in accordance with licensee procedures.

The results reviewed by the inspector were found to be within the TS and procedurally prescribed parameters.

c. Conclusions

The MNRC Preventive Maintenance Program was being used to effectively accomplish maintenance and surveillance activities at the facility.

6. Fuel Handling

a. Inspection Scope (IP 69009)

To ensure that the licensee was following the requirements of TS Sections 3.2.4, 4.2.4, and 5.3, the inspector reviewed selected aspects of the following:

- Selected Fuel Inspection Sheets for 2009
- Various UCD/MNRC Fuel Transfer Forms
- Selected UCD/MNRC Present Element Location Forms
- Fuel Handling Checklists for fuel handling in December 2009
- Selected entries in the UCD/MNRC Fuel Measurement Notebook
- Various Fuel Movement Sheets - developed prior to fuel movements
- Selected UCD/MNRC Fuel Element Tracking Information Log Sheets
- Various entries in the UCD/MNRC Fuel Measurement Data Notebook detailing fuel element measurements
- Selected UCD/MNRC Operations Log pages from Log Book No. 122 through Log Book No. 127
- Selected Visual Inspection Forms completed for fuel elements inspected in 2009
- Core Fuel Status and Storage Boards located in the Control Room and in the Reactor Room indicating fuel element locations
- Facility Procedure UCD/MNRC-0019-OMM 5220, "Fuel Handling Tools," Rev. 4, approval dated January 12, 2009
- Facility Procedure UCD/MNRC-0011-OMM 5240, "Fuel," Rev. 5, approval dated April 19, 2001

b. Observations and Findings

The inspector reviewed the fuel movement process and verified that fuel was moved according to established procedure and in conjunction with the specific fuel movement sheets developed by an SRO for each evolution. The inspector reviewed fuel movement sheets for 2009. They had been initiated and used for fuel inspection and for transferring fuel from the core to storage and from storage to the core. The inspector also compared the location of fuel elements in the reactor core with the information maintained on the Fuel Status Board in the Control Room and on the fuel movement sheet for the latest core, the Mixed "J" Core. No problems were noted.

The inspector also reviewed selected fuel inspection sheets that had been completed for 2009. The inspections were completed annually in compliance

with TS Section 3.2.4. It was also noted that fuel handling tools were being properly maintained and controlled/secured.

c. Conclusions

Fuel movements and inspections were conducted in accordance with TS and procedural requirements.

7. **Experiments**

a. Inspection Scope (IP 69005)

The inspector reviewed selected aspects of the following to verify compliance with TS Sections 3.8, 4.8, and 6.5:

- Various UCD/MNRC Irradiation Request Forms
- Various UCD/MNRC Irradiation Summary Forms
- Listing of current experiments and authorized users
- Selected UCD/MNRC Experimenter Certification Forms
- Various UCD/MNRC Experimenter Approval Request Forms
- Selected UCD/MNRC Irradiation Tracking Sheets for 2009 and 2010
- Various UCD/MNRC Operations Log pages from Log Book No. 122 through Log Book No. 127
- Selected UCD/MNRC Experiment Request Forms documenting:
 - Experiment Approval No.: K-4-1, "Radiography of Aircraft Parts," UCD/MNRC Director's approval dated March 16, 2005
 - Experiment Approval No.: K-4-2, "General Radiography," UCD/MNRC Director's approval dated October 9, 2007, with Amendment for "Using Hydrogen as a Contrast Agent," UCD/MNRC Director's approval dated March 16, 2005
 - Experiment Approval No.: K-4-44, "INAA of Basalt Using the Central Irradiation Facility," UCD/MNRC Director's approval dated March 19, 2004
 - Experiment Approval No.: K-4-47, "La-139 Irradiation," UCD/MNRC Director's approval dated July 31, 2008
- Completed Facility Use Authorization Forms including:
 - Facility Use Authorization No. UCD/MNRC-001, "Radiography of Aircraft Parts," NSC approval dated February 7, 2000
 - Facility Use Authorization No. UCD/MNRC-002, "Irradiation of Materials in the UCD/MNRC Reactor In-core Irradiation Facilities," NSC approval dated February 7, 2000
 - Facility Use Authorization No. UCD/MNRC-003, "Irradiation of Materials Using the Pneumatic Transfer System," NSC approval dated February 7, 2000
 - Facility Use Authorization No. UCD/MNRC-004, "Radiography Bay Irradiations," NSC approval dated February 7, 2000
 - Facility Use Authorization No. UCD/MNRC-006, "In-Tank/Out-of Core Irradiation and Irradiation Fixtures," NSC approval dated February 7, 2000

- Facility Procedure UCD/MNRC-0027-DOC, "Utilization of the University of California, Davis/McClellan Nuclear Radiation Center Research Reactor Facility," Rev. 7, approval dated January 18, 2000
- Facility Procedure UCD/MNRC-0033-DOC, "University of California, Davis/McClellan Nuclear Radiation Center Research Reactor Facility Experiment Review and Authorization Process," Rev. 5, approval dated July 2, 2003
- Facility Procedure UCD/MNRC-0081-DOC, "UCD/MNRC Experiment Coordination Checklist," Rev. 0, approval dated October 24, 2000
- University of California, Davis/McClellan Nuclear Radiation Center 2007 Annual Report submitted to the NRC June 13, 2008
- University of California, Davis/McClellan Nuclear Radiation Center 2008 Annual Report, submitted to the NRC on June 17, 2009

b. Observations and Findings

The experiments conducted at the facility were well established and had been reviewed and approved as required. The inspector noted that three new experiments were being contemplated involving fuel cell research, Iodine-125 production, and Molybdenum-99 production. The licensee was aware that each would need to be reviewed and evaluated by the Experiment Review Board (ERB) using the process stipulated in Facility Procedure UCD/MNRC-0027-DOC, "Utilization of the University of California, Davis/McClellan Nuclear Radiation Center Research Reactor Facility." The procedure required any approved experimenter who proposed a new experiment to complete an Experiment Request Form and submit it to the Experiment Coordinator at the facility. The Experiment Request Form required an evaluation of the target material. This was to verify that, if performed within the guidelines stated in the safety analysis, the irradiation experiment would remain within the TS limits for experiments. The evaluation was to also include a safety analysis which consisted of a review of various operational, radiological, and safety considerations and limitations. The experimenter had to ensure that the proposed experiment would meet the conditions established for one of five approved Facility Use Authorizations. The request then had to be reviewed by the Experiment Coordinator, and by the ERB (as noted above), and be approved by the MNRC Facility Director. All new or revised experiments were also required to be reviewed and approved by the NSC.

The inspector reviewed several experiments or revisions that had been submitted. The evaluation/safety analysis for each had been performed and the reviews and approvals completed by the ERB, the MNRC Facility Director, and the NSC. The experiments were conducted using an approved Facility Use Authorization and Experiment Approval Number and under the cognizance of the Reactor Supervisor and the SRO, and in accordance with TS requirements (e.g., reactivity limitations). The results of the experiments were documented on the appropriate Irradiation Request Forms (IRFs) which listed the conditions of the irradiation and the radiological survey results of the material when removed from the reactor. If the irradiated material was found to be radioactive following removal from the reactor, the IRFs also typically included information on the final

disposition of the irradiated material (i.e., to whom the material was transferred and documentation of their license to receive the material).

c. Conclusions

The program for reviewing and conducting experiments satisfied TS and procedural requirements.

8. Procedures

a. Inspection Scope (IP 69008)

To verify compliance with TS Section 6.4, the inspector reviewed selected portions of the following:

- “Document Review” forms completed by staff members
- “UCD/MNRC Controlled Document Review and Approval Reference List”
- MNRC Document List including the procedure number and title, individual responsible for the review, and date of the last review
- Various memoranda from the Reactor Supervisor to the staff indicating document review assignments and due dates
- Facility Procedure UCD/MNRC-0005-DOC, “Document Control Plan,” Rev. 9, approval dated February 16, 2007

b. Observations and Findings

TS Section 6.4 required that procedures be prepared and approved for the activities listed in that section. The procedures were required to be approved by the UCD/MNRC Director. Changes to the procedures also required the approval of the UCD/MNRC Director and all changes were required to be documented. The inspector noted that the appropriate facility procedures had been developed for the activities as required by the TS and had been approved by the Director. Also, recent changes had been approved by the Director as well.

Various members of the facility staff were required to perform periodic reviews of the procedures to assure that they were current. The completion of these reviews was tracked by the Reactor Supervisor. The inspector determined that biennial reviews of the maintenance procedures and annual reviews of the other types of procedures were generally being completed as required.

c. Conclusions

The current procedure review, revision, control, and implementation program satisfied TS requirements.

9. Emergency Preparedness

a. Inspection Scope (IP 69011)

The inspector reviewed selected aspects of the following to verify compliance with the UCD/MNRC-0001-DOC, "Emergency Plan for the University of California, Davis - McClellan Nuclear Radiation Center (UCD/MNRC)," Rev. 8, approval by the NSC Chairman dated June 12, 2006:

- Assistance to be provided by offsite support groups
- 2008 and 2009 emergency drill documentation and critiques
- Memorandum of Understanding with the UCD Medical Center dated May 1, 2006
- Memorandum of Understanding dated November 23, 2004, between the County of Sacramento and McClellan Park
- Training Schedule for Maintenance of Qualifications for SROs for the 2008-2010 requalification cycle
- Facility Procedure UCD/MNRC-0018-DOC, "University of California, Davis/McClellan Nuclear Radiation Center Emergency Procedures," Rev. 7, approval dated November 11, 2007
- Facility Procedure UCD/MNRC-0078-DOC, "UCD/MNRC Emergency Procedures for Emergency Response Personnel – Class 0 Emergency - Personnel and Operation Events," Rev. 2, approval dated October 27, 2005
- Facility Procedure UCD/MNRC-0079-DOC, "UCD/MNRC Emergency Procedures for Emergency Response Personnel - Class I Emergency - Notification of Unusual Events," Rev. 2, approval dated October 27, 2005
- Facility Procedure UCD/MNRC-0080-DOC, "UCD/MNRC Emergency Procedures for Emergency Response Personnel – Class II Emergency - Alert," Rev. 2, approval dated October 27, 2005

b. Observations and Findings

The inspector reviewed the Emergency Plan (E-Plan) in use at the reactor and verified that it was reviewed biennially as required. The inspector also reviewed the UCD/MNRC Emergency Procedures. It was noted that the procedures were reviewed annually and revised as needed to ensure effective implementation of the E-Plan.

Through records review and interviews with SRO personnel (e.g., emergency responders), the inspector determined that they were knowledgeable of the proper actions to take in case of an emergency. Training for these individuals had been conducted annually through the Requalification Program and documented acceptably. Training for support organization personnel was provided whenever those organizations' schedules would permit.

The inspector verified that the Memorandum of Understanding (MOU), dated November 23, 2004, between the County of Sacramento and McClellan Park remained in effect. The MOU stipulated that the Sacramento Metropolitan Fire

District (SMFD) would be available during an emergency and would provide support for the facility. The inspector also verified that the MOU between the UCD/MNRC facility and UC Davis Medical Center (UCDMC) remained in effect. That MOU indicated that the UCDMC would provide the MNRC with needed support in case of any event involving a medical emergency.

Communications capabilities with support groups were acceptable and the various items of equipment (e.g., telephones and the building public address [PA] system) were in use daily. Portable radios and a portable PA device were also available for use as needed and were checked semiannually. Emergency Call Lists had been revised and updated as needed and were available in the Control Room and in the various Emergency Cache Kits as required. The inspector also verified that emergency equipment, including decontamination material, was available and was being inventoried semiannually as required by the E-Plan.

The documentation of the training and drills conducted during the past two years was reviewed. Emergency preparedness and response training was being completed typically just prior to the drills during the meetings held to prepare for the drills. Through drill scenario and record reviews, and personnel interviews, off-site emergency responders were determined to be knowledgeable of the proper actions to take in case of an emergency. Emergency drills had been conducted annually and had included participation of off site support groups every other year as required by the E-Plan. Critiques were written following the drills to document the strengths and weaknesses identified during the exercise. Action items, if needed, were developed to correct the problems noted.

The inspector met with the Captain of the UC Davis Fire Department (FD). The inspector determined that FD representatives were familiar with the MNRC facility and were involved with various aspects of the operation including reviewing experiments that had been proposed for the facility. There appeared to be a good working relationship between the licensee and this support group.

c. Conclusions

The emergency preparedness program was being conducted in accordance with the Emergency Plan.

10. Follow-up on Previous Identified Items

a. Inspection Scope (IP 92701)

The inspector reviewed the licensee's actions taken in response to previously identified Inspector Follow-up Items (IFIs) in NRC Inspection Report No. 50-607/2006-201, dated August 23, 2006.

b. Observation and Findings

- (1) (Open) IFI 50-607/2006-201-01 - Follow-up on the licensee's actions to update and correct the organizational chart specified in the TS by submitting the appropriate TS change request.

During an inspection in August 2006, the inspector determined that the licensee's organizational chart for the UCD/MNRC stipulated that the chain of command included an "Operations Manager" who would be in charge of reactor operations and to whom the Reactor Supervisor would report. The chart also included a staff position designated as "HP (Health Physics) Supervisor." Since these two positions were not part of the current organization, the inspector questioned the licensee about this. The licensee indicated that a TS change had been prepared but had not been submitted as of the date of that inspection.

The inspector reviewed this issue with the licensee. The licensee had developed a change to the TS concerning the organization and was preparing to submit it to the NRC. Review of the change by the NSC was still in progress at the time of this inspection. This issue remains open.

- (2) (Open) IFI 50-607/2006-201-02 - Follow-up on the licensee's actions to update facility drawings so that they reflect current plant conditions.

During the inspection referenced above, the inspector also reviewed selected Facility Modification Installation Authorization Forms and the associated Facility Modification Checklist Forms. The completed forms showed that the proposed modifications (mods) were acceptably reviewed in accordance with the procedure. However, the inspector noted that some of the 2005 facility modification packages had not been closed out. The licensee indicated that this was because the mods required a change to specific facility drawings and that those changes had not been completed. Other modification work was still ongoing.

The issue was reviewed with the licensee during this inspection. The licensee had not been able to locate anyone who could help with updating the facility drawings. The issue remains open.

c. Conclusions

Two Inspector Follow-up Items identified during a previous inspection were reviewed during this inspection but neither was closed.

11. Exit Interview

The inspection scope and results were summarized on February 4, 2010, with members of licensee management and staff. The inspector described the areas inspected and discussed in detail the inspection findings. The licensee acknowledged the findings presented and did not identify as proprietary any of the material provided to or reviewed by the inspector during the inspection. No dissenting comments were received from the licensee.

PARTIAL LIST OF PERSONS CONTACTED

Licensee Personnel

H. Bollman	Building Manager and SRO
M. Boussoufi	Experiment Coordinator
B. Klein	UCD Vice Chancellor for Research and Interim MNRC Reactor Director
R. Miller	Level II Radiographer and SRO
D. Reap	Radiation Safety Officer and SRO
W. Steingass	Reactor Supervisor and SRO

Other Personnel

M. Lagunas-Solar	Chief, Chemistry and Agriculture Program, Crocker Nuclear Laboratory, UCD, and member of the MNRC Nuclear Safety Committee
J. Patterson	Chief, UCD Fire District
J. Shackelford	Professor, Department of Chemical Engineering and Materials Science, UCD, and member of the MNRC Nuclear Safety Committee

INSPECTION PROCEDURE USED

IP 69003	Class I Research and Test Reactor Operator Licenses, Requalification, and Medical Activities
IP 69005	Class I Research and Test Reactor Experiments
IP 69006	Class I Research and Test Reactor Organization, Operations, and Maintenance Activities
IP 69007	Class I Research and Test Reactor Review and Audit and Design Change Functions
IP 69008	Class I Research and Test Reactor Procedures
IP 69009	Class I Research and Test Reactor Fuel Movement
IP 69010	Class I Research and Test Reactor Surveillance
IP 69011	Class I Research and Test Reactor Emergency Preparedness
IP 92701	Follow-up on Previously Identified Items

ITEMS OPENED, CLOSED, AND DISCUSSED

Opened

None

Closed

None

Discussed

50-607/2006-201-01	IFI	Follow-up on the licensee's actions to update and correct the organizational chart specified in the TS by submitting the appropriate TS change request.
--------------------	-----	---

50-607/2006-201-02 IFI Follow-up on the licensee's actions to update facility drawings so that they reflect current plant conditions.

PARTIAL LIST OF ACRONYMS USED

10 CFR	Title 10 of the <i>Code of Federal Regulations</i>
E-Plan	Emergency Plan
ERB	Experiment Review Board
HP	Health Physics
IFI	Inspector Follow-up Item
IP	Inspection procedure
IRF	Irradiation Request Form
LOA	Letter of Agreement
MNRC	McClellan Nuclear Radiation Center
Mod.	Modification
MOU	Memorandum of Understanding
MRC	Modification Review Committee
MW	Megawatt
MWO	MNRC Work Order
NRC	Nuclear Regulatory Commission
NSC	Nuclear Safety Committee
OMM	Operation and Maintenance Manual
PA	Public Address (system)
Rev.	Revision
SMFD	Sacramento Metropolitan Fire District
SRO	Senior Reactor Operator
TS	Technical Specifications
UCD	University of California, Davis
UCDMC	University of California, Davis Medical Center
UCD/MNRC	University of California, Davis/McClellan Nuclear Radiation Center