

TABLE 4.3-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

FUNCTIONAL UNIT	CHANNEL CHECK (20)	CHANNEL CALIBRATION (20)	ANALOG CHANNEL OPERATIONAL TEST (19) (20)	TRIP ACTUATING DEVICE OPERATIONAL TEST (20)		ACTUATION LOGIC TESTS REQUIRED (20)	MODES FOR WHICH SURVEILLANCE IS REQUIRED (20)
				CHANNEL CALIBRATION (20)	ANALOG CHANNEL OPERATIONAL TEST (19) (20)		
19. Reactor Trip System Interlocks							
a. Intermediate Range Neutron Flux, P-6	N.A.	R(4)	R	N.A.	N.A.	N.A.	2**
b. Low Power Reactor Trips Block, P-7	N.A.	R(4)	R	N.A.	N.A.	N.A.	I
c. Power Range Neutron Flux, P-8	N.A.	R(4)	R	N.A.	N.A.	N.A.	I
d. Power Range Neutron Flux, P-9	N.A.	R(4)	R	N.A.	N.A.	N.A.	I
e. Power Range Neutron Flux, P-10	N.A.	R(4)	R	N.A.	N.A.	N.A.	I, 2
f. Turbine Impulse Chamber Pressure, P-13	N.A.	R	R	N.A.	N.A.	N.A.	I
20. Reactor Trip Breaker	N.A.	N.A.	N.A.	R(7, 11)	N.A.	N.A.	I, 2, 3*, 4*, 5*
21. Automatic Trip and Interlock Logic	N.A.	N.A.	N.A.	N.A.	R(7)	N.A.	I, 2, 3*, 4*, 5*
22. Reactor Trip Bypass Breaker	N.A.	N.A.	N.A.	R(15), R(16)	N.A.	N.A.	I, 2, 3*, 4*, 5*