

APPENDIX A

NOTICE OF VIOLATION

Consolidated Edison Company of New York, Inc.

Docket Nos. 50-03
50-247

Based on the results of an NRC inspection conducted on July 21 - August 8, 1980, it appears that certain of your activities were not conducted in full compliance with NRC regulations and the conditions of your NRC Facility License Nos. DPR-5 and DPR-26, as indicated below. These items are categorized as deficiencies.

- A. Section 4.2.1.1 of the ETSR requires that environmental samples be collected and analyzed according to Table 4.2-1. Table 4.2-1 requires, in part, that drinking water samples and surface lake water samples be analyzed for Sr-90 once per year.

Contrary to these requirements, Sr-90 analyses were not performed on drinking water samples or surface lake water samples collected during 1979.

- B. Section 4.2.1.1 of the ETSR requires that environmental samples shall be collected and analyzed according to Table 4.2-1. Table 4.2-1 requires in part, that drinking water samples be collected and analyzed monthly from Station No. 26, the New York City aqueduct.

Contrary to these requirements, drinking water samples from the New York City aqueduct were not collected and analyzed from January 2 until May 21, 1979.

- C. Section 3.1.4.1 of the ETSR requires that delta Tc described in Section 3.1.1 shall be differentiated to provide the rate of change of temperature, and that this information shall be recorded during all flow conditions.

Contrary to these requirements, rate of change of temperature was not recorded during the periods April 29 to May 19, May 20 to 24, May 26 to 30, June 4 to 9, and June 10 to July 7, 1980.

8102060068