

Stephen B. Bram
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, NY 10511
Telephone (914) 737-8116

February 5, 1993

Re: Indian Point Unit No. 2
Docket No. 50-247

Document Control Desk
US Nuclear Regulatory Commission
Mail Station P1-137
Washington, DC 20555

SUBJECT: Proposed Changes in Technical Specification
Surveillance Intervals to Accommodate a 24 Month
Fuel Cycle

REFERENCE: Letter, S. Bram to Document Control Desk, dated
November 25, 1992; same subject.

By the referenced letter, Consolidated Edison submitted the third submittal in a series of amendments intended to revise the Technical Specification refueling surveillance intervals. As a result of discussions with Mr. F. Williams, we are submitting the attached material which addresses the following points:

1. Table 4.1-1, item 19 has been revised to reflect "Process Radiation Monitoring System". In addition the hash bar has been removed from item 19b. to reflect issuance of Technical Specification Amendment 159.
2. The Safety Assessments for R-48 and R-54 and R-49 have been revised to reflect Table 4.10-2.
3. Technical difficulties with installation of R-50 require a modification to be implemented which will delay its scheduled date for operation. The existing monitor, R-20, will be used in the interim. No extension of the surveillance interval for R-20 is being sought as it will be replaced shortly by R-50. Processing of the change to Table 4.10-4 should be deferred at this time.
4. Item 3 of the "Basis for No significant Hazards Consideration Determination" for the Area Radiation Monitors has been revised to reflect that only the CCR monitor is subjected to a daily channel check.

190147

9302230027 930205
PDR ADDCK 05000247
P PDR


ADD 1/1

5. The Safety Assessment for the Safety Valve Position Indicators should be deleted as this was addressed in Technical Specification Amendment 159.
6. The title page for the Main Steam Line Radiation Monitor has been revised to indicate the numeric designation.
7. The Safety Assessments for R-46 and R-53 as well as R-39 & R-40 have been revised to reflect "high" set points to preclude false alarms.

None of these revisions invalidate the assumptions in the licensing basis for Indian Point Unit #2.

Should you have any questions regarding this matter, please contact Mr. Charles W. Jackson, Manager, Nuclear Safety and Licensing.

Very truly yours,



cc: Mr. Thomas T. Martin
Regional Administrator - Region I
US Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Francis J. Williams Jr., Project Manager
Project Directorate I-1
Division of Reactor Projects I/II
US Nuclear Regulatory Commission
Mail Stop 14B-2
Washington, DC 20555

Senior Resident Inspector
US Nuclear Regulatory Commission
PO Box 38
Buchanan, NY 10511

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, NY 10511

Ms. Donna Ross
Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2, Empire State Building
Albany, NY 12223