

Stephen B. Bram  
Vice President

Consolidated Edison Company of New York, Inc.  
Indian Point Station  
Broadway & Bleakley Avenue  
Buchanan, NY 10511  
Telephone (914) 737-8116

April 8, 1993

Re: Indian Point Unit No. 2  
Docket No. 50-247

Document Control Desk  
US Nuclear Regulatory Commission  
Mail Station P1-137  
Washington, DC 20555

SUBJECT: Proposed Amendment to Technical Specifications  
Regarding Weld Channel Pressurization System  
Requirements

Consolidated Edison Company of New York, Inc. transmits herewith one (1) signed original and two (2) copies of the document entitled "Application for Amendment to Operating License" sworn to April 8, 1993.

This application requests an amendment to the Indian Point Unit No. 2 Technical Specifications regarding operability of the Weld Channel Pressurization System. The proposed change would permit disconnection of a portion of that system if it were inoperable and it is determined that repairs are not practicable.

Attachment B to this application for amendment reflects the safety assessment evaluation supporting this change as well as the conclusion that the proposed change does not constitute a significant hazards consideration as defined by 10 CFR 50.92.

This proposed Technical Specification change is required prior to exceeding an RCS temperature of 200°F during return to service following the current refueling outage.

090020


9304090235 930408  
PDR ADDCK 05000247  
P PDR

ADD 11

At this time, no practicable repair for portions of the WCPS have been identified. Therefore, since the current scheduled date for going above 200°F is April 16, 1993, it is necessary for the NRC to act by that date to allow resumption of operation of the plant. Therefore, Consolidated Edison requests that this application be processed on an emergency basis in accordance with 10 CFR 50.91(a)(5) by April 15, 1993. Attachment C further discusses the basis for this request.

Should you or your staff have any questions regarding this submittal, please contact Mr. Charles W. Jackson, Manager, Nuclear Safety and Licensing.

Very truly yours,



Attachments

cc: Mr. Thomas T. Martin  
Regional Administrator - Region I  
US Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Francis J. Williams Jr., Project Manager  
Project Directorate I-1  
Division of Reactor Projects I/II  
US Nuclear Regulatory Commission  
Mail Stop 14B-2  
Washington, DC 20555

Senior Resident Inspector  
US Nuclear Regulatory Commission  
PO Box 38  
Buchanan, NY 10511

Mayor, Village of Buchanan  
236 Tate Avenue  
Buchanan, NY 10511

Ms. Donna Ross  
Division of Policy Analysis and Planning  
New York State Energy Office  
Agency Building 2, Empire State Building  
Albany, NY 12223