

Stephen B. Bram
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, NY 10511
Telephone (914) 737-8116

May 5, 1993

Re: Indian Point Unit No. 2
Docket No. 50-247

Document Control Desk
US Nuclear Regulatory Commission
Mail Station P1-137
Washington, DC 20555

SUBJECT: Proposed Changes in Technical Specification
Surveillance Intervals to Accommodate a 24 Month
Fuel Cycle

Transmitted herewith are the original and two (2) copies of an "Application for Amendment to the Operating License". This application requests an amendment to the Con Edison, Indian Point Unit No. 2, Technical Specifications. In accordance with 10 CFR 50.91, a copy of this specification and the associated attachments are being submitted to the designated New York State official.

This application for amendment to the Indian Point 2 Technical Specification supplements our submittal of May 29, 1992. In that submittal we indicated by the designations "R" or "at least once every Refueling Interval", those Technical Specification surveillances which would be revised to reflect a 24 month fuel cycle. In this submittal, safety assessments are enclosed which support revision of a portion of the Technical Specification surveillance intervals. These Technical Specification surveillance intervals are highlighted by a # sign to distinguish them from refueling surveillance intervals which remain to be evaluated.

This submittal is the fourth in a series of submittals intended to revise all Technical Specification 18 month surveillance intervals in accordance with Generic Letter 91-04. The changes are indicated by vertical lines in the right margin of the proposed Technical Specification pages, enclosed.

We confirm that the assumptions in the plant licensing basis will not be invalidated on the basis of performing any surveillance at the bounding surveillance interval.

9305140227 930505
PDR ADDCK 05000247
P PDR

Adol
11

Should there be any questions with regard to this matter, please contact Mr. Charles W. Jackson, Manager, Nuclear Safety and Licensing.

Very truly yours,



cc: Mr. Thomas T. Martin
Regional Administrator - Region I
US Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Francis J. Williams Jr., Project Manager
Project Directorate I-1
Division of Reactor Projects I/II
US Nuclear Regulatory Commission
Mail Stop 14B-2
Washington, DC 20555

Senior Resident Inspector
US Nuclear Regulatory Commission
PO Box 38
Buchanan, NY 10511

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, NY 10511

Ms. Donna Ross
Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2, Empire State Building
Albany, NY 12223