

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION


In the Matter of)
)
CONSOLIDATED EDISON COMPANY) Docket No. 50-247
OF NEW YORK, INC.)
(Indian Point Station,)
Unit No. 2))

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission ("NRC"), Consolidated Edison Company of New York, Inc. ("Con Edison"), as holder of Facility Operating License No. DPR-26, hereby applies for amendment of the Technical Specifications contained in Appendix A of that license. Specifically, we request that Technical Specification 1.0, Table 1.1, "Frequency Notation" be amended to reflect a "Refueling Interval, R" of "At least once every 24 months". Correspondingly, Technical Specification 4.0, in its entirety, would be amended to reflect "R" or "at least once every 24 months" where an 18 month surveillance interval is currently indicated.

The specific proposed Technical Specification revisions are set forth in Attachment A to this Application. A Safety Assessment of the currently proposed changes is set forth in Attachment B to this Application. This assessment demonstrates that the proposed changes do not represent a significant hazards considerations as defined in 10 CFR 50.92(c).

As required by 10 CFR 50.91(b)(1), a copy of this application and our analysis concluding that the proposed changes do not constitute a significant hazards consideration have been provided to the appropriate New York State official designated to receive such amendments.

BY: 
Stephen B. Bram
Vice President

Subscribed and sworn to
before me this 5th day
of May, 1993.


Notary Public

KAREN L. LANCASTER
Notary Public, State of New York
No. 60-4643659
Qualified in Westchester County
Term Expires 9/30/93

9305140231 930505
PDR ADDCK 05000247
P PDR