

Stephen B. Bram  
Vice President

Consolidated Edison Company of New York, Inc.  
Indian Point Station  
Broadway & Bleakley Avenue  
Buchanan, NY 10511  
Telephone (914) 737-8116

June 10, 1993

Re: Indian Point Unit No. 2  
Docket No. 50-247


Document Control Desk  
US Nuclear Regulatory Commission  
Mail Station P1-137  
Washington, DC 20555

SUBJECT: Supplementary Information in Support of  
Application to Amend Technical Specifications  
Pertaining to 480 Volt Bus Degraded Voltage  
Setpoints Dated September 29, 1992

In response to a question from the Office of Nuclear Reactor  
Regulation, if our application is approved, additional field  
voltage verification tests on calculated system voltages are  
planned to be performed on the 6.9 kV and 480V systems prior  
to the completion of the 1995 refueling outage.

Should you have any questions regarding this matter, please  
contact Mr. Charles W. Jackson, Manager, Nuclear Safety and  
Licensing.

Very truly yours,



cc: Mr. Thomas T. Martin  
Regional Administrator - Region I  
US Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Mr. Francis J. Williams, Jr., Project Manager  
Project Directorate I-1  
Division of Reactor Projects I/II  
US Nuclear Regulatory Commission  
Mail Stop 14B-2  
Washington, DC 20555

Senior Resident Inspector  
US Nuclear Regulatory Commission  
PO Box 38  
Buchanan, NY 10511

210049

9306230208 930615  
PDR ADOCK 05000305  
P PDR

A001  
1/10