

Stephen B. Bram
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, NY 10511
Telephone (914) 737-8116

September 29, 1993

Re: Indian Point Unit No. 2
Docket No. 50-247

Document Control Desk
US Nuclear Regulatory Commission
Mail Station P1-137
Washington, DC 20555

SUBJECT: Proposed Amendment to Technical Specifications
Regarding Boron Monitor Tanks Level Monitoring
Requirements


Transmitted herewith are the original and two copies of an "Application for Amendment to Operating License", sworn to on September 29, 1993. This Application requests an amendment to the Indian Point Unit No. 2 Technical Specifications.

The proposed Technical Specification changes are contained in Attachment A to this Application. If approved, these changes would delete controls for three tanks which are no longer in service from Section 3.9.A.5 and Tables 3.9-1 and 4.10-2. This deletion will eliminate the limit on quantity of radioactive material contained in each tank, as well as the requirements for tank level monitoring capability and related instrument surveillance. The quantity limit and level monitoring will no longer be required after the inlet and outlet piping of the empty tanks are cut and capped. A Safety Assessment is presented in Attachment B to the Application and provides the No Significant Hazards analysis for the proposed amendment.

In accordance with 10 CFR 50.91, a copy of this application and the associated attachments are being submitted to the designated New York State official.

Should there be any questions regarding this matter, please contact Mr. Charles W. Jackson, Manager, Nuclear Safety and Licensing.

Very truly yours,



A001
11

9310070294 930929
PDR ADDCK 05000247
P PDR

Attachments

cc: Mr. Thomas T. Martin
Regional Administrator - Region I
US Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Francis J. Williams Jr., Project Manager
Project Directorate I-1
Division of Reactor Projects I/II
US Nuclear Regulatory Commission
Mail Stop 14B-2
Washington, DC 20555

Senior Resident Inspector
US Nuclear Regulatory Commission
PO Box 38
Buchanan, NY 10511

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, NY 10511

Ms. Donna Ross
Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2, Empire State Building
Albany, NY 12223