

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
CONSOLIDATED EDISON COMPANY) Docket No. 50-247
OF NEW YORK, INC.)
(Indian Point Station,)
Unit No. 2))


APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission ("NRC"), Consolidated Edison Company of New York, Inc. ("Con Edison"), as holder of Facility Operating License No. DPR-26, hereby applies for amendment of the Technical Specifications contained in Appendix A of that license.

This application for amendment to the Indian Point 2 Technical Specifications seeks to amend: 1) Section 5.3.A (Reactor Core) to allow the use of VANTAGE + fuel with ZIRLO cladding and fuel with filler rods to allow fuel reconstitution, and 2) the basis to Section 2.1 (Safety Limit: Reactor Core) to allow the use of DNB Correlations applicable to VANTAGE + fuel.

The specific proposed Technical Specification revisions are set forth in Attachment A to this Application. A Safety Assessment of the proposed changes is set forth in Attachment B to this Application. This assessment demonstrates that the proposed changes do not represent a significant hazards considerations as defined in 10 CFR 50.92(c).

As required by 10 CFR 50.91(b)(1), a copy of this application and our analysis concluding that the proposed changes do not constitute a significant hazards consideration have been provided to the appropriate New York State official designated to receive such amendments.

BY: 
Stephen B. Bram
Vice President

Subscribed and sworn to
before me this 10th day
of December, 1993.


Notary Public

KAREN L. LANCASTER
Notary Public, State of New York
No. 60-4643659
Qualified in Westchester County
Term Expires 9/30/95

9312220132 931210
PDR ADOCK 05000247
PDR