

Table 4.1-1

Minimum Frequencies for Checks, Calibrations and  
Tests of Instrument Channels

Channel Description	Check	Calibrate	Test	Remarks
10. Rod Position Bank Counters	S	N.A.	N.A.	With analog rod position
11. Steam Generator Level	S	R#	Q	
12. Charging Flow	N.A.	R#	N.A.	
13. Residual Heat Removal Pump Flow	N.A.	R#	N.A.	
14. Boric Acid Tank Level	W	R	N.A.	Bubbler tube rodded during calibration
15. Refueling Water Storage Tank Level	W	R	N.A.	
16. DELETED				
17. Volume Control Tank Level	N.A.	R	N.A.	
18a. Containment Pressure	D	R#	Q	Wide Range
18b. Containment Pressure	S	R#	Q	Narrow Range
18c. Containment Pressure (PT-3300, PT-3301)	M	R#	N.A.	High Range
19. Process Radiation Monitoring System	D	R#	M	
19a. Area Radiation Monitoring System	D	R#	M	
19b. Area Radiation Monitoring System (VC)	D	R#	M	