

Stephen B. Bram
Vice President

Consolidated Edison Company of New York, Inc.
Indian Point Station
Broadway & Bleakley Avenue
Buchanan, NY 10511
Telephone (914) 734-5340

April 13, 1994

Re: Indian Point Unit No. 2
Docket No. 50-247


Document Control Desk
US Nuclear Regulatory Commission
Mail Station P1-137
Washington, DC 20555

SUBJECT: Proposed Amendment to Technical Specifications
Regarding Steam Generator Tube Slewing and
Acceptance Criteria

Consolidated Edison Company of New York, Inc. transmits herewith one (1) signed original and two (2) copies of "Application of Amendment to Operating License", sworn to on April 13, 1994. This application proposes an amendment to the Indian Point Unit No. 2 Technical Specifications that would permit steam generator tube slewing as an alternative to removing defective tubes from service through the use of tube plugs. Additionally, a new tube acceptance criteria, F*, as evaluated by B&W Nuclear Technologies, is proposed which would allow tubes that are degraded in a location not affecting structural integrity of the tube to remain in service.

Should you or your staff have any questions regarding this matter, please contact Mr. Charles W. Jackson, Manager, Nuclear Safety and Licensing.

Very truly yours,



Attachments

9404290270 940413
PDR ADDOCK 05000247
PDR

ADDI

cc: Mr. Thomas T. Martin
Regional Administrator - Region I
US Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. Francis J. Williams Jr., Project Manager
Project Directorate I-1
Division of Reactor Projects I/II
US Nuclear Regulatory Commission
Mail Stop 14B-2
Washington, DC 20555

Senior Resident Inspector
US Nuclear Regulatory Commission
PO Box 38
Buchanan, NY 10511

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, NY 10511

Ms. Donna Ross
Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2, Empire State Building
Albany, NY 12223