

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION


In the Matter of)
)
CONSOLIDATED EDISON COMPANY) Docket No. 50-247
OF NEW YORK, INC.)
(Indian Point Station,)
Unit No. 2))

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission ("NRC"), Consolidated Edison Company of New York, Inc. ("Con Edison"), as holder of Facility Operating License No. DPR-26, hereby applies for amendment of the Technical Specifications contained in Appendix A of that license. Specifically, we request that Technical Specification Table 3.5-1, "Engineered Safety Features Initiation Instrument Setting Limits" item 1, High Containment Pressure (Hi Level), Safety Injection Setting Limit, be revised from ≤ 2.0 psig to ≤ 5.0 psig.

The specific proposed Technical Specification revision is set forth in Attachment A to this Application. A Safety Assessment of the proposed change is set forth in Attachment B to this Application. This assessment demonstrates that the proposed change does not represent a significant hazards consideration as defined in 10 CFR 50.92(c).

As required by 10 CFR 50.91(b)(1), a copy of this application and our analysis concluding that the proposed changes do not constitute a significant hazards consideration have been provided to the appropriate New York State official designated to receive such amendments.

BY: 
Stephen B. Bram
Vice President

Subscribed and sworn to
before me this 26th day
of April, 1994.

Karen L. Lancaster
Notary Public

KAREN L. LANCASTER
Notary Public, State of New York
No. 60-4643659
Qualified in Westchester County
Term Expires 9/30/95

9405160246 940426
PDR ADOCK 05000247
P PDR