

The maximum permissible inleakage rate from the containment isolation valves sealed with service water for the full 12-month period of post-accident recirculation without flooding the internal recirculation pumps is 0.36 gpm per fan-cooler.

#### References

- (1) UFSAR - Section 5
- (2) UFSAR - Section 5.1.6
- (3) UFSAR - Section 14.3.6
- (4) UFSAR - Section 6.6
- (5) UFSAR - Section 6.5