

**William States Lee III Nuclear Station**

**COL Application**

**Part 7**

**Departures and Exemptions Requests**

**Revision 2**

**A. STD and WLS Departures**

This Departure Report includes deviations in the Lee Nuclear Station COLA FSAR from the Tier 2 information in the applicable Design Control Document (DCD), pursuant to 10 CFR Part 52, Appendix D, Sections VIII and X.B.1.

The following Departures are described and evaluated in detail in this report.

<u>Departure Number</u>	<u>Description</u>
STD DEP 1.1-1	Administrative departure for organization and numbering for the FSAR sections
WLS DEP 18.8-1	Emergency Response Facility locations

**A.1 Departures That Can Be Implemented Without Prior NRC Approval**

<u>Departure Number</u>	<u>Description</u>
STD DEP 1.1-1	Administrative departure for organization and numbering for the FSAR sections

Departure Number: STD DEP 1.1-1

Affected DCD/FSAR Sections: 2.1.1, 2.1.4, 2.2.1, 2.2.4, 2.4.1, 2.4.15, 2.5, 2.5.6, 9.2.11, 9.2.12, 9.2.13, 9.5.1.8, 9.5.1.9, 13.1, 13.5, 13.7, 17.5, 17.6, 17.7, 17.8 (Note the affected sections may vary in subsequent COL applications, but the departure is standard)

Summary of Departure:

This FSAR generally follows the AP1000 DCD organization and numbering. Some organization and numbering differences are adopted where necessary to include additional material, such as additional content identified in Regulatory Guide 1.206.

Scope/Extent of Departure:

The renumbered sections associated with this Departure are identified in the FSAR (at the sections identified above).

Departure Justification:

An administrative departure is established to identify instances where the renumbering of FSAR sections is necessary to effectively include content consistent with Regulatory Guide 1.206, as well as NUREG-0800, Standard Review Plan (SRP).

Departure Evaluation:

This Departure is an administrative change that affects only section numbering of the indicated FSAR sections. Accordingly, it does not:

1. Result in more than a minimal increase in the frequency of occurrence of an accident previously evaluated in the plant-specific DCD;
2. Result in more than a minimal increase in the likelihood of occurrence of a malfunction of a structure, system, or component (SSC) important to safety and previously evaluated in the plant-specific DCD;
3. Result in more than a minimal increase in the consequences of an accident previously evaluated in the plant-specific DCD;
4. Result in more than a minimal increase in the consequences of a malfunction of an SSC important to safety previously evaluated in the plant-specific DCD;
5. Create a possibility for an accident of a different type than any evaluated previously in the plant-specific DCD;
6. Create a possibility for a malfunction of an SSC important to safety with a different result than any evaluated previously in the plant-specific DCD;
7. Result in a design basis limit for a fission product barrier as described in the plant-specific DCD being exceeded or altered; or
8. Result in a departure from a method of evaluation described in the plant-specific DCD used in establishing the design bases or in the safety analyses.

This Departure does not affect resolution of a severe accident issue identified in the plant-specific DCD.

Therefore, this Departure has no safety significance.

NRC Approval Requirement:

This departure does not require NRC approval pursuant to 10 CFR Part 52, Appendix D, Section VIII.B.5.

**A.2 Departures That Require NRC Approval Prior to Implementation**

<u>Departure Number</u>	<u>Description</u>
WLS DEP 18.8-1	Emergency Response Facility locations

Departure Number: WLS DEP 18.8-1

Affected DCD/FSAR Sections: 1.2.3, 12.3.1.2, 12.5.2.2, 9A.2.1, 18.8.3.5, 18.8.3.6

Summary of Departure:

At Lee Nuclear Station, the Technical Support Center (TSC) is not located in the control support area (CSA) as identified in DCD Subsection 18.8.3.5; the TSC location is as described in the Emergency Plan. Additionally, the Operations Support Center (OSC) is also being moved from the location identified in DCD Subsections 12.5.2.2 and 18.8.3.6 and as identified on DCD Figures 1.2-18, 9A-3 (Sheet 1 of 3), 12.3-2 Sheet 11 of 15), and 12.3-3 (Sheet 11 of 16); the OSC location is as described in the Emergency Plan.

**Scope/Extent of Departure:**

This departure is identified in FSAR Subsection 18.8.

**Departure Justification:**

The referenced DCD states "The TSC is located in the control support area (CSA)." This is not the case for Lee Nuclear Station. The TSC location is moved to a central location such that a single TSC can serve both Lee Nuclear Station Units 1 and 2 as identified in the Emergency Plan. The referenced DCD also states "The ALARA briefing and operational support center is located off the main corridor immediately beyond the main entry to the annex building" and indicates that the OSC location is identified on Figure 1.2-18. However, the OSC is being moved to the control support area vacated by the move of the TSC in order to better utilize the now available space.

**Departure Evaluation:**

This Departure is for a non-safety-related system, and the alternate locations of the TSC and OSC meet applicable requirements. Relocating the TSC and OSC does not adversely affect their function and therefore this Departure does not:

1. Result in more than a minimal increase in the frequency of occurrence of an accident previously evaluated in the plant-specific DCD;
2. Result in more than a minimal increase in the likelihood of occurrence of a malfunction of a structure, system, or component (SSC) important to safety and previously evaluated in the plant-specific DCD;
3. Result in more than a minimal increase in the consequences of an accident previously evaluated in the plant-specific DCD;
4. Result in more than a minimal increase in the consequences of a malfunction of an SSC important to safety previously evaluated in the plant-specific DCD;
5. Create a possibility for an accident of a different type than any evaluated previously in the plant-specific DCD;
6. Create a possibility for a malfunction of an SSC important to safety with a different result than any evaluated previously in the plant-specific DCD;
7. Result in a design basis limit for a fission product barrier as described in the plant-specific DCD being exceeded or altered; or
8. Result in a departure from a method of evaluation described in the plant-specific DCD used in establishing the design bases or in the safety analyses.

This Departure does not affect resolution of a severe accident issue identified in the plant-specific DCD.

Therefore, this Departure has no safety significance.

**NRC Approval Requirement:**

This departure requires NRC approval pursuant to 10 CFR Part 52, Appendix D, Section VIII.B.6.

**B. Lee Nuclear Station Exemption Requests**

Duke requests the following exemption related to:

- 1) Not used
- 2) Combined License Application Organization and Numbering

Discussion and justifications for this request are provided in the following pages.

**1) Withdrawn. This exemption is no longer required.****2) Combined License Application Organization and Numbering (Part 52, Appendix D)**

Applicable Regulation(s): 10 CFR Part 52, Appendix D, Section IV.A.2.a

Specific wording from which exemption is requested:

**IV. Additional Requirements and Restrictions**

A. An applicant for a combined license that wishes to reference this appendix shall, in addition to complying with the requirements of 10 CFR 52.77, 52.78, and 52.79, comply with the following requirements:

1. Incorporate by reference, as part of its application, this appendix.
2. Include, as part of its application:
  - a. A plant-specific DCD containing the same type of information and using the same organization and numbering as the generic DCD for the AP1000 design, as modified and supplemented by the applicant's exemptions and departures;

Pursuant to 10 CFR 52.7 and 52.93 (as amended and promulgated effective Sept. 27, 2007), Duke Energy Carolinas, LLC (Duke) requests an exemption from the requirement of 10 CFR 52, Appendix D, Section IV.A.2.a, to include a plant-specific DCD "containing the same type of information and using the same organization and numbering as the generic DCD for the AP1000 design...." While the William States Lee III Nuclear Station Units 1 and 2 (Lee Nuclear Station) plant-specific DCD (i.e., the final safety analysis report) does contain the same type of information and generally follows the same organization and numbering as the generic DCD for the AP1000 design, some limited subsections of the FSAR (as identified in the departures report as item STD DEP 1.1-1) do not follow the "same organization and numbering as the generic DCD for the AP1000 design." Duke proposes to provide the plant-specific DCD (i.e., FSAR) with some administrative revisions to the organization and numbering of the AP1000 DCD.

Discussion:

The AP1000 Design Control Document (DCD) generally has an organization and numbering format that provides text by subject in general conformance with the Standard Review Plan (SRP) in effect at the time the DCD was written. Generally, Combined License information items are included at the end of a chapter, section, or subsection. In some cases, such as DCD Sections 2.1 and 2.2, the section may consist solely of a short description of topic and the Combined License information item subsection. This organization and numbering does not allow for the detailed discussion of these topics that is to be included in a complete FSAR section. As such, it is necessary to include numerous additional subsections to fully address the topic as identified in the guidance of Regulatory Guide 1.206 and the applicable SRP. In other cases, the organization and numbering must be modified slightly to allow for inclusion of plant-specific discussions within the appropriate section of the FSAR, such as including an additional water system description in Section 9.2. In these cases, the Combined License information item discussions are retained at the end of the DCD corresponding chapter, section, or subsection (to maintain the organization), but the numbering may be different.

These differences are well identified in the FSAR as STD DEP 1.1-1 at each location where the departure is taken and are considered to be purely administrative to support a logical construction of the document. Where the departure from the DCD organization and numbering is taken, the revised organization and numbering generally follows the guidance provided in Regulatory Guide 1.206 and the applicable SRP. As such, there are no significant departures from the expected organization and numbering of a typical FSAR, and the information is readily identifiable to facilitate NRC review.

In view of the above, we believe that it would be less efficient for both Duke and the NRC to comply with the portion of the regulation of 10 CFR Part 52, Appendix D, Section IV.A.2.a, that requires strict adherence to the “same organization and numbering as the generic DCD for the AP1000 design.” Accordingly, Duke hereby submits a request for an exemption from the regulations of 10 CFR 52, Appendix D, Section IV.A.2.a, pursuant to 10 CFR 52.7, “Specific Exemptions,” and 10 CFR 52.93, “Exemptions and Variances.”

Granting this request, which is authorized by law, would facilitate the NRC review of the Lee Nuclear Station COL application. For this and other reasons, granting this exemption request will not present an undue risk to the public health and safety, and is consistent with the common defense and security.

Moreover, compliance with the current rule would cause undue hardship for Duke and would also be inefficient and burdensome for the NRC staff. That approach would require Duke to prepare, and NRC to review, information with an organization and numbering that is unfamiliar and inconsistent with the current guidance for format and content of a combined license application.

For these reasons, Duke requests approval of the requested exemption from current regulations of 10 CFR 52, Appendix D, Section IV.A.2.a, as identified herein and in the application departures report.