



Florida Department of Environmental Protection

Marjory Stoneman Douglas Building
3900 Commonwealth Boulevard
Tallahassee, Florida 32399-3000

Charlie Crist
Governor

Jeff Kottkamp
Lt. Governor

Michael W. Sole
Secretary

January 12, 2010

Mr. John Hunter
Lead Environmental Specialist
Progress Energy Florida, Inc.
299 First Avenue North
Mail Code: PEF-903
St. Petersburg, FL 33701

RE: Progress Energy Levy Nuclear Plant
Modification to Conditions of Certification
Alteration of Submittal Dates
DEP Case Number PA08-51A
OGC Case Number 09-3933

FINAL ORDER MODIFYING CONDITIONS OF CERTIFICATION

Dear Mr. Hunter:

On November 18, 2009 the Florida Department of Environmental Protection (Department) received a request from the Southwest Florida Water Management District to modify the Conditions of Certification for the Progress Energy Florida (PEF) Levy Nuclear Plant (LNP). The request is to alter specific submittal date requirements set forth in the Conditions of Certification.

The Department has reviewed the modification request. On or before November 20, 2009, all parties to the certification proceeding were provided with notice by certified mail of the Department's intent to modify the Conditions of Certification for this facility, along with a copy of the proposed Order Modifying Conditions of Certification.

On December 11, 2009, notice of the Department's intent to modify the Conditions of Certification for this facility was published on the Florida Administrative Weekly (FAW). Pursuant to Section 403.516, Florida Statutes ("F.S."), and Rule 62-17.211, Florida Administrative Code ("F.A.C."), all parties to the certification proceeding have 45 days from the issuance of notice by mail to such party's last address of record in which to file a written objection to the modification; that any person who is not already a party to the certification proceeding and whose substantial interests will be affected by the requested modification has 30 days from the date of publication of the public notice in the Florida Administrative Weekly to object in writing; that failure to act within the time frame constitutes a waiver of the right to

become a party; and that the Department will issue an Order Modifying the Conditions of Certification for this facility if no written objections are received by the Department.

No objections to the modification have been received by the Department. The Conditions of Certification for the Levy Nuclear Plant are hereby modified as follows:

I. through XXVII. No Change

**XXVIII. SOUTHWEST FLORIDA WATER MANAGEMENT DISTRICT
GROUNDWATER WITHDRAWAL QUANTITIES AND FACILITIES**

District ID/ Owner ID	Water Allocation Average Gallons per Day	Well Casing/Depth Feet	STATUS <u>LOCATION</u>
1/PW-1	395,000	100/300**	PROPOSED
2/PW-2	395,000	100/300**	PROPOSED
3/PW-3	395,000	100/300**	PROPOSED
4/PW-4	395,000	100/300**	PROPOSED
5/CW-1*	90,000	100/300**	PROPOSED
TOTAL ALL WELLS	1,580,000		

* Temporary Construction Well (not a Permanent Production Well)

** Estimated

[Sections 373.016, 373.219, 373.223(1), F.S.; Rule 40D-2.301, F.A.C., District Basis of Review (BOR) Sections 3.2, 3.4, 4.1, 4.4, 4.8, 4.10]

A. Special Conditions

All conditions referring to the District shall mean the

Southwest Florida Water Management District
2379 Broad Street
Brooksville, Florida 34604-6899

1. Submit Reports/Data

a. All reports and data required by these conditions of certification shall be submitted to the District (and copied to the DEP Siting Office) according to the due dates contained in the specific condition. If the report or data is received on or before the tenth day of the month following data collection, it shall be deemed as a timely submittal. The Licensee may use the District’s website to submit data, plans or reports online. To set up an account, the Licensee can address the request to permitdata@watermatters.org. All mailed reports and data are to be sent to:

Permit Data Section, Regulation Performance Management Department
Southwest Florida Water Management District
2379 Broad Street
Brooksville, Florida 34604-6899

Submission of plans and reports: Unless submitted online or otherwise indicated in the special condition, the original and two copies of each plan and report required herein.

Submission of data: Unless submitted online or otherwise indicated in the special condition, an original (no copies) is required for data submittals such as meter readings and/or pumpage, rainfall, water level, evapotranspiration, or water quality data

b. Within sixty (60) days of Certification, the Licensee shall designate one individual responsible for receiving and responding to District notices and correspondence related to these conditions of certification. Notification to the District of the designee, including address and telephone number shall be in written form.

c. Prior to the construction and operation of the construction well (District ID No. 5; Licensee ID No. CW-1), the Licensee shall submit for District review and approval, under the provisions of Section A: Condition X of this Certification, the information required by the District's "Small General Permit" application form and any required supplemental forms (40D-2.101(2)(c), F.A.C. – March 2009).

[Sections 373.016, 373.219, 373.236, F.S.; Rules 40D-2.301(1) and 40D-2.381(1), (2) and (4), F.A.C.; BOR Section 6.2]

2. Environmental Impacts, Monitoring and Mitigation

a. Environmental Assessment

i. Environmental Monitoring Plan

~~Licensee shall submit a~~ An Environmental Monitoring Plan (EMP) shall be submitted no less than 3 years prior to any production well use in excess of 100,000 gallons per day (annual average) for production purposes. The EMP shall be approved and implemented a minimum of one-year prior to initial use of the first production well in excess of 100,000 gallons per day (annual average) for production purposes. ~~for District review and approval within 90 days of conditions of certification issuance.~~ The monitoring plan, at a minimum shall utilize the District's Wetland Assessment Procedure to evaluate the relative condition of surface waters and wetlands in areas potentially affected by water withdrawals of Licensee. Upon District approval, the plan shall be implemented and monitoring reports shall be provided in the annual monitoring report required by Condition No. A.2.a.v. After five years of monitoring following groundwater use rising to more than 1.25 million gallons per day (average annual daily withdrawal quantity) from all the wells included in this site certification, the Licensee may request the District release the Licensee from monitoring. If the District concurs with the request, the District will request DEP modify the conditions of certification to remove the monitoring condition.

ii. Data Collection

Licensee shall maintain and monitor the environmental monitoring sites included in the approved monitoring plan. Water levels for monitor wells staff gauges, and piezometers for the sites included in the monitoring plan shall be referenced to National Geodetic Vertical Datum (NGVD) and reported in a form acceptable to the District by the 10th day of each month for the preceding month. The time and date that the elevation is

taken shall be included. Any changes to the methods or frequency of monitoring for any of these data collection programs must be approved by the District.

iii. Staff Gauges

Licensee shall install and thereafter maintain District-approved staff gauges and shall report measurements of water levels, as indicated in the monitoring plan. Water levels shall be recorded and reported to the District on or before the tenth day of the following month. To the maximum extent possible, water levels shall be recorded as indicated in the monitoring plan. The frequency of recording may be modified by the District as necessary to ensure protection of the resource.

iv. Monitoring Wells and Piezometers

Licensee shall monitor water levels in the monitor wells and piezometers as specified in the monitoring plan. Reports of the data shall be submitted to the District in a form acceptable to the District. All data shall be referenced to NGVD. The frequency of water-level recording may be modified by the District as necessary to ensure the protection of the resource.

v. Annual Environmental Monitoring Reports

Following implementations of the EMP, the Licensee shall submit an annual environmental monitoring data summary by January 1st of each year for the preceding water year (October 1 - September 30). The Annual Monitoring Report shall include all raw data, essential graphs, tables, and text. Monitoring progress at each site shall be summarized in the Annual Monitoring Report, as specified below. Licensee shall submit three copies of the Annual Monitoring Report each year. Interpretive reports of environmental conditions shall incorporate all environmental monitoring sites used. The Annual Monitoring Report shall assess relationships between water level fluctuations, well pumpage, atmospheric conditions, and drainage factors related to the environmental condition of the wetlands and surface waters in the vicinity of the Levy Nuclear Plant. Pumpage data, wetland, water level data collected from the aquifer and for the region, and environmental parameters collected at the monitoring sites and in the region (SWFWMD data shall be used for information of the region) shall be used for the report results. Statistical trend analysis, such as double-mass curve analysis, multiple linear regression, time series analysis and/or factor analysis shall be performed to analyze the interactions of rainfall and pumpage on surficial water levels, potentiometric levels in the semi-confined aquifers, surface waters, and wetland water levels, rate of soil subsidence, and evidence of vegetational succession. Data shall be obtained through field measurements and aerial photo interpretation. A brief summary of any recommended changes to the monitoring requirements shall be provided. Upon review of those recommended changes, SWFWMD may approve changes to the monitoring requirements under the approved Environmental Monitoring Plan.

[Sections 373.016, 373.219, 373.223(1), F.S.; Rules 40D-2.301(1), 2.381(1), 2.381(4), F.A.C.; BOR Sections 1.5, 4.2, 5.8]

3. Alternative Water Supply Implementation

The Licensee shall investigate the development of one or more alternative water supply projects to supply the water supply demands to offset all or a portion of the groundwater allocated by these conditions of certification. Alternative water supplies include seawater desalination, brackish surface or ground water, water that has been reclaimed after one or more uses, stormwater, and any other water supply source designated as non-traditional. If adverse impacts are detected or predicted through the Environmental Monitoring as specified in Condition A.2. or through aquifer performance testing or groundwater modeling as specified in Conditions A.4.a. and A.4.b. below, Licensee shall either mitigate such adverse impacts in accordance with a plan submitted by the Licensee and approved by the District or, by selecting and implementing an Alternate Water Supply project in accordance with the following schedule:

- a. Within 3 years of completion of site aquifer testing specified in condition, A.4.a. the Licensee shall submit for District approval, an Alternative Water Supply Plan. The Alternative Water Supply Plan shall evaluate, identify, and propose alternative water supply development of one million five hundred eighty thousand (1,580,000) gallons per day (gpd).
- b. Within 4 years of completion of site aquifer testing and modeling specified in condition A.4.a., Licensee shall submit to the District, a preliminary design of the approved alternative water supply project that the Licensee will implement.
- c. Within 3 years of groundwater use rising to more than 1.25 million gallons per day (average annual daily withdrawal quantity) from all the wells included in this site certification, the Licensee shall provide an analysis of environmental conditions as specified in Condition A.4.a. above. The Licensee may ask for a time extension or waiver for implementing the Alternate Water Supply project if the District confirms that adverse environmental impacts have not been detected or are not predicted to occur. The Alternate Water Supply project schedule shall be maintained unless the District confirms that adverse environmental impacts have not been detected or are not predicted to occur. If adverse environmental impacts are occurring or are predicted to occur, the Alternative Water Supply quantity required to be developed will be determined based upon a revised hydrogeologic evaluation performed by the Licensee and accepted by the District.
- d. With 4 years of completion of site aquifer testing specified in condition A.4.a., submit to the Florida Department of Environmental Protection and the District, applications for authorization to develop and use 1,580,000 gpd of alternative water sources for the project as appropriate, unless an extension of time or waiver has been granted by the District.
- e. Within 4 years of completion of site aquifer testing specified in condition A.4.a., submit to the District an alternative water supply implementation schedule detailing the dates when construction will begin and end, and the date when water will be delivered from the project for use by the Licensee.

f. Compliance with the Alternative Water Supply Implementation Schedule is required by the Licensee, unless extended or otherwise modified in writing by the District. Each year, by March 1, after the triggers described above, the Licensee shall submit to the District a status report describing the progress made on the Alternative Water Supply Implementation Schedule, including the specific actions taken to meet the requirements set forth above. If the project has fallen behind schedule, Licensee shall provide just cause for the delay and/or explain how the Licensee will comply with the schedule described herein.

[Sections 373.016, 373.219, 373.223(1), F.S.; Rule 40D-2.301(1); BOR Section 3.1(pending amendment)]

4. Aquifer Testing and Groundwater Impact Analysis

a. For the purpose of confirming Upper Floridan transmissivity and leakance values used in Licensee's groundwater flow model, a step-drawdown test shall be performed on the production wells. A multi-well constant-rate test shall be performed on two of the following production wells: District ID Nos. 1, 2, 3, 4, Licensee ID Nos. PW-1, PW-2, PW-3, PW-4, after the wells have been fully developed. Constant-rate multi-well test locations will be based on step-drawdown tests, water quality, and other data submitted to the District prior to the multi-well constant-rate site selections. The constant-rate tests shall be performed in accordance with the specifications in an Aquifer Performance Testing (APT) Plan submitted to and approved by the District. The APT Plan shall be submitted to the District ~~within 90 days of the approval of the conditions of certification~~ at least 6 months prior to the start of construction of the first production well to support plant operations. The step-drawdown and constant-rate tests shall be conducted by the Licensee within 6 months of completion of construction of the wells included in the APT Plan and , or within 6 months of the final approval of the APT Plan, whichever occurs later. In addition, these tests must be completed at least 5 years prior to initial the use of any of the first production wells in excess of 100,000 gallons per day (annual average) for production purposes. All recorded raw data and a full report analyzing the data shall be submitted to the District within ninety (90) days of completion of all the tests.

[Sections 373.016, 373.219, 373.223(1), F.S.; Rule 40D-2.301(1); BOR Sections 1.5, 4.2, 4.5, 4.6, 4.8, 4.13]

b. If any of the transmissivity or leakance values derived from either the step-drawdown or the multi-well constant-rate tests referenced in condition A.4.a. above, differ significantly from the values used in the groundwater flow model submitted as part of Licensee's application, the Licensee will revise its submitted Focused Telescoping Mesh Refinement groundwater model of the wellfield area based on the results of the aquifer tests described in Condition No. A.4.a. above. Significantly different transmissivity or leakance values shall mean any well having either a leakance or transmissivity value twenty (20) percent higher or lower than those included in the Licensee's submitted groundwater flow model. The revised model will include wellfield-specific Upper Floridan aquifer transmissivity or leakance values and properties derived from well drilling and the aquifer tests described in Condition ~~no~~ No. A.4.a. The modeling parameters, including but not limited to the following: surficial aquifer transmissivity/hydraulic conductivity and thickness, Upper Floridan aquifer thickness and transmissivity/hydraulic conductivity, measured groundwater levels (NGVD) and gradients, aquifer leakage, and aquifer boundary conditions, may require revision to reasonably represent aquifer conditions. The revised model must also reflect a groundwater impact analysis including

cumulative and incremental analysis to evaluate the pumping effects on other water users, and other analysis to confirm that the withdrawal meets the District's conditions of issuance for water-use permits. If required, all groundwater modeling and a full report, meeting District modeling guidelines, shall be submitted to the District within one-hundred eighty (180) days of completion of the aquifer tests described in Condition No. A.4.a. above. Upon acceptance of the report by the District, the Licensee will complete any required Alternative Water Supply Implementation Plans as specified above.

[Sections 373.016, 373.219, 373.223(1), F.S.; Rules 40D-2.301(1), 2.381(1), (4); BOR sections 4.2, 5.4, 5.5, 5.6, 5.7]

5. Compliance Reporting

The Licensee shall submit a compliance report beginning the fifth year after groundwater use rising to at least 1.25 million gallons per day (average annual daily withdrawal quantity) and at 5 year intervals thereafter. The report must contain sufficient information to demonstrate reasonable assurance that the withdrawals and use of water authorized by these conditions of certification continue to meet the substantive requirements set forth in Chapter 40D-2, F.A.C., and the District's Water Use Permit Information Manual Part B, Basis of Review. The compliance report shall include:

- a. Information documenting water demands and updated demand projections demonstrating that allocations from all sources in the conditions of certification will continue to be needed for the remainder of the conditions of certification duration;
- b. Documentation verifying that the sources are capable of supplying the needs authorized by these conditions of certification without causing harm to water and water-related resources;
- c. Documentation verifying that the use of water is efficient and that the Licensee is implementing all feasible water conservation measures;
- d. An updated ground water modeling analysis and data analysis demonstrating that the use of groundwater does not interfere with legal uses existing at the time of issuance of the conditions of certification;
- e. An updated ground water modeling analysis, along with statistical analyses of water-level and wetland monitoring data, demonstrating that the use does not cause adverse impacts to wetlands, and surface waters, or violations of MFLs;
- f. Documentation that ground water withdrawals by the Licensee are not causing or contributing to significant water quality deterioration, including but not limited to review and statistical analyses of groundwater level and water quality data collected by the Licensee under these conditions of certification;
- g. Information demonstrating that the lowest quality source of water is being used to meet the water demands.

Following review of this report and as requested by the District, DEP may modify the conditions of certification to ensure that the use continues to meet the substantive conditions for the consumptive use of water as set forth in Section 373.223, F.S., and Chapter 40D-2, F.A.C.

[Sections 373.016, 373.219, 373.223(1), 373.236, F.S.; Rules 40D-2.301(1), 40D-2.381(1), (4), F.A.C.]

6. Pumpage Reporting

Licensee shall meter withdrawals and record meter readings from each withdrawal point and water supply line on a monthly basis within the last week of the month. The meter readings shall be reported to the District on or before the tenth day of the following month. If a metered withdrawal is not utilized during a given month, the meter report shall be submitted to the District indicating the same meter reading as was submitted the previous month.

Licensee shall install meters on District ID Nos. 1, 2, 3, 4, 5, Licensee ID Nos. PW-1, PW-2, PW-3, PW-4, CW-1, within 90 days of completion of construction of the withdrawal facilities.

All meters shall adhere to the following descriptions and shall be installed and maintained as follows:

a. All meters shall be non-resettable, totalizing flow meters that have a totalizer of sufficient magnitude to retain total gallon data for a minimum of the three highest consecutive months permitted quantities. If other measuring devices or alternative accounting or reporting methods are proposed, prior to installation, the Licensee shall submit documentation that the other measuring devices or accounting methods meet the accuracy requirement provided below. If the alternative accounting method involves a meter belonging to another entity or to an alternative water supply provider, the Licensee shall submit documentation from the owner/supplier that the meter readings conform to these meter requirements. Such documentation is subject to approval by the District. Approval for other measuring devices, accounting methods, or reporting methods must be obtained in writing from the Brooksville Regulation Department Director.

i. The flow meter(s) or other approved flow-measuring device(s) shall have and maintain an accuracy within five percent of the actual flow as installed.

ii. Accuracy testing requirements:

a) For newly metered withdrawal points, the flow meter installation shall be designed for inline field access for meter accuracy testing.

b) The meter shall be tested for accuracy on-site, as installed, every five years beginning from the date of its installation for new meters or from the date of initial issuance of the permit.

c) The testing frequency will be decreased if the Licensee demonstrates to the satisfaction of the District that a longer period of time for testing is warranted.

d) The test will be accepted by the District only if performed by a person certified on the test equipment used as described in the section entitled Flow Meter Verification, below.

e) If the actual flow is found to be greater than 5% different from the measured flow, within 30 days the Licensee shall have the meter re-calibrated, repaired, or replaced, whichever is necessary. Documentation of the test and a certificate of re-calibration, if applicable, shall be submitted within 30 days of each test or re-calibration.

b. The meter shall be installed according to the manufacturer's instructions for achieving accurate flow to the specifications above, or it shall be installed in a straight length of pipe where there is at least an upstream length equal to ten (10) times the outside pipe diameter and a downstream length equal to two (2) times the outside pipe diameter. Where there is not at least a length of ten diameters upstream available, flow straightening vanes shall be used in the upstream line. Existing systems that would require retrofitting to achieve the above standards will not be required to retrofit provided it is documented on the Flow Meter Accuracy Verification Form, Form No. LEG-R. 021.000 (07/08) that the flow meter is accurately and reliably measuring flow over different flow ranges or for the permanent operating flow.

c. If a metered withdrawal point, AWS inflow line or re-pump withdrawal point is not utilized during a given month, the meter report shall be submitted to the District showing the same meter reading that was submitted the previous month.

d. Broken or malfunctioning meter:

If the meter or other flow-measuring device malfunctions or breaks, the Licensee shall:

i. Notify the District within 15 days of discovering the malfunction or breakage;

ii. Replace the broken or malfunctioning meter with a repaired or new meter, subject to the specifications given above, within 30 days of the discovery; and

iii. Submit estimates of their pumpage as described below.

If the meter is removed from the withdrawal point for any other reason, it shall be replaced with another meter having the same specifications given above, or the meter shall be reinstalled within 30 days of its removal from the withdrawal. In either event, the withdrawal point shall not lack a fully functioning meter for more than 60 consecutive days.

e. While the meter is not functioning correctly, the Licensee shall document the total amount of time in minutes that the withdrawal point was used for each month and multiply those minutes times the pump capacity (in gallons per minute) for total gallons. The estimate of the number of gallons used each month during that period shall be submitted on District scanning forms and noted as estimated per instructions on the form. If the data are submitted by another approved method, the fact that it is estimated must be indicated. The reason for the necessity to estimate pumpage shall be reported with the estimate.

f. In the event a new meter is installed to replace a broken meter, the meter and its installation shall meet the specifications of the District. The Licensee shall notify the District of the replacement with the first submittal of meter readings from the new meter.

[Sections 373.016, 373.219, 373.223(1), 373.236, F.S.; Rules 40D-2.301(1),(3), 40D-2.381(1), (4); F.A.C.; BOR 5.1, 6.2]

7. Distribution Flexibility

The average day, peak monthly, and maximum daily, if applicable, quantities for District ID No(s) 1, 2, 3, 4, 5, Licensee ID No(s) PW-1, PW-2, PW-3, PW-4, CW-1, shown above in the production withdrawal table are estimates based on projected distribution of pumpage, and are for water use inventory and impact analysis purposes. The quantities listed in the table for these individual sources are not intended to dictate the distribution of pumpage from the withdrawal sources. The Licensee may make adjustments in pumpage distribution as necessary up to 125 percent on an average basis, up to 125 percent on a peak monthly basis, so long as adverse environmental impacts do not result and other conditions of this certification are complied with. In all cases, the total average annual daily withdrawal and the total peak monthly daily withdrawal are limited to the quantities set forth above.

[Sections 373.016, 373.219, 373.223(1), F.S.; Rule 40D-2.301, F.A.C., BOR sections 3.2, 3.4, 4.1]

8. Water Quality Sampling

a. Water quality samples shall be collected and analyzed for parameters and at the frequencies specified below. Water quality samples from production wells shall be collected from all wells, unless infeasible. If sampling is infeasible, Licensee shall indicate the reason for not sampling on the water quality data form. Water quality samples shall be analyzed by a laboratory certified by the Florida Department of Health utilizing the standards and methods applicable to the parameters analyzed and to the water use pursuant to Chapter 64E-1, Florida Administrative Code, "Certification of Environmental Testing Laboratories". At a minimum, water quality samples shall be collected after pumping the well at its normal rate for a pumping time specified in the table below, or to a constant temperature, pH, and conductivity. In addition, Licensee's sampling procedure shall follow the handling and chain of custody procedures designated by the certified laboratory which will undertake the analysis. Any variance in sampling and/or analytical methods shall have prior approval of the Brooksville Regulation Department Director. Reports of the analyses shall be submitted to the Permit Data Section, Regulation Performance Management Department, (using District forms) on or before the tenth day of the following month, and shall include the signature of an authorized representative and certification number of the certified laboratory which undertook the analysis. The parameters and frequencies of sampling and analyses may be modified by the Brooksville Regulation Department Director, as necessary to ensure the protection of the resource.

<u>District ID No.</u>	<u>Licensee ID No.</u>	<u>Minimum Pumping Time (minutes)</u>	<u>Parameter</u>	<u>Sampling Frequency</u>
1	PW-1	20 minutes	Chlorides, Sulfates, and T.D.S.	February, May, August and November
2	PW-2	20 minutes		
3	PW-3	20 minutes		
4	PW-4	20 minutes		

Water quality samples shall be collected quarterly and on the same week of the months specified.

Analyses shall be performed according to procedures outlined in the current edition of Standard Methods for the Examination of Water and Wastewater by the American Public Health Association-American Water Works Association-Water Pollution Control Federation (APHA-AWWA-WPCF) or Methods for Chemical Analyses of Water and Wastes by the U.S. Environmental Protection Agency (EPA).

[Sections 373.016, 373.219, 373.223(1), 373.236, F.S.; Rules 40D-2.301(1), 40D-2.381(1), (4); F.A.C.; BOR 6.2]

b. Water quality samples from monitor wells shall be collected and analyzed for the District ID No., parameter(s), and frequency (ies) specified in the table below. Water quality samples shall be collected after pumping the monitor wells(s) to a constant temperature, pH, and conductivity. Sampling method(s) shall be designed to collect water quality samples that are chemically representative of the zone to be sampled. Water quality samples shall be analyzed by a laboratory certified by the Florida Department of Health utilizing the standards and methods applicable to the parameters analyzed and to the water use pursuant to Chapter 64E-1, Florida Administrative Code, "Certification of Environmental Testing Laboratories". The Licensee's sampling procedure(s) shall follow the handling and chain of custody procedures designated by the certified laboratory which will undertake the analysis. A report describing the sampling and chain of custody procedures shall be included with the first data submitted after the date this permit is granted, and upon any change in sampling and/or analytical method(s). Any variance in sampling and/or analytical methods shall have prior approval of the District. Reports of the analyses shall be submitted to the District on District forms on or before the tenth day of the following month, and shall include the signature of an authorized representative and certification number of the certified laboratory that undertook the analysis. The parameters and frequency of sampling and analysis may be modified by the District as necessary to ensure the protection of the resource.

<u>District ID No.</u>	<u>Licensee ID No.</u>	<u>Parameter</u>	<u>Sample Frequency</u>
5	TBD	Chlorides, Sulfates, and TDS	May, September
6	TBD		
7	TBD		
8	TBD		
9	TBD		
10	TBD		

Water quality samples shall be collected based on the following timetable:

Semi-annually Same week of months specified

Analyses shall be performed according to procedures outlined in the current edition of Standard Methods for the Examination of Water and Wastewater by the American Public Health Association-American Water Works Association-Water Pollution Control Federation (APHA-AWWA-WPCF) or Methods for Chemical Analyses of Water and Wastes by the U.S. Environmental Protection Agency (EPA).

[Sections 373.016, 373.219, 373.223(1), 373.236, F.S.; Rules 40D-2.301(1), 40D-2.381(1), (4); F.A.C.; BOR 6.2]

c. The District with DEP's concurrence, reserves the right to set chloride, sulfate or TDS concentration limits on any production well in the future to prevent long-term upward trends or other significant water quality changes from occurring, based on data collected and after a sufficient data base has been established to determine limits. These limits shall be required after discussions with the Licensee. At such time as the concentration in any water sample reaches or exceeds the designated concentration limits, the Licensee shall take appropriate action to reduce concentrations to below those set for the particular well. If the District determines that long-term upward trends or other significant water quality changes are occurring, the District may consult with FDEP to reconsider the quantities included in these conditions of certification.

[Sections 373.016, 373.219, 373.223(1), 373.236, F.S.; Rules 40D-2.301(1), 40D-2.381(1), (4); F.A.C.; BOR 6.2]

d. During drilling of District ID Nos. 1, 2, 3, 4, Licensee ID Nos. PW-1, PW-2, PW-3, PW-4, water quality samples shall be collected at intervals of the change of drill rod or 30 feet, whichever is less, from 150 feet to a maximum depth of five feet above the bottom of the well when drilling on reverse air. Regardless of the specified sample collection interval, a sample shall be collected from the depth which corresponds to five feet above the bottom of the well. Samples shall be collected during reverse air drilling, or other appropriate method with prior approval by the District.

Samples shall be analyzed by a certified laboratory for Chloride, Sulfate, and Specific Conductivity. Licensee's sampling procedure shall follow the handling and chain of custody procedures designated by the certified laboratory which will undertake the analysis. Reports of the analyses shall be submitted to the Permit Data Section, Regulation Performance Management Department (using District forms) within thirty days of sampling, and shall include the signature of an authorized representative and the certification number of the Florida Department of Health certified laboratory utilizing the standards and methods applicable to the parameters analyzed and to the water use pursuant to Chapter 64E-1, Florida Administrative Code, "Certification of Environmental Testing Laboratories".

Analyses shall be performed according to procedures outlined in the current edition of Standard Methods for the Examination of Water and Wastewater by the American Public Health Association-American Water Works Association-Water Pollution Control Federation (APHA-AWWA-WPCF) or by Methods for Chemical Analyses of Water and Wastes by the U.S. Environmental Protection Agency (EPA).

[Sections 373.016, 373.219, 373.223(1), 373.236, F.S.; Rules 40D-2.301(1), 40D-2.381(1), (4); F.A.C.; BOR 6.2]

e. Monthly water levels for monitor wells for the sites included in the table below shall be referenced to NGVD, and reported in a form acceptable to the District by the tenth day of each month for the preceding month. The time and date that the elevation is taken shall be included. Changes to the methodology, extent, or frequency of monitoring at any of these sites may be modified by the District, as necessary to ensure the protection of the resources.

<u>District ID No.</u>	<u>Licensee Site No.</u>
5	TBD
6	TBD
7	TBD
8	TBD
9	TBD
10	TBD

[Sections 373.016, 373.219, 373.223(1), 373.236, F.S.; Rules 40D-2.301(1), 40D-2.381(1), (4); F.A.C.; BOR 6.2]

9. Wells

a. Well construction permits shall be obtained from the District by the Licensee for all wells to be constructed for this project. Well construction shall conform to requirements set forth in District and DEP rules for well construction.

[Sections 373.016, 373.219, 373.223(1), 373.308, 373.313, F.S.; Rules 40D-2.301(1), 40D-2.381(1), 40D-3.041, F.A.C.; WUP BOR 6.2]

b. Wells not in use with no installed pumping equipment shall be capped or valved in a water tight manner in accordance with Rule 62-532.500(3)(a)(4), F.A.C.

[Sections 373.016, 373.219, 373.223(1), 373.308, 373.313, F.S.; Rules 40D-2.301(1), 40D-2.381(1), 40D-3.037, 40D-3.041, 40D-3.521, 62-532.500, F.A.C.]

c. Within 90 days of the completion of each proposed well, Licensee shall submit to the District specific capacity (well testing) information from any test performed by the Water Well Contractor or pump installer on the well. This information shall include:

- i. Static water level before pumping
- ii. Duration of test pumping
- iii. Gallons per minute pumped
- iv. Final water level measured during pumping

If step-drawdown tests were performed, the information listed above shall be submitted for each step. A report analyzing the results shall be presented.

[Sections 373.016, 373.219, 373.223(1), F.S.; Rules 40D-2.301(1), 40D-2.381(1), 40D-3.301(2), F.A.C.]

d. Within 90 days of construction, Licensee shall submit to the Permit Data Section, Regulation Performance Management Department, the specific locations of District ID Nos. 1, 2, 3, 4, 5, Licensee ID Nos. PW-1, PW-2, PW-3, PW-4, CW-1, on an original blue line aerial with a minimum scale of one inch equals 800 feet, or by latitude/longitude. Intake and mainline diameters for each of the above pumps shall be reported at the time of location reporting.

[Sections 373.016, 373.219, 373.223(1), F.S.; Rules 40D-2.301(1), 40D-2.381(1), 40D-3.301(2), F.A.C.]

e. ~~Within one year of conditions of certification issuance,~~ Prior to start of construction activity that involves withdrawal of groundwater, the Licensee shall develop and implement a Water Conservation Plan (Plan) that includes practices currently employed or planned. This Plan shall address water conservation measures related to the construction phase of the project. In addition, the Licensee shall update this Plan, or submit a separate Plan, to address the operation phase of the project no later than one-year prior to the anticipated commercial operation of the first unit. For planned components, include an estimated time-frame for implementation for each. The Plan must indicate that technically and economically feasible water conservation opportunities have been or will be employed.

[Sections 373.016, 373.219, 373.223(1), F.S.; Rules 40D-2.301(1), 40D-2.381(1), F.A.C.; BOR 3.4 (pending amendment)]

f. The lowest quality water source, including reclaimed water, surface water and stormwater, must be used for each consumptive use authorized by these conditions of certification when available, except when Licensee demonstrates that the use of the lower quality water source is determined to be not economically, environmentally, or technologically feasible, in accordance with the District's Water Use Permit Information Manual Part B, Basis of Review, Sections 4.4 and 4.11.

[Sections 373.016, 373.219, 373.223(1), F.S.; Rules 40D-2.301(1), 40D-2.381(1), F.A.C.; BOR 4.4, 4.11]

g. Wetlands and other surface waters may not be adversely impacted as a result of the water use authorized by these conditions of certification. If unacceptable adverse impacts occur, the District will request that DEP modify the conditions of certification to curtail or abate the unacceptable adverse impacts, unless the impacts can be mitigated by Licensee.

[Sections 373.016, 373.219, 373.223(1), F.S.; Rules 40D-2.301(1), 40D-2.381(1), F.A.C.; BOR 2.8, 4.2, 4.13, 6.2]

h. A construction dewatering plan shall be provided to the District, for approval 6 months prior to the conduct of the dewatering. This plan shall include the details of the dewatering system, discharge quantities and location, a monitoring plan, and other details as appropriate to demonstrate that the dewatering plans meet the Districts Conditions of Issuance as included in 40D-2.301 and comply with all applicable Environmental Resource Permit construction dewatering requirements.

[Sections 373.016, 373.219, 373.223(1), F.S.; Rules 40D-2.301(1), 40D-2.381(1), F.A.C.; BOR Sections 3.5, 5.4, 5.5]

B. STANDARD CONDITIONS:

Licensee shall comply with the following Standard Conditions:

1. If any of the statements in the application and in the supporting data are found to be untrue and inaccurate, or if Licensee fails to comply with all of the provisions of Chapter 373, F.S., Chapter 40D, or the conditions set forth herein, the District shall seek revocation of any conditions of certification.

2. These conditions of certification are imposed based on information provided by Licensee demonstrating that the use of water is reasonable and beneficial, consistent with the public interest, and will not interfere with any existing legal use of water. If, during the term of this certification, it is determined by the District that the use is not reasonable and beneficial, in the public interest, or does impact an existing legal use of water, the District shall seek modification these conditions of certification or revocation of the certification authorized by DEP.

3. Licensee shall not deviate from any of the District- imposed conditions of this certification without written approval by the District.

4. In the event the District declares that a Water Shortage exists pursuant to Chapter 40D-21, Licensee agrees that portions of these conditions of certification shall be modified, or declared inactive as necessary to address the water shortage.

5. The District shall collect water samples from any withdrawal point listed in these conditions of certification or shall require Licensee to submit water samples when the District determines there is a potential for adverse impacts to water quality.

6. Licensee shall provide access to an authorized District representative to enter the property at any reasonable time to inspect the facility and make environmental or hydrologic assessments. Licensee shall either accompany District staff onto the property or make provision for access onto the property.

7. Licensee shall cease or reduce any surface water withdrawals as directed by the District if water levels in surface water fall below applicable minimum water level established in Chapter 40D-8 or rates of flow in streams fall below the minimum levels established in Chapter 40D-8.

8. Licensee shall cease or reduce withdrawals if water levels in aquifers fall below the minimum levels established by the District.

9. Licensee shall practice water conservation to increase the efficiency of transport, application, and use, as well as to decrease waste and to minimize runoff from the property. At such time as the District adopts specific conservation requirements for Licensee's water use classification, these conditions of certification shall be modified accordingly.

10. The District may establish special regulations for Water Use Caution Areas. At such time as the Governing Board adopts such provisions, these conditions of certification shall be subject to them upon notice and after a reasonable period for compliance.

11. Licensee shall mitigate any adverse impact to existing legal uses caused by withdrawals. When adverse impacts occur or are imminent, Licensee shall be required to mitigate the impacts. Adverse impacts include:

a. A reduction in water levels which impairs the ability of the well to produce water;

b. Significant reduction in levels or flows in water bodies such as lakes, impoundments, wetlands, springs, streams or other watercourses; or

c. Significant inducement of natural or manmade contaminants into a water supply or into a usable portion of any aquifer water body.

12. Licensee shall mitigate any adverse impact to environmental features or offsite land uses as a result of withdrawals. When adverse impacts occur or are imminent, the Licensee shall be required to mitigate the impacts. Adverse impacts include:

a. Significant reduction in levels or flows in water bodies such as lakes, impoundments, wetlands, springs, streams or other watercourses;

b. Sinkholes or subsidence caused by reduction in water levels;

c. Damage to crops and other vegetation causing financial harm to the owner; and

d. Damage to the habitat of endangered or threatened species.

13. When necessary to analyze impacts to the water resource or existing users, Licensee shall be required to install flow metering or other measuring devices to record withdrawal quantities and submit the data to the District.

14. A District identification tag shall be prominently displayed at each withdrawal point by permanently affixing the tag to the withdrawal facility.

15. Licensee shall notify the District within 30 days of the sale or conveyance of permitted water withdrawal facilities or the land on which the facilities are located.

16. The annual average daily withdrawal quantity is determined by calculating the total quantity of water to be withdrawn over a one year period, divided by 365 days, which results in a gallons per day (gpd) quantity pursuant to Basis of Review, Section 3.2, Permitted Withdrawal Quantities. This is a running 12-month average, whereby each month the annual average daily quantity is recalculated based on the previous 12-month pumpage.

[Sections 373.016, 373.219, 373.223(1), F.S.; Rules 40D-2.301(1), 40D-2.381(1), F.A.C.; BOR Section 6.1]

XXIX-XLIX. No Change

A complete set of the Conditions of Certification (including attachments) can be viewed and downloaded from the following website: <http://www.dep.state.fl.us/siting/certification.htm>. Copies of the Conditions of Certification and/or attachments may also be obtained by contacting Michael P. Halpin, P.E., Administrator, Siting Coordination Office, Department of Environmental Protection, 3900 Commonwealth Blvd, MS 48, Tallahassee, Florida 32399-3000, (850) 245-2002.

Any party to the this Order has a right to seek judicial review of it pursuant to Section 120.68, Florida Statutes by filing a Notice of Appeal, pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department of Environmental Protection in the Office of General Counsel, 3900 Commonwealth Boulevard, M.S. 35, Tallahassee, Florida 32399-3000, and by filing a copy of the Notice of Appeal, accompanied by the applicable filing fees, with the appropriate District Court of Appeal. The Notice of Appeal must be filed within thirty days from the date this Order is filed with the Clerk of the Department of Environmental Protection.

Executed in Tallahassee, Florida.

Michael P. Halpin, P.E.
Administrator,



Siting Coordination Office

FILING AND ACKNOWLEDGMENT

FILED, on this date, pursuant to §120.52 Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

Essie Turner 1-12-10 Clerk Date

Service List: CC by email (receipt verification requested):

Brooke Lewis, Esquire
Carolyn Raeppe, Esquire
Douglas S. Roberts, Esquire
Hopping Green & Sams, P.A.
P.O. Box 6526
Tallahassee, FL 32314
craeppe@hgslaw.com
droberts@hgslaw.com
blewis@hgslaw.com

Katherine Fleming, Asst. Gen. Cnsl.
Florida Public Service Commission
2540 Shumard Oak Blvd.
Tallahassee, FL 32399-0850
keflemin@psc.state.fl.us

Lawrence N. Curtin
Gigi Rollini
Holland & Knight, LLP
P.O. Drawer 810
Tallahassee, FL 32301
larry.curtin@hklaw.com
gigi.rollini@hklaw.com

Kealy West, Asst. Gen. Cnsl
St. Johns River Water Management District
4049 Reid Street
Palatka, FL 32177
kwest@sjrwmd.com

R. Alex Glenn, Esquire
Suzanne Ennis, Esquire
Progress Energy Florida, LLC
Post Office Box 14042
St. Petersburg, FL 33733
alex.glenn@pgnmail.com
Suzanne.Ennis@pgnmail.com

Martha A. Moore, Sr. Attorney
Southwest FL Water Management District
2379 Broad Street
Brooksville, FL 34604-6899
martha.moore@swfwmd.state.fl.us

E. Leon Jacobs, Jr.
Williams & Jacobs
1720 S. Gadsden St.
MS 14, Suite 201
Tallahassee, FL 32301
Ljacobs50@comcast.net
(Attorney for Southern Alliance for Clean
Energy, Inc.)

Fred Landt, Esquire
PO Box 2045
Ocala, FL 34478
fl3swim47@aol.com
(Counsel for Withlacoochee RPC)

Emily Norton, Esquire
Fish and Wildlife Conservation Commission
620 South Meridian Street
Tallahassee, FL 32399-1600
emily.norton@myfwc.com

Gerald Livingston, Esquire
Pennington, Moore et al.
215 S. Monroe St., Flr 2
Tallahassee, FL 32301
(counsel for East Central Florida RPC)
jerry@penningtonlaw.com

Matt Davis, Asst. Gen. Cnsl.
Department of Community Affairs
2555 Shumard Oak Blvd.
Tallahassee, Florida 32399-2100
matthew.davis@dca.state.fl.us

Donald D. Conn, Esquire
4000 Gateway Centre Blvd.
Suite 100
Pinellas Park, FL 33782
(counsel for Tampa Bay RPC)
dconn@penningtonlaw.com

Menchion, Kimberly, Asst. Gen. Cnsl.
Department of Transportation
Haydon Burns Building
605 Suwannee Street, MS 58
Tallahassee, FL 32399-0450
Kimberly.Menchion@dot.state.fl.us

J. Norman White, Esquire
2632 Eagle Court
Lake Wales, FL 33898
gatorwhite@aol.com
(counsel for Central Florid RPC)

Peter Aare, Asst. County Attorney
Office of the Citrus County Attorney
110 N. Apopka Ave.
Inverness, FL 34450
peter.aare@bocc.citrus.fl.us

Anne Bast Brown, County Attorney
Office of the Levy County Attorney
380 South Court Street
Bronson, FL 32621
annebrownlevy@bellsouth.net

Kent L. Wessinger, Asst. Co. Atty.
Garth C. Coller, County Atty.
Office of the Hernando County Attorney
20 North Main Street Suite 462
Brooksville, FL 34601
kentw@co.hernando.fl.us
cao@co.hernando.fl.us

Fred Morrison, City Attorney
City of Leesburg
PO Box 491357
Leesburg, FL. 34740-1357
fredm@mclinburnsed.com

Marva M. Taylor, Asst. Co. Atty
Robert Brazel, Asst. Co. Atty
Hillsborough County Atty.
Post Office Box 1110
Tampa, Florida 33601-1110
taylormm@hillsboroughcounty.org
brazelr@hillsboroughcounty.org

Thomas Trask, Esquire
Attorney for the City of Oldsmar
Frazer Hubbard Brandt Trask & Yacavone
595 Main Street
Dunedin, FL 34698
ttrask@fhbty.com

Sanford A. Minkoff, County Attorney
Office of the Lake County Attorney
PO Box 7800
Tavares, Florida 32778-7800
sminkoff@lakecountyfl.gov

Kenneth Buchman, City Attorney
City of Plant City
1012 Redbud Circle
Plant City, FL 33563
kbuchman@plantcitygov.com

Janice McLean, Asst. City Attorney
City Attorney – City of Tampa
Old City Hall, 5th Floor
315 E. Kennedy Blvd.
Tampa, FL 33602
jan.mclean@ci.tampa.fl.us

Jerri A. Blair, Esquire
CITY ATTORNEY FOR THE CITY OF
WILDWOOD
P.O. Box 130
Tavares, Florida 32778
jblair710@aol.com

Thomas L. Wright, County Attorney
Marion County
601 SE 25th Ave.
Ocala, FL 34471-9109
tom.wright@marioncountyfl.org

Jewel White Cole, Asst. Co. Atty.
Pinellas County Attorney's Office
315 Court St
Clearwater, Florida 33756-5165
jcole@pinellascounty.org

Richard T. Tschantz, General Counsel
Andrew Zodrow, Asst. General Counsel
EPC of Hillsborough County
3629 Queen Palm Drive
Tampa, FL 33619
tschantz@epchc.org
zodrow@epchc.org

Michael Duclos, Asst. Co. Atty
Polk County Attorney's Office
Post Office Box 9005
Bartow, Florida 33830-9005
michaelduclos@polk-county.net

Derrill McAteer, Esquire
The Hogan Law Firm
Post Office Box 485
Brooksville, FL 34605
(Attorney for Sumter County*)
derrill@hoganlawfirm.com

Harold A. Horne, Comm. Dev. Director
City of Dunnellon
20750 River Drive
Dunnellon, FL 34431
hhorne@dunnellon.org
cc: wjespersen@dunnellon.org

George O'Bier, Bld & Zoning Official
City of Inglis
PO Box 249
Inglis, Florida 34449
ingliszoning@bellsouth.net

Robert W. Brinkman, Chair
Suwannee – St. John's Group of the Sierra
Club of Florida
915 NE 20th Avenue
Gainesville, FL 32609-3850
robbrinkman@cox.net

Toni Sturtevant, Esquire
Department of Environmental Protection
3900 Commonwealth Blvd.
Mail Station 35
Tallahassee, FL 32399-3000
toni.sturtevant@dep.state.fl.us