

FACILITY NAME: Turkey Point

Section 5

REPORT NUMBER: 2009-302

DRAFT SIM/IN-PLANT JPMS

CONTENTS:

Draft SIMULATOR / IN-PLANT JPMS

Location of Electronic Files:

Submitted By:

Edwin Diaz

Verified By:

Mark J. Riches



Facility: Turkey Point Task No: 24094001501
 Place Unit 4 Post Accident
 Task Title: Hydrogen Monitor In Service JPM No: NRC-25-IP-JPM-I
 K/A Reference: 028 A2.02 (3.5/3.9)
 Examinee: _____ NRC Examiner: _____
 Facility Evaluator: _____ Date: _____
 Method of testing: In Plant
 Simulated Performance X
 Classroom _____ Simulator _____ Plant X

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

1. Unit 4 has experienced a valid Safety Injection signal.
2. All applicable prerequisites listed in Section 3.0 are satisfied.
3. Post Accident Hydrogen Monitoring system is in normal standby alignment.

Task Standard:

1. PAHMS Alignment Completed per Section 7.1 of 4-OP-094, "Containment Post-Accident Monitoring Systems."

Required Materials:

1. Two way radio (optional communications device)
2. 4-OP-094, "Containment Post-Accident Monitoring Systems"
3. "A" key
4. Valve Operating Handle (located in Aux Bldg E/W hallway)

General References:

1. 4-OP-094, "Containment Post-Accident Monitoring Systems"

Initiating Cue:

1. You have been directed by the RO to place the Post Accident Hydrogen Monitor in service in accordance with 4-OP-094, Section 7.1.

Time Critical Task: YES (30 min)

Validation Time: 15 minutes

HAND JPM BRIEFING SHEET TO EXAMINEE AT THIS TIME!

SIMULATOR SETUP

Reset to IC #

N/A

Load Lesson

N/A

Ensure Simulator Operator Checklist is complete

N/A

Denote critical steps with a check mark(✓)

Start Time _____

STEP 1 :	Obtain Required Materials	<input type="checkbox"/> SAT <input type="checkbox"/> UNSAT
<u>Standard:</u>	<ol style="list-style-type: none"> 1. Obtains a copy of <u>4-OP-094, Post Accident Monitoring System</u>. 2. Verifies latest revision and no outstanding OTSCs. 3. Begins review of section: 7.1 Post Accident H₂ Monitor Startup. 	
<u>Cue</u>	<p>Evaluator may choose to require the candidate to obtain procedure section.</p> <p>When the correct procedure is identified & verified, provide the operator with the procedure.</p>	
<u>Comment</u>		
NOTE:	<p style="text-align: center;">NOTE</p> <p><i>Hydrogen Monitors should be in service within 30 minutes of a valid SI signal.</i></p>	

NOTE		
STEP 2 :	<i>Hydrogen Monitors should be in service within 30 minutes of a valid SI signal.</i>	<input type="checkbox"/> SAT <input type="checkbox"/> UNSAT
	7.1.1 Initial Conditions <input type="checkbox"/> 1. All applicable prerequisites listed in Section 3.0 are satisfied.	
<u>Standard:</u>	1. Reviews Note prior to step 7.1.1. Notes that the task must be completed within 30 minutes of the safety injection signal. 2. Determines prerequisites met from JPM Briefing Sheet Initial Conditions (thus procedure initial conditions complete).	
<u>Cue</u>	N/A	
<u>Comment</u>		
NOTE:		

STEP 3 :	7.1.2 Procedure Steps	NOTES
√		___ SAT ___ UNSAT
	<p>• Valves PASS-4-008, 4-001A, 4-001B, 4-002A and 4-002B are located in the floor at the junction of the north/south hallway.</p> <p>• Full travel for valves is provided in parenthesis and should not be exceeded or damage to reach rod assemblies may occur.</p> <p>1. Remove the floor caps AND open the following valves using the reach rods located in the Auxiliary Building.</p> <p>___ a. Post Accident Sampling System Return Line Isolation Valve, PASS-4-008 (2 turns)</p> <p>___ b. H₂ Analyzer 4A Outlet Isol, PAHM-4-001A (3 turns)</p> <p>___ c. H₂ Analyzer Outlet Isol, PAHM-4-001B (6 turns)</p> <p>___ d. PACV Vent and Sample System to PAHM Header Isolation Valve (RR), PAHM-4-002A (6 turns)</p> <p>___ e. PACV Vent and Sample System to PAHM Header Isolation Valve (RR), PAHM-4-002B (6 turns)</p>	
<u>Standard:</u>	<p>Proceeds to the Aux Bldg east-west hallway and describes how to unlock and obtain a T-handle tool from the rack.</p> <p>Simulates removing floor caps by engaging the T-handle tool into each cap and rotating them counter clockwise. Then simulates opening the following valves by engaging the T-handle tool to the valve operator and turning the operator the specified number of turns counter clockwise:</p> <p>a. PASS-4-008 (2 turns).</p> <p>b. PAHM-4-001A (3 turns).</p> <p>c. PAHM-4-001B (6 turns).</p> <p>d. PAHM-4-002A (6 turns).</p> <p>e. PAHM-4-002B (6 turns).</p>	
<u>Cue</u>	<p>For each of the valves listed above, when applicant correctly identifies how to remove floor cap, state, "The floor cap is removed."</p> <p>When applicant correctly demonstrates how to operate valve in the open direction, state, "The valve operator has been rotated the applicable number of turns".</p>	
<u>Comment</u>		
NOTE:	<p style="text-align: center;">NOTES</p> <p>• Valves PASS-4-008, 4-001A, 4-001B, 4-002A and 4-002B are located in the floor at the junction of the north/south hallway.</p> <p>• Full travel for valves is provided in parenthesis and should not be exceeded or damage to reach rod assemblies may occur.</p>	

<p>STEP 4 : √</p>	<p>7.1.2 (Cont'd)</p> <p>2. Unlock and open PACVS Isol Vlv Penet 51, HV-4-3, outside the Unit 4 Pipe and Valve Room. (An A key is required for this lock.)</p>	<p>___ SAT ___ UNSAT</p>
<p><u>Standard:</u></p>	<p>Removes lock from HV-4-3 remote operator handwheel (South end of Aux Bldg 18' elevation N/S hallway outside U4 P&V Room) using an A key, then opens valve using remote operator handwheel.</p>	
<p><u>Cue</u></p>	<p>When candidate simulates turning valve handwheel counterclockwise, point to open indicator to show valve is open.</p>	
<p><u>Comment</u></p>		
<p>NOTE:</p>	<p>Although not specified in the procedure, candidate may reinstall lock on valve. This is not required for this JPM.</p>	

STEP 6 :	Request the Unit 4 RO perform step 7.1.2.4	<input type="checkbox"/> SAT <input type="checkbox"/> UNSAT
<u>Standard:</u>	Simulates request for Unit 4 RO to perform step 7.1.2.4 of 4-OP-094	
<u>Cue</u>	<ol style="list-style-type: none"> 1. As Unit 4 RO acknowledge request to perform step 7.1.2.4 of 4-OP-094 (Control Room Portion) 2. As Unit 4 RO, tell candidate step 7.1.2.4 has been completed. Direct candidate to continue with step 7.1.2.5. 	
<u>Comment</u>		
NOTE:	<i>Candidate may attempt to use a communication device or simulate communication directly to the evaluator.</i>	

STEP 7 : ✓	5. At the area outside the Unit 3 BA Evap Room, remove floor cap AND close WHT Waste Transfer Pump Discharge to Rad Waste Building, MPAS-001,(1/4 turn). OR At the Waste Evaporator Feed Pump Room in the Radwaste Bldg, close Aux Bldg WHT valve to Radwaste Bldg WHT, 1731.	___ SAT ___ UNSAT
<u>Standard:</u>	<ol style="list-style-type: none"> 1. Attempts to remove the floor cap for MPAS-001. 2. When MPAS-001 floor cap determined to be jammed in place, leaves the Aux Building and proceeds to the Waste Evaporator Feed Pump room in the Radwaste Building. 3. Closes valve 1731 (Rotates handwheel fully clockwise until the valve stem is fully inserted.) 	
<u>Cue</u>	<ol style="list-style-type: none"> 1. When candidate attempts to remove MPAS-001 floor cap, state that it is jammed and cannot be removed 2. When candidate identifies 1731 handwheel has been rotated fully clockwise and valve stem inserted, confirm this indication. 	
<u>Comment</u>		
NOTE:		

NOTE		
STEP 8 √	<p><i>The following valves are located on the Auxiliary Building roof near the Unit 4 containment wall.</i></p> <p>6. Perform the following:</p> <p> a. Unlock and open Isol Vlv from WHT Pp Back, MPAS-4-004 (an A key is required).</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<u>Standard:</u>	<p>1. Proceeds to Auxiliary Building roof near Unit 4 Containment wall.</p> <p>2. Unlocks MPAS-4-004 handwheel with an A key, then opens valve. (Rotates handwheel fully counterclockwise until valve stem fully withdrawn.)</p>	
<u>Cue</u>	When candidate identifies handwheel has been rotated fully counterclockwise and valve stem withdrawn, confirm this indication	
<u>Comment</u>		
NOTE:	<i>Although not specified in the procedure, candidate may reinstall lock on valve.</i>	

STEP 9 : √	_____ b. Close Isol Vlv MPAS to Purge Air Rtn, MPAS-4-005.	____ SAT ____ UNSAT
<u>Standard:</u>	Simulates Closing MPAS-4-005. (Rotates handwheel fully clockwise until the valve stem is fully inserted.)	
<u>Cue</u>	1. When candidate identifies handwheel has been rotated fully clockwise and valve stem inserted, confirm that valve travel has stopped and stem is inserted. 2. Tell candidate another operator will perform step 7.1.2.7	
<u>Comment</u>		
NOTE:		
Termination Cue:	Operator returns JPM briefing sheet when informed step 7.1.2.7 will be performed by another operator.	STOP

Stop Time _____

Verification of Completion

Job Performance Measure No. NRC-25-IP-JPM-I

Examinee's Name: _____

Examiner's Name: _____

Date Performed: _____

Facility Evaluator: _____

Number of Attempts: _____

Time to Complete: _____

Question Documentation:

Question:

Response:

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

JPM BRIEFING SHEET

The examiner will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

INITIAL CONDITIONS:

1. Unit 4 has experienced a valid Safety Injection signal.
2. All applicable procedure prerequisites are satisfied.
3. Post Accident Hydrogen Monitoring system is in **NORMAL STANDBY ALIGNMENT**.

INITIATING CUE:

You are the Primary Operator and you have been directed by the Unit 4 RO to place the Post Accident Hydrogen Monitor in service per 4-OP-094 section 7.1.

This is a Simulate JPM. No plant equipment is to be manipulated during the performance of this task.

HAND THIS PAPER BACK TO YOUR EVALUATOR
WHEN YOU HAVE SATISFACTORILY COMPLETED
THE ASSIGNED TASK.



Facility:	Turkey Point	Task No:	_____
Task Title:	TRIP and RESET AFW Pump "A" T&T Valve, MOV-6459A	JPM No:	NRC-25-IP-JPM-J
K/A Reference:	061-K4.07 Turbine trip, including overspeed 3.1/3.3		
Examinee:	_____	NRC Examiner:	_____
Facility Evaluator:	_____	Date:	_____
Method of testing:	_____		
Simulated Performance	<input checked="" type="checkbox"/>	Actual Performance	_____
Classroom	_____	Simulator	_____
		Plant	<input checked="" type="checkbox"/>

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

1. 3-OP-075, Auxiliary Feedwater System, Section 7.8, Auxiliary Feedwater Pump A Manual Start is in progress.
2. 3-OP-075, Auxiliary Feedwater System has been completed up to Section 7.8.7 by another NPO.
3. The Unit 3 Unit Supervisor has directed the NPO to perform steps 7.8.8 through 7.8.10 of 3-OP-075, Auxiliary Feedwater System.

Task Standard:

- AFW Pump "A" T&T Valve, MOV-6459A, is TRIPPED in accordance with 3-OP-075, Auxiliary Feedwater System, Section 7.8.
- AFW Pump "A" T&T Valve, MOV-6459A is RESET, in accordance with 3-OP-075, Auxiliary Feedwater System, Section 7.8.

Required Materials:

- Applicable Personal Protective Equipment
- 3-OP-075, Auxiliary Feedwater System

General References:

- 3-OP-075, Auxiliary Feedwater System

Initiating Cue: You have been directed to perform steps 7.8.8 through 7.8.10 of 3-OP-075, Auxiliary Feedwater System to TRIP and RESET AFW Pump "A" T&T Valve, MOV-6459A.

Time Critical Task: No

Validation Time: 15 minutes

HAND JPM BRIEFING SHEET TO EXAMINEE AT THIS TIME!

SIMULATOR SETUP

Reset to IC #

N/A

Load Lesson

N/A

Ensure Simulator Operator Checklist is complete

N/A

Denote critical steps with a check mark(✓)

Start Time _____



STEP 1 : ✓	Trip AFW Pump A T&T Valve, MOV-6459A.	___ SAT ___ UNSAT
<u>Standard:</u>	7.8.8 Push the mechanical trip button for the AFW Pump A T&T Valve, MOV-6459A	
<u>Cue</u>	Once NPO identifies Mechanical Trip Button and simulates depressing the button, confirm Trip Button has been depressed.	
<u>Comment</u>		
NOTE:		

STEP 2 :	NPO verifies AFW Pump A T&T Valve, MOV-6459A, is closed.	<input type="checkbox"/> SAT <input type="checkbox"/> UNSAT
<u>Standard:</u>	then verify the following: 1. AFW Pump A T&T Valve, MOV-6459A, is closed. 2. Control Room mechanical trip light is ON.	
<u>Cue</u>	1. If operator verifies MOV-6459A CLOSED by valve stem moving downward and stopping, confirm CLOSED. 2. When NPO simulates contacting Control Room confirm that Control Room mechanical trip light is On and valve indicates CLOSED.	
<u>Comment</u>		
NOTE:	Evaluator may act as Control Room Operator to simulate communications.	


STEP 3 :	NPO confirms Local Test Panel Mechanical Trip Light is on.	___ SAT ___ UNSAT
<u>Standard:</u>	Local Test Panel mechanical trip light is On.	
<u>Cue</u>	When NPO identifies Local Test Panel mechanical trip light tell the NPO that the RED light is OFF and the GREEN light is on.	
<u>Comment</u>		
NOTE:	Local Test Panel Mechanical Trip Light is AMBER.	

STEP 4 : √	Reset AFW Pump A T&T Valve, MOV-6459A	<input type="checkbox"/> SAT <input type="checkbox"/> UNSAT
<u>Standard:</u>	<p style="text-align: center;">CAUTION</p> <p><i>When releasing the mechanical trip rod, ensure the rod does not snap back towards the turbine. This could damage the turbine overspeed tappet shaft.</i></p> <p>7.8.9 Reset AFW Pump A T&T Valve, MOV-6459A, by pulling the mechanical trip rod approximately one inch.</p>	
<u>Cue</u>	When NPO describes operating mechanical trip rod tell operator that the mechanical trip rod will travel no further and does not snap back to the tripped position.	
<u>Comment</u>		

NOTE:



TRIP HEAD LEVER
CORRECT POSITION



TRIP HEAD LEVER INCORRECT
POSITION (HELD BY TAPPET)

STEP 5 :	Verify the limit switch arm roller is properly positioned.	<input type="checkbox"/> SAT <input type="checkbox"/> UNSAT
<u>Standard:</u>	7.8.10 Verify the limit switch arm roller is on the North side of the roller plate AND the tappet nut is contacting the head lever below the scribe mark.	
<u>Cue</u>	When operator describes the correct standard, confirm that the limit switch arm roller is properly positioned.	
<u>Comment</u>		
NOTE:		

Terminating Cue:	The task is complete when the Examinee returns the cue sheet to the examiner.	STOP
-------------------------	--	-------------

Stop Time _____

Verification of Completion

Job Performance Measure No. NRC-25-IP-JPM-J

Examinee's Name: _____

Examiner's Name: _____

Date Performed: _____

Facility Evaluator: _____

Number of Attempts: _____

Time to Complete: _____

Question Documentation:

Question:

Response:

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

JPM BRIEFING SHEET

The examiner will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

INITIAL CONDITIONS:

1. 3-OP-075, Auxiliary Feedwater System, Section 7.8, Auxiliary Feedwater Pump A Manual Start is in progress.
2. 3-OP-075, Auxiliary Feedwater System has been completed up to Section 7.8.7 by another NPO.
3. The Unit 3 Unit Supervisor has directed the NPO to perform steps 7.8.8 through 7.8.10 of 3-OP-075, Auxiliary Feedwater System.

INITIATING CUE:

You have been directed to perform steps 7.8.8 through 7.8.10 of 3-OP-075, Auxiliary Feedwater System to TRIP and RESET AFW Pump "A" T&T Valve, MOV-6459A.

Acknowledge to the examiner when you are ready to begin.

**HAND THIS PAPER BACK TO YOUR EVALUATOR WHEN YOU HAVE
SATISFACTORILY COMPLETED THE ASSIGNED TASK.**



1
2
3
4
5

Facility: Turkey Point Task No: _____
 Task Title: Transfer Vital Loads Between Inverters Job Performance Measure No: NRC-25-IP-JPM-K
 K/A Reference: 062-A4.04 (2.6/2.7)
 Examinee: _____ NRC Examiner: _____
 Facility Evaluator: _____ Date: _____
 Method of testing: In Plant
 Simulated Performance X Actual Performance _____
 Classroom _____ Simulator _____ Plant X

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

1. 3B Inverter is Supplying Load, 4B Inverter is Supplying Load, and B SPARE Inverter is in STANDBY.
2. All initial conditions in 0-OP-003.3, 120V VITAL INSTRUMENT AC SYSTEM, specifically Sections 3.0 and 5.1, have been verified satisfactorily and complete.

Task Standard:

1. Transfer load to the correct inverter.

Required Materials:

1. 0-OP-003.3, 120V VITAL INSTRUMENT AC SYSTEM (12/08)

General References:

1. 0-OP-003.3, 120V VITAL INSTRUMENT AC SYSTEM (12/08)

Initiating Cue:

In preparation for inverter maintenance, you have been directed by the Unit 4 RO to transfer 4P08 bus load from the 4B (4Y02) Inverter to the B SPARE (4Y04) Inverter in accordance with 0-OP-003.3, 120V VITAL INSTRUMENT AC SYSTEM, Section 7.1.

Time Critical Task: No

Validation Time: 18 minutes

HAND JPM BRIEFING SHEET TO EXAMINEE AT THIS TIME!

SIMULATOR SETUP

Reset to IC #

N/A

Load Lesson

N/A

Ensure Simulator Operator Checklist is complete

N/A

INSTRUCTIONS TO OPERATOR

HAND JPM BRIEFING SHEET TO OPERATOR AT THIS TIME!

INITIAL CONDITIONS:

1. Two inverters in service, B SPARE (4Y04) in standby and 4B (4Y02) supplying load.
2. All initial conditions in 0-OP-003.3, 120V VITAL INSTRUMENT AC SYSTEM, specifically Sections 3.0 and 5.1, have been verified satisfactorily and complete.

INITIATING CUE:

In preparation for inverter maintenance, you have been directed by the Unit 4 RO to transfer 4P08 bus load from the 4B (4Y02) Inverter to the B SPARE (4Y04) Inverter.

TERMINATION CUE:

When you feel that you have satisfactorily completed the assigned task, hand your JPM Briefing Sheet back to me.

Do you have any questions?

You may begin.

NOTES TO EVALUATOR:

1. Two inverters in service, B SPARE (4Y04) in standby and 4B (4Y02) supplying load.
2. All initial conditions in 0-OP-003.3, 120V VITAL INSTRUMENT AC SYSTEM, specifically Sections 3.0 and 5.1, have been verified satisfactorily and complete.

NOTE: This is a SIMULATE JPM. Tell candidate that NO plant equipment is to be manipulated during the performance of this task.

Denote critical steps with a check mark (✓)

Start Time _____

<p>STEP 1 :</p>	<p>7.0 INFREQUENT OPERATIONS 7.1 Transfer of Bus Load from Normal to Spare Inverter (Normal Transfer)</p> <p>INIT Transfer from Inverter _____ Date/Time Started: _____ / _____</p> <p>7.1.1 Initial Conditions ____ 1. All applicable prerequisites listed in Section 3.0 are satisfied. ____ 2. The applicable Spare Inverter is in Standby in accordance with Subsection 5.1 of this procedure.</p>	<p>____ SAT ____ UNSAT</p>
<p><u>STANDARD:</u></p>	<p>1. Obtains copy of 0-OP-003.3, 120V VITAL INSTRUMENT AC SYSTEM.</p> <p>2. Verifies procedure is current with no outstanding OTSCs.</p>	
<p>CUES:</p>	<p>1. <i>Provide copy of procedure once operator has located & verified 0-OP-003.3, or require candidate to obtain procedure.</i></p> <p>2. <i>Inform operator that Sections 3.0 and 5.1 conditions have been met.</i></p> <p>3. Candidate should proceed to Control Room, ask permission to enter and go to the Inverter Room.</p> <p><u>Once candidate has identified need to go to the Control Room tell the candidate to insure that the specific task to be performed is not relayed to Control Room personnel.</u></p>	
<p>Comment</p>		
<p>NOTE:</p>	<p style="text-align: center;">NOTE</p> <p><i>Enclosure 1 provides a reference for Typical Normal Vital AC Inverter Switch Location, or Enclosure 2 provides a reference for Typical Spare Vital AC Inverter Switch Location as applicable.</i></p>	

<p>STEP 2 : ↓</p>	<p>(procedure step 7.1.2.1)</p> <p>_____ 1. Place the Alternate Source Transfer Switch to the position indicated in Table 2.</p> <p style="text-align: center;">TABLE 2</p> <table border="1" data-bbox="365 426 1263 804"> <thead> <tr> <th>When Substituting SPARE INVERTER</th> <th>For INSERVICE NORMAL INVERTER</th> <th>Place ALTERNATE SOURCE TRANSFER SWITCH</th> <th>To Position (LOCKED)</th> <th>INTI</th> </tr> </thead> <tbody> <tr> <td>AS (3Y04)</td> <td>3A (3Y01)</td> <td>3Y01B</td> <td>BACKUP TO SPARE INVERTER (3Y04) AS</td> <td></td> </tr> <tr> <td>AS (3Y04)</td> <td>4A (4Y01)</td> <td>4Y01B</td> <td>BACKUP TO SPARE INVERTER (3Y04) AS</td> <td></td> </tr> <tr> <td>BS (4Y04)</td> <td>3B (3Y02)</td> <td>3Y02B</td> <td>BACKUP TO SPARE INVERTER (4Y04) BS</td> <td></td> </tr> <tr> <td>BS (4Y04)</td> <td>4B (4Y02)</td> <td>4Y02B</td> <td>BACKUP TO SPARE INVERTER (4Y04) BS</td> <td></td> </tr> <tr> <td>CS (3Y06)</td> <td>3C (3Y05)</td> <td>3Y05B</td> <td>BACKUP TO SPARE INVERTER (3Y06) CS</td> <td></td> </tr> <tr> <td>CS (3Y06)</td> <td>4C (4Y05)</td> <td>4Y05B</td> <td>BACKUP TO SPARE INVERTER (3Y06) CS</td> <td></td> </tr> <tr> <td>DS (4Y06)</td> <td>3D (3Y07)</td> <td>3Y07B</td> <td>BACKUP TO SPARE INVERTER (4Y06) DS</td> <td></td> </tr> <tr> <td>DS (4Y06)</td> <td>4D (4Y07)</td> <td>4Y07B</td> <td>BACKUP TO SPARE INVERTER (4Y06) DS</td> <td></td> </tr> </tbody> </table>	When Substituting SPARE INVERTER	For INSERVICE NORMAL INVERTER	Place ALTERNATE SOURCE TRANSFER SWITCH	To Position (LOCKED)	INTI	AS (3Y04)	3A (3Y01)	3Y01B	BACKUP TO SPARE INVERTER (3Y04) AS		AS (3Y04)	4A (4Y01)	4Y01B	BACKUP TO SPARE INVERTER (3Y04) AS		BS (4Y04)	3B (3Y02)	3Y02B	BACKUP TO SPARE INVERTER (4Y04) BS		BS (4Y04)	4B (4Y02)	4Y02B	BACKUP TO SPARE INVERTER (4Y04) BS		CS (3Y06)	3C (3Y05)	3Y05B	BACKUP TO SPARE INVERTER (3Y06) CS		CS (3Y06)	4C (4Y05)	4Y05B	BACKUP TO SPARE INVERTER (3Y06) CS		DS (4Y06)	3D (3Y07)	3Y07B	BACKUP TO SPARE INVERTER (4Y06) DS		DS (4Y06)	4D (4Y07)	4Y07B	BACKUP TO SPARE INVERTER (4Y06) DS		<p>_____ SAT</p> <p>_____ UNSAT</p>
When Substituting SPARE INVERTER	For INSERVICE NORMAL INVERTER	Place ALTERNATE SOURCE TRANSFER SWITCH	To Position (LOCKED)	INTI																																											
AS (3Y04)	3A (3Y01)	3Y01B	BACKUP TO SPARE INVERTER (3Y04) AS																																												
AS (3Y04)	4A (4Y01)	4Y01B	BACKUP TO SPARE INVERTER (3Y04) AS																																												
BS (4Y04)	3B (3Y02)	3Y02B	BACKUP TO SPARE INVERTER (4Y04) BS																																												
BS (4Y04)	4B (4Y02)	4Y02B	BACKUP TO SPARE INVERTER (4Y04) BS																																												
CS (3Y06)	3C (3Y05)	3Y05B	BACKUP TO SPARE INVERTER (3Y06) CS																																												
CS (3Y06)	4C (4Y05)	4Y05B	BACKUP TO SPARE INVERTER (3Y06) CS																																												
DS (4Y06)	3D (3Y07)	3Y07B	BACKUP TO SPARE INVERTER (4Y06) DS																																												
DS (4Y06)	4D (4Y07)	4Y07B	BACKUP TO SPARE INVERTER (4Y06) DS																																												
<p><u>STANDARD:</u></p>	<ol style="list-style-type: none"> 1. Selects correct switch (4Y02B) and unlocks operating handle. 2. Repositions switch 4Y02B to BACKUP TO SPARE INVERTER (4Y04) BS and re-installs lock. 																																														
<p>CUES:</p>	<ol style="list-style-type: none"> 1. <i>Once candidate locates switch, correctly describes how to remove lock from operating handle and simulates repositioning switch handle, confirm these operations.</i> 2. <i>When candidate correctly describes how to re-install lock on switch handle, confirm this operation.</i> 																																														
<p>Comment</p>																																															
<p>NOTE:</p>																																															

STEP 3 : ↓	<p>DO NOT ALLOW THE BS INVERTER DOOR TO BE OPENED</p> <p>(procedure step 7.1.2.2)</p> <p>_____ 2. Place the Sync Reference Selector Switch (SW-2) inside the applicable SPARE inverter to NORMAL (DOWN) position.</p>	_____ SAT _____ UNSAT
<u>STANDARD:</u>	<ol style="list-style-type: none"> 1. Operator identifies the B SPARE (4Y04) inverter. 2. Simulates positioning switch SW-2 to NORMAL (DOWN) position. 	
CUE:	<ol style="list-style-type: none"> 1. <i>When candidate identifies B SPARE (4Y04) inverter and states that the switch is inside the inverter requiring door opening to operate, tell the operator to simulate going inside the inverter to position the switch.</i> 2. <i>When SW-2 operation properly described, confirm re-positioning.</i> 	
Comment		
NOTE:	<p>DO NOT ALLOW THE BS INVERTER DOOR TO BE OPENED</p>	

STEP 4 :	(procedure step 7.1.2.3) 3. Verify the following at the SPARE inverter: ___ a. The IN SYNC light is ON. ___ b. The ALT SOURCE AVAIL light is ON. ___ c. The SYNC REFERENCE NORMAL light is ON.	___ SAT ___ UNSAT
<u>STANDARD:</u>	Determines the B SPARE (4Y04) inverter lights listed above are all ON.	
CUE:	When each light properly identified, state light is ON.	
Comment		
NOTE:		

STEP 5 : ✓	<p>DO NOT ALLOW THE 4B(4Y02) INVERTER DOOR TO BE OPENED</p> <p>(procedure step 7.1.2.4)</p> <p>___ 4. Place the Sync Reference Selector Switch (SW-2) inside the applicable INSERVICE NORMAL inverter to the EXTERNAL (UP) position</p>	___ SAT ___ UNSAT
<u>STANDARD:</u>	<ol style="list-style-type: none"> 1. Operator identifies 4B (4Y02) inverter. 2. Simulates positioning switch SW-2 to EXTERNAL (UP) position. 	
CUE:	<ol style="list-style-type: none"> 1. <i>When candidate identifies 4B (4Y02) inverter and states that the switch is inside the inverter requiring door opening to operate, tell the operator to simulate going inside the inverter to position the switch.</i> 2. <i>When SW-2 operation properly described, confirm re-positioning.</i> 	
Comment		
NOTE:	<p>DO NOT ALLOW THE 4B(4Y02) INVERTER DOOR TO BE OPENED</p>	

STEP 6 :	(procedure step 7.1.2.5) 5. Verify the following at the INSERVICE NORMAL inverter: ___ a. The IN SYNC Light is ON. ___ b. The SYNC REFERENCE EXTERNAL light is ON.	___ SAT ___ UNSAT
<u>STANDARD:</u>	Determines the 4B (4Y02) inverter lights listed above are all ON.	
<u>CUE:</u>	When each light properly identified, state light is ON.	
<u>Comment:</u>		
<u>NOTE:</u>		

STEP <u>7</u> : ✓	(procedure step 7.1.2.6) ___ 6. Using Table 3, determine which Instrument AC Selector Switch should be used AND record: _____ <div style="text-align: center;"> TABLE 3 </div> <table border="1" style="margin-left: auto; margin-right: auto; border-collapse: collapse; text-align: center;"> <thead> <tr> <th style="padding: 2px;">When Substituting SPARE INVERTER</th> <th style="padding: 2px;">For INSERVICE NORMAL INVERTER</th> <th style="padding: 2px;">Place INSIRUMENT AC SELECTOR SWITCH</th> <th style="padding: 2px;">To SUPPLY Position</th> <th style="padding: 2px;">INITIALS</th> </tr> </thead> <tbody> <tr><td style="padding: 2px;">AS (3Y04)</td><td style="padding: 2px;">3A (3Y01)</td><td style="padding: 2px;">3P07A</td><td style="padding: 2px;">AC LINE</td><td style="padding: 2px;"></td></tr> <tr><td style="padding: 2px;">AS (3Y04)</td><td style="padding: 2px;">4A (4Y01)</td><td style="padding: 2px;">4P07A</td><td style="padding: 2px;">AC LINE</td><td style="padding: 2px;"></td></tr> <tr><td style="padding: 2px;">BS (4Y04)</td><td style="padding: 2px;">3B (3Y02)</td><td style="padding: 2px;">3P08A</td><td style="padding: 2px;">AC LINE</td><td style="padding: 2px;"></td></tr> <tr><td style="padding: 2px;">BS (4Y04)</td><td style="padding: 2px;">4B (4Y02)</td><td style="padding: 2px;">4P08A</td><td style="padding: 2px;">AC LINE</td><td style="padding: 2px;"></td></tr> <tr><td style="padding: 2px;">CS (3Y06)</td><td style="padding: 2px;">3C (3Y05)</td><td style="padding: 2px;">3P06A</td><td style="padding: 2px;">AC LINE</td><td style="padding: 2px;"></td></tr> <tr><td style="padding: 2px;">CS (3Y06)</td><td style="padding: 2px;">4C (4Y05)</td><td style="padding: 2px;">4P06A</td><td style="padding: 2px;">AC LINE</td><td style="padding: 2px;"></td></tr> <tr><td style="padding: 2px;">DS (4Y06)</td><td style="padding: 2px;">3D (3Y07)</td><td style="padding: 2px;">3P09A</td><td style="padding: 2px;">AC LINE</td><td style="padding: 2px;"></td></tr> <tr><td style="padding: 2px;">DS (4Y06)</td><td style="padding: 2px;">4D (4Y07)</td><td style="padding: 2px;">4P09A</td><td style="padding: 2px;">AC LINE</td><td style="padding: 2px;"></td></tr> </tbody> </table>	When Substituting SPARE INVERTER	For INSERVICE NORMAL INVERTER	Place INSIRUMENT AC SELECTOR SWITCH	To SUPPLY Position	INITIALS	AS (3Y04)	3A (3Y01)	3P07A	AC LINE		AS (3Y04)	4A (4Y01)	4P07A	AC LINE		BS (4Y04)	3B (3Y02)	3P08A	AC LINE		BS (4Y04)	4B (4Y02)	4P08A	AC LINE		CS (3Y06)	3C (3Y05)	3P06A	AC LINE		CS (3Y06)	4C (4Y05)	4P06A	AC LINE		DS (4Y06)	3D (3Y07)	3P09A	AC LINE		DS (4Y06)	4D (4Y07)	4P09A	AC LINE		___ SAT ___ UNSAT
When Substituting SPARE INVERTER	For INSERVICE NORMAL INVERTER	Place INSIRUMENT AC SELECTOR SWITCH	To SUPPLY Position	INITIALS																																											
AS (3Y04)	3A (3Y01)	3P07A	AC LINE																																												
AS (3Y04)	4A (4Y01)	4P07A	AC LINE																																												
BS (4Y04)	3B (3Y02)	3P08A	AC LINE																																												
BS (4Y04)	4B (4Y02)	4P08A	AC LINE																																												
CS (3Y06)	3C (3Y05)	3P06A	AC LINE																																												
CS (3Y06)	4C (4Y05)	4P06A	AC LINE																																												
DS (4Y06)	3D (3Y07)	3P09A	AC LINE																																												
DS (4Y06)	4D (4Y07)	4P09A	AC LINE																																												
<u>STANDARD:</u>	Using Table 3, identifies 4P08A as the correct Selector Switch to use.																																														
<u>CUE:</u>	N/A																																														
<u>Comment</u>																																															
<u>NOTE:</u>																																															

STEP 8 :	(procedure step 7.1.2.7.a) 7. Perform the following steps at the appropriate Instrument AC Selector Switch panel in the Cable Spreading Room: ___ a. Verify that the Alternate Power Available light is ON.	___ SAT ___ UNSAT
STANDARD:	Verifies 4P08A alternate power available light ON	
CUE:	<i>When 4P08A alternate power available light correctly identified, tell candidate that light is ON.</i>	
Comment		
NOTE:		

STEP 9 :	(procedure step 7.1.2.7.b) b. Test the Sync Verification Light as follows: ____ (1) Position the Sync Switch to SYNCH LAMP TEST. ____ (2) Verify lamp comes ON.	____ SAT ____ UNSAT
<u>STANDARD:</u>	1. Positions 4P08A SYNC switch to SYNCH LAMP TEST. 2. Verifies 4P08A SYNC Verification Light ON.	
CUE:	1. <i>When SYNC switch identified and operation correctly described, confirm switch manipulation.</i> 2. <i>When Sync Verification Light correctly identified, tell candidate light is ON.</i>	
Comment		
NOTE:		

STEP 10 :	<p>(procedure step 7.1.2.7.c)</p> <p style="text-align: center;">NOTE</p> <p><i>In the following Substeps 7.1.2.7.c.(1) and 7.1.2.7.c.(2) the bright light will go OFF, but a slight glow is expected. This is acceptable.</i></p> <p>c. Perform a synch check as follows: ___ (1) Position the Sync Switch to SYNCH CHECK PUSH. ___ (2) Depress and hold the Sync Switch. ___ (3) Verify that the Sync Verification Light stays OFF.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<u>STANDARD:</u>	<ol style="list-style-type: none"> 1. Positions 4P08A SYNC Switch to SYNCH CHECK PUSH. 2. Depresses & holds 4P08A SYNC Switch. 3. Verifies 4P08A Sync Verification Light stays OFF. 4. Releases 4P08A SYNC Switch. 	
CUE:	<ol style="list-style-type: none"> 1. <i>When SYNC switch identified and operation correctly described, confirm switch manipulations.</i> 2. <i>When Sync Verification Light correctly identified, tell candidate light is OFF.</i> 	
Comment		
NOTE:	<p style="text-align: center;">NOTE</p> <p><i>In the following Substeps 7.1.2.7.c.(1) and 7.1.2.7.c.(2) the bright light will go OFF, but a slight glow is expected. This is acceptable.</i></p>	

<p>STEP 11 : ↓</p>	<p>___ d. Place the Instrument AC Selector Switch to the position indicated in Table 3.</p> <p style="text-align: center;">NOTE</p> <p><i>Initials should be entered for the applicable inverter. N/A should be entered for all others.</i></p> <p style="text-align: center;">TABLE 3</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th>When Substituting SPARE INVERTER</th> <th>For INSERVICE NORMAL INVERTER</th> <th>Place INSTRUMENT AC SELECTOR SWITCH</th> <th>To SUPPLY Position</th> <th>INITIALS</th> </tr> </thead> <tbody> <tr><td>AS (3Y04)</td><td>3A (3Y01)</td><td>3P07A</td><td>AC LINE</td><td></td></tr> <tr><td>AS (3Y04)</td><td>4A (4Y01)</td><td>4P07A</td><td>AC LINE</td><td></td></tr> <tr><td>BS (4Y04)</td><td>3B (3Y02)</td><td>3P08A</td><td>AC LINE</td><td></td></tr> <tr><td>BS (4Y04)</td><td>4B (4Y02)</td><td>4P08A</td><td>AC LINE</td><td></td></tr> <tr><td>CS (3Y06)</td><td>3C (3Y05)</td><td>3P06A</td><td>AC LINE</td><td></td></tr> <tr><td>CS (3Y06)</td><td>4C (4Y05)</td><td>4P06A</td><td>AC LINE</td><td></td></tr> <tr><td>DS (4Y06)</td><td>3D (3Y07)</td><td>3P09A</td><td>AC LINE</td><td></td></tr> <tr><td>DS (4Y06)</td><td>4D (4Y07)</td><td>4P09A</td><td>AC LINE</td><td></td></tr> </tbody> </table>	When Substituting SPARE INVERTER	For INSERVICE NORMAL INVERTER	Place INSTRUMENT AC SELECTOR SWITCH	To SUPPLY Position	INITIALS	AS (3Y04)	3A (3Y01)	3P07A	AC LINE		AS (3Y04)	4A (4Y01)	4P07A	AC LINE		BS (4Y04)	3B (3Y02)	3P08A	AC LINE		BS (4Y04)	4B (4Y02)	4P08A	AC LINE		CS (3Y06)	3C (3Y05)	3P06A	AC LINE		CS (3Y06)	4C (4Y05)	4P06A	AC LINE		DS (4Y06)	3D (3Y07)	3P09A	AC LINE		DS (4Y06)	4D (4Y07)	4P09A	AC LINE		<p>___ SAT</p> <p>___ UNSAT</p>
When Substituting SPARE INVERTER	For INSERVICE NORMAL INVERTER	Place INSTRUMENT AC SELECTOR SWITCH	To SUPPLY Position	INITIALS																																											
AS (3Y04)	3A (3Y01)	3P07A	AC LINE																																												
AS (3Y04)	4A (4Y01)	4P07A	AC LINE																																												
BS (4Y04)	3B (3Y02)	3P08A	AC LINE																																												
BS (4Y04)	4B (4Y02)	4P08A	AC LINE																																												
CS (3Y06)	3C (3Y05)	3P06A	AC LINE																																												
CS (3Y06)	4C (4Y05)	4P06A	AC LINE																																												
DS (4Y06)	3D (3Y07)	3P09A	AC LINE																																												
DS (4Y06)	4D (4Y07)	4P09A	AC LINE																																												
<p><u>STANDARD:</u></p>	<ol style="list-style-type: none"> 1. Selects correct switch (4P08A). 2. Positions 4P08A Instrument AC Selector Switch to AC LINE. 																																														
<p>CUE:</p>	<p><i>When 4P08A Instrument AC Selector Switch identified and operation correctly described, confirm switch manipulation.</i></p>																																														
<p>Comment</p>																																															
<p>NOTE:</p>	<p style="text-align: center;">NOTE</p> <p><i>Initials should be entered for the applicable inverter. N/A should be entered for all others.</i></p> <p><i>Tell candidate that another operator will continue with step 7.1.2.8</i></p>																																														
<p>Terminating Cue:</p>	<p><i>The task is complete when the Examinee returns the cue sheet to the examiner.</i></p>	<p>STOP</p>																																													

Verification of Completion

Job Performance Measure No. NRC-25-IP-JPM-K

Examinee's Name: _____

Examiner's Name: _____

Date Performed: _____

Facility Evaluator: _____

Number of Attempts: _____

Time to Complete: _____

Question Documentation:

Question:

Response:

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

JPM BRIEFING SHEET

THIS IS A SIMULATED PLANT JPM. DO NOT OPERATE ANY PLANT EQUIPMENT.

Initial Conditions:

1. 3B Inverter is Supplying Load, 4B Inverter is Supplying Load, and B SPARE Inverter is in STANDBY.
2. All initial conditions in 0-OP-003.3, 120V VITAL INSTRUMENT AC SYSTEM, specifically Sections 3.0 and 5.1, have been verified satisfactorily and complete.

INITIATING CUE:

In preparation for inverter maintenance, you have been directed by the Unit 4 RO to transfer 4P08 bus load from the 4B (4Y02) Inverter to the B SPARE (4Y04) Inverter in accordance with 0-OP-003.3, 120V VITAL INSTRUMENT AC SYSTEM, Section 7.1.

HAND THIS PAPER BACK TO YOUR EVALUATOR WHEN YOU FEEL THAT YOU HAVE SATISFACTORILY COMPLETED THE ASSIGNED TASK.



Facility:	Turkey Point	Task No:	_____
Task Title:	Respond to Turbine Runback, Rods Fail to Insert	JPM No:	NRC-25- SIM-JPM-A
	045 K4.12 Automatic turbine runback 3.3/3.6		
K/A Reference:	_____		
Examinee:	_____	NRC Examiner:	_____
Facility Evaluator:	_____	Date:	_____
Method of testing:	_____		
Simulated Performance	_____	Actual Performance	X
Classroom	_____	Simulator	X
		Plant	_____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

- Unit 3 is operating at 60% power and stable
- Unit 3 is preparing to return to 100% power.
- No equipment is out of service.

Task Standard:

- 3-ONOP-089, Turbine Runback actions have been performed correctly.
- Tavg/Tref within 4°F in accordance with 0-ONOP-089, Turbine Runback (Match Tavg-Tref), 0-ADM-211, Emergency and Off-Normal Operating Procedure Usage (Tavg-Tref within 4° F during a transient)
-

Required Materials:

- 0-ONOP-089, Turbine Runback
- 0-ADM-211, Emergency and Off-Normal Operating Procedure Usage

General References:

- 0-ADM-211, Emergency and Off-Normal Operating Procedure Usage
- 0-ONOP-089, Turbine Runback

Initiating Cue:

- You have been directed to Respond to Plant Conditions

Time Critical Task: No

Validation Time: 10 minutes

HAND JPM BRIEFING SHEET TO EXAMINEE AT THIS TIME!

SIMULATOR SETUP**Reset to IC #**

16

Instructor Facility Operator Actions

1. Verify Reset to IC 24
2. Schema » Reactor » Rod Control/Rod Position » SC408 Rod Motion Failures & Controls » TFL10101:L1-SC408 Rods Fail to Move Auto » TRUE » INSERT
3. Verify RED SQUARE framing SC408.
4. Schema » Feedwater » F/W Main » Condensate Polishing Demineralizers » Feedwater Pumps » 3P1B (B Feedwater Pump) » TVFABP1B:FA-3P1B Bearing » Selected 1.0 » Pending » Verify ORANGE SQUARE framing 3P1B.

Ensure Simulator Operator Checklist is complete**Instructor Facility Operator Actions (Cont.)**

5. Go to RUN.
6. Go to SUMMARY » PENDING » Right click on TVFABP1B » TRIGGER

Denote critical steps with a check mark()

Start Time _____

STEP 1 :	Recognition by Operator that Turbine Runback is occurring.	___ SAT ___ UNSAT
<u>Standard:</u>	Operator recognizes the Turbine Runback and identifies the need to respond in accordance with 3-ONOP-089, Turbine Runback.	
<u>Cue</u>	Provided by Simulator response.	
<u>Comment</u>		
NOTE:	<i>Operator may identify that 3B Feedwater Pump is degrading and trip the 3B Feedwater Pump.</i>	

STEP 2 : √	4.0 IMMEDIATE OPERATOR ACTIONS 4.1 Verify the automatic actions listed in Section 3.0 are functioning to stabilize and maintain plant conditions, or assume manual control.	___ SAT ___ UNSAT
<u>Standard:</u>	Used 3-ONOP-089, Turbine Runback to verify Immediate Operator Actions have been completed.	
<u>Cue</u>	1. Provided by Simulator response. 2. Terminate JPM after Operator matches Tavg-Tref within 4° F.	
<u>Comment</u>		
NOTE:	<p><i>Operator may choose at any time to address the lack of Control Rod insertion and take manual action in accordance with Elements 6, 7, and 8.</i></p> <p><i>Operator may choose to review all Automatic Actions prior to addressing lack of Control Rod insertion.</i></p> <p><i>Inserting rods to match Tavg and Tref may be delayed until the subsequent actions after verifying Automatic Actions w/3-ONOP-089.</i></p>	

STEP 3 :	3.1 Main Turbine Control Valves and the Reheat Intercept Valves modulate closed upon receipt of a runback signal from the Generator Governor/Speed Changer.	<input type="checkbox"/> SAT <input type="checkbox"/> UNSAT
<u>Standard:</u>	Verified Main Turbine Control Valves and the Reheat Intercept Valves modulate closed	
<u>Cue</u>	Provided by Simulator response.	
<u>Comment</u>		
NOTE:	<p><i>Operator may choose at any time to address the lack of Control Rod insertion and take manual action in accordance with Elements 6,7,and 8.</i></p> <p><i>Operator may choose to review all Automatic Actions prior to addressing lack of Control Rod insertion.</i></p> <p><i>Inserting rods to match Tavg and Tref may be delayed until the subsequent actions after verifying Automatic Actions w/3-ONOP-089.</i></p>	

STEP 4 :	3.2 Steam Dump Valves arm and open to relieve excess steam to the condenser due to the load rejection and subsequent Tavg/Tref mismatch.	<input type="checkbox"/> SAT <input type="checkbox"/> UNSAT
<u>Standard:</u>	Verified Steam Dump Valves are armed and opened if needed.	
<u>Cue</u>	Provided by Simulator response.	
<u>Comment</u>		
NOTE:	<p><i>Operator may choose at any time to address the lack of Control Rod insertion and take manual action in accordance with Elements 6,7, and 8.</i></p> <p><i>Operator may choose to review all Automatic Actions prior to addressing lack of Control Rod insertion.</i></p> <p><i>Inserting rods to match Tavg and Tref may be delayed until the subsequent actions after verifying Automatic Actions w/3-ONOP-089.</i></p>	

STEP 5 :	3.3 Automatic Rod Insertion Control adjusts core reactivity to match Tavg with Tref.	<input type="checkbox"/> SAT <input type="checkbox"/> UNSAT
<u>Standard:</u>	Operator recognizes that Control Rods did not insert as required and inserts Control Rods to match Tavg within 4 degrees F.	
<u>Cue</u>	Provided by Simulator response.	
<u>Comment</u>		
NOTE:	<p><i>Operator may choose at any time to address the lack of Control Rod insertion and take manual action in accordance with Elements 6,7, and 8.</i></p> <p><i>Operator may choose to review all Automatic Actions prior to addressing lack of Control Rod insertion.</i></p> <p><i>Inserting rods to match Tavg and Tref may be delayed until the subsequent actions after verifying Automatic Actions w/3-ONOP-089.</i></p>	

STEP 6 : √	Operator places Rod Control Selector Switch to MANUAL.	___ SAT ___ UNS ___ AT
<u>Standard:</u>	Operator placed Rod Control Selector Switch to MANUAL.	
<u>Cue</u>	Provided by Simulator response.	
<u>Comment</u>		
NOTE:	<p><i>Operator may choose at any time to address the lack of Control Rod insertion and take manual action in accordance with Elements 6,7, and 8.</i></p> <p><i>Operator may choose to review all Automatic Actions prior to addressing lack of Control Rod insertion.</i></p> <p><i>Inserting rods to match Tavg and Tref may be delayed until the subsequent actions after verifying Automatic Actions w/3-ONOP-089.</i></p>	

STEP 7 : √	Insertion Control Rods to adjust core reactivity to match Tavg with Tref.	___ SAT ___ UNSAT
<u>Standard:</u>	Operator places IN-HOLD-OUT Switch to IN to insert Control Rods to match Tavg with Tref within 4 □ F.	
<u>Cue</u>	Provided by Simulator response.	
<u>Comment</u>		
NOTE:	<p><i>Operator may choose at any time to address the lack of Control Rod insertion and take manual action in accordance with Elements 6, 7, and 8.</i></p> <p><i>Operator may choose to review all Automatic Actions prior to addressing lack of Control Rod insertion.</i></p> <p><i>Inserting rods to match Tavg and Tref may be delayed until the subsequent actions after verifying Automatic Actions w/3-ONOP-089.</i></p>	

STEP 8 : √	Tavg and Tref are matched.	___ SAT ___ UNS ___ AT
<u>Standard:</u>	Tavg and Tref are within 4°F.	
<u>Cue</u>	Provided by Simulator response.	
<u>Comment</u>		
NOTE:	<p><i>Operator may choose at any time to address the lack of Control Rod insertion and take manual action in accordance with Elements 6, 7, and 8.</i></p> <p><i>Operator may choose to review all Automatic Actions prior to addressing lack of Control Rod insertion.</i></p> <p><i>Inserting rods to match Tavg and Tref may be delayed until the subsequent actions after verifying Automatic Actions w/3-ONOP-089.</i></p>	

STEP 9 :	3.4 Verifies Main Feedwater Control Valves open or close in programmed response to steamflow/feedflow mismatch and level input signals, to maintain steam generator levels at program.	<input type="checkbox"/> SAT <input type="checkbox"/> UNSAT
<u>Standard:</u>	Verified that Main Feedwater Control Valves responded properly to steamflow/feedflow mismatch and level input signals, to maintain steam generator levels at program.	
<u>Cue</u>	Provided by Simulator response.	
<u>Comment</u>		
NOTE:	<p><i>Operator may choose at any time to address the lack of Control Rod insertion and take manual action in accordance with Elements 6,7,and 8.</i></p> <p><i>Operator may choose to review all Automatic Actions prior to addressing lack of Control Rod insertion.</i></p> <p><i>Inserting rods to match Tavg and Tref may be delayed until the subsequent actions after verifying Automatic Actions w/3-ONOP-089.</i></p>	

<u>STEP 10</u> :	3.5 Verify Pressurizer Level Controller and Pressurizer Pressure Controller vary charging pumps speed and Heater/Spray actuation to maintain the programmed level and pressure, as required for the changing values of Tavg.	___ SAT ___ UNSAT
<u>Standard:</u>	Verifies that Pressurizer Level Controller and Pressurizer Pressure Controller maintaining the programmed level and pressure, as required for the changing values of Tavg.	
<u>Cue</u>	Provided by Simulator response.	
<u>Comment</u>		
NOTE:	<p><i>Operator may choose at any time to address the lack of Control Rod insertion and take manual action in accordance with Elements 6,7, and 8.</i></p> <p><i>Operator may choose to review all Automatic Actions prior to addressing lack of Control Rod insertion.</i></p> <p><i>Inserting rods to match Tavg and Tref may be delayed until the subsequent actions after verifying Automatic Actions w/3-ONOP-089.</i></p>	

SUBSEQUENT OPERATOR ACTIONS		
STEP 11 : √	5.1 Determine the cause of the runback initiation AND refer to the appropriate ONOP for specific recovery instructions. 5.2 Verify the following conditions: 5.2.1 Steam generator levels and pressures stabilized. 5.2.2 Steam dumps closed. 5.2.3 Tavg matches Tref. 5.2.4 Pressurizer levels and pressures stabilized.	___ SAT ___ UNSAT
<u>Standard:</u>	5.2 Verify the following conditions: 5.2.1 Steam generator levels and pressures stabilized. 5.2.2 Steam dumps closed. 5.2.3 Tavg matches Tref within 4° F. 5.2.4 Pressurizer levels and pressures stabilized.	
<u>Cue</u>	Terminate JPM after Operator matches Tavg-Tref within 4° F.	
<u>Comment</u>		
NOTE:	Critical Step: 5.2.3 Tavg matches Tref within 4° F.	
Terminating Cue:	The task is complete when the Examinee returns the cue sheet to the examiner.	STOP

Stop Time _____

Verification of Completion

Job Performance Measure No. NRC-25-SIM-JPM-A

Examinee's Name: _____

Examiner's Name: _____

Date Performed: _____

Facility Evaluator: _____

Number of Attempts: _____

Time to Complete: _____

Question Documentation:

Question:

Response:

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

JPM BRIEFING SHEET

The examiner will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

INITIAL CONDITIONS:

- Unit 3 is operating at 60% power and stable
- Unit 3 is preparing to return to 100% power.
- No equipment is out of service.

INITIATING CUE:

You have been directed to respond to plant conditions.

Acknowledge to the examiner when you are ready to begin.

HAND THIS PAPER BACK TO YOUR EVALUATOR WHEN YOU HAVE SATISFACTORILY COMPLETED THE ASSIGNED TASK.



Facility:	<u>Turkey Point</u>	Task No:	_____
	<u>Pressurizer Level Control</u>		
Task Title:	<u>Channel Fails Low</u>	JPM No:	<u>NRC-25-SIM-JPM-B</u>
	<u>APE 028 AA2.01 PZR level</u>		
	<u>indicators and alarms 3.4 /3.6</u>		
K/A Reference:	_____		
Examinee:	_____	NRC Examiner:	_____
Facility Evaluator:	_____	Date:	_____
Method of testing:	_____		
Simulated Performance	_____	Actual Performance	<u>X</u>
Classroom	_____	Simulator	<u>X</u>
		Plant	_____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

- Unit 3 is at 100% and stable
- No equipment is out of service

Task Standard:

- Unit 3 is at 100% and stable.
- Pressurizer level stable and returning to programmed level.
- Letdown has been returned to service.

Required Materials:

- 3-ONOP-041.6, Pressurizer Level Control Malfunction

General References:

- 3-ONOP-041.6, Pressurizer Level Control Malfunction

Initiating Cue:

- You have been directed to respond to plant conditions.

Time Critical Task: No

Validation Time: XX minutes

HAND JPM BRIEFING SHEET TO EXAMINEE AT THIS TIME!

SIMULATOR SETUP**Reset to IC #**

IC-1: 100% Power MOL

Ensure Simulator Operator Checklist is complete**Simulator Operator Instructions**

1. Verify IC-1
2. Place Simulator to RUN
3. Schema » Reactor Coolant System » Pressurizer » L-459 » LT-459 » TFH1TV59:H1-LT-459
Transmitter Fail Low » TRUE » INSERT

Denote critical steps with a check mark(✓)

Start Time _____

STEP 1 :	Respond to Pressurizer Level Control Channel 459 fails low.	___ SAT ___ UNSAT
<u>Standard:</u>	<ul style="list-style-type: none"> Operator refers to 3-ONOP-041.6 Pressurizer Level Control Malfunction. 	
<u>Cue</u>		
<u>Comment</u>		
NOTE:	<i>Operator may choose to refer to ARP prior to entering ONOP.</i>	

STEP 2 :	Verify automatic actions occur.	___ SAT ___ UNSAT
<u>Standard:</u>	Operator verifies the following: 1. High Pressure LTDN Isolation Valve LCV-3-460 CLOSES. 2. LTDN Orifice Isolation Valves, CV-3-200A, CV-3-200B AND CV-3-200C CLOSE. 3. All Pressurizer Heaters turn OFF. 4. Charging flow INCREASES.	
<u>Cue</u>		
<u>Comment</u>		
NOTE:		

STEP 3 :	Check pressurizer level indicators LI-3-459A, LI-3-460 AND LI-3-461,	___ SAT ___ UNSAT
<u>Standard:</u>	Identifies Channel 459 as failed low.	
<u>Cue</u>		
<u>Comment</u>		
NOTE:		

STEP 4 : √	Place CHANNEL SELECT PRESSURIZER LEVEL CONTROL switch in position 2 or 3.	___ SAT ___ UNSAT
<u>Standard:</u>	Places CHANNEL SELECT PRESSURIZER LEVEL CONTROL switch in position 2 or 3.	
<u>Cue</u>		
<u>Comment</u>		
NOTE:		

STEP 5 : √	Place MASTER CHARGING PUMP CONTROLLER, LC-3-459G in MANUAL.	___ SAT ___ UNSAT
<u>Standard:</u>	1. Placed MASTER CHARGING PUMP CONTROLLER, LC-3-459G in MANUAL 2. Maintain programmed level per Enclosure 1.	
<u>Cue</u>		
<u>Comment</u>		
NOTE:		

STEP 6 :	IF LR-3-459 is selected to a defective channel, THEN place CHANNEL SELECT PRESSURIZER LEVEL RECORDER in another position.	___ SAT ___ UNSAT
<u>Standard:</u>	Placed CHANNEL SELECT PRESSURIZER LEVEL RECORDER in position other than Channel 459.	
<u>Cue</u>		
<u>Comment</u>		
NOTE:		

STEP 6 : √	Re-establish Letdown flow	___ SAT ___ UNSAT
<u>Standard:</u>	<ol style="list-style-type: none"> 1. Throttle Low Pressure LTDN Controller, PCV-3-145, as necessary to prevent LTDN relief valve from lifting, (approximately 50 percent open). 2. Manually control Low Pressure Letdown Control Valve, PCV-3-145, to limit pressure spike. 3. OPEN High Pressure L/D Isol Vlv from Loop B Cold Leg LCV-3-460. 4. OPEN L/D Isolation Valves, CV-3-200 A, B OR C as required to restore pressurizer level to programmed level. 5. Return Lower Pressure Letdown Control Valve, PCV-3-145 to automatic. 	
<u>Cue</u>	Tell operator that another operator will perform the remainder of the procedure.	
<u>Comment</u>		
NOTE:	<i>Steps 1,2, and 5 are not critical steps.</i>	
Terminating Cue:	The task is complete when the Examinee returns the cue sheet to the examiner.	STOP

Stop Time _____

Verification of Completion

Job Performance Measure No. NRC-25-SIM-JPM-B

Examinee's Name: _____

Examiner's Name: _____

Date Performed: _____

Facility Evaluator: _____

Number of Attempts: _____

Time to Complete: _____

Question Documentation:

Question:

Response:

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

JPM BRIEFING SHEET

The examiner will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

INITIAL CONDITIONS:

- Unit 3 is at 100% and stable
- No equipment is out of service

INITIATING CUE:

- You have been directed to respond to plant conditions.

Acknowledge to the examiner when you are ready to begin.

**HAND THIS PAPER BACK TO YOUR EVALUATOR WHEN YOU HAVE
SATISFACTORILY COMPLETED THE ASSIGNED TASK.**



Facility: Turkey Point Task No: _____

ALIGN SAFETY INJECTION FOR
HOT LEG RECIRC

Task Title: _____ JPM No: NRC-25-SIM-JPM-C

011 EK3.13 Hot-leg
injection/recirculation 3.8 / 4.2

K/A Reference: _____

Examinee: _____ NRC Examiner: _____

Facility Evaluator: _____ Date: _____

Method of testing: _____

Simulated Performance	_____	Actual Performance	_____ X
-----------------------	-------	--------------------	---------

Classroom	_____	Simulator	_____ X	Plant	_____
-----------	-------	-----------	---------	-------	-------

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

- UNIT ON COLD LEG RECIRCULATION (RHR LOOP A)
- 12 HOURS HAVE ELAPSED SINCE EVENT INITIATION
- IDLE RHR TRAIN AVAILABLE (RHR LOOP B)
- POWER AVAILABLE TO BOTH 4 KV BUSES
- 3A HHSI PUMP IS RUNNING
- RHR SUPPLYING COLD LEG RECIRCULATION
- ALL CCW HEAT EXCHANGERS ARE IN SERVICE
- STEP 32 OF 3-EOP-E-1, Loss of Reactor or Secondary Coolant. IS IN PROGRESS
- 3-EOP-E-1, Loss of Reactor or Secondary Coolant. IS OPEN ON THE UNIT SUPERVISOR DESK AND OPEN TO STEP 32 WITH STEP 32 CIRCLED.

Task Standard:

- S.I. FLOW SUPPLIED TO HOT LEGS

Required Materials:

- 3-EOP-ES-1.4, TRANSFER TO HOT LEG RECIRCULATION
- 3-EOP-E-1, Loss of Reactor or Secondary Coolant

General References:

- 3-EOP-ES-1.4, TRANSFER TO HOT LEG RECIRCULATION
- 3-EOP-E-1, Loss of Reactor or Secondary Coolant

- Initiating Cue:

You have been directed to ALIGN SAFETY INJECTION FOR HOT LEG RECIRC AS REQUIRED BY STEP 32 OF 3-EOP-E-1, Loss of Reactor or Secondary Coolant.

Time Critical Task: NO

Validation Time: 15 minutes

HAND JPM BRIEFING SHEET TO EXAMINEE AT THIS TIME!

SIMULATOR SETUP

Reset to IC # 58

Load Lesson

- LOADAND EXECUTE LESSON: JPM 01062012501.LSN
- TRIGGER “**MOV-3-869 CLOSED**”
- OPEN MOV-3-863A & MOV-3-863B
- Unfreeze simulator.

Ensure Simulator Operator Checklist is complete

Denote critical steps with a check mark()

Start Time

<p>STEP 1 : √</p>	<p>TRANSITION AS REQUIRED BY STEP 32 OF 3-EOP-E-1</p>	<p>___ SAT ___ UNSAT</p>
<p><u>Standard:</u></p>	<p>TRANSITION MADE TO 3-EOP-ES-1.4, TRANSFER TO HOT LEG RECIRCULATION</p>	
<p><u>Cue</u></p>		
<p><u>Comment</u></p>		
<p>NOTE:</p>	<p><i>Candidate should place a mark through circled step 32 prior to transition.</i></p>	

STEP 2 :	Check High-Head SI Pumps – ANY RUNNING	___ SAT ___ UNSAT
<u>Standard:</u>	<ul style="list-style-type: none">• Candidate recognizes that 3A HHSI Pump is running	
<u>Cue</u>		
<u>Comment</u>		
NOTE:		

<p>STEP 3 :</p>	<p>Verify RHR Heat Exchanger CCW Outlet Valve On Operating RHR Train – OPEN MOV-3-749A for train A</p>	<p>___ SAT ___ UNSAT</p>
<p><u>Standard:</u></p>	<p>MOV-3-749A, RHR Heat Exchanger CCW Outlet Valve VERIFIED OPEN</p>	
<p><u>Cue</u></p>		
<p><u>Comment</u></p>		
<p>NOTE:</p>		

STEP 4 : √	3 Verify Safety Injection To Hot Leg Isolation Valve, MOV-3-869 - OPEN	___ SAT ___ UNSAT
<u>Standard:</u>	1.MOV-3-869 ATTEMPTED TO BE VERIFIED OPEN. (Candidate should attempt to open valve prior to transitioning to Att. 1) 2.Candidate transitions to to ATTACHMENT 1.	
<u>Cue</u>	If candidate calls to locally open MOV-3-869 tell candidate that valve is inaccessible.	
<u>Comment</u>		
NOTE:	MOV-3-869 is closed and cannot be opened. Operator should attempt to open valve prior to transitioning to Att. 1	

<p>STEP 4 : √</p>	<p>ESTABLISH ALTERNATE HOT LEG INJECTION FLOWPATH (ATT. 1)</p>	<p>___ SAT ___ UNSAT</p>
<p><u>Standard:</u></p>	<ol style="list-style-type: none"> 1. TRANSITIONED TO ATTACHMENT 1 OF 3-EOP-ES-1.4 2. Primary Operator DIRECTED TO CLOSE 3-752A AND 3-752B 3. RHR LOOP VALVES MOV-3-750 AND MOV-3-751 OPENED 	
<p><u>Cue</u></p>	<p>BOOTH OPERATOR RESPOND AS PO/FS AND ON SIMULATOR TRIGGER "CLOSE 3-752A/B", I.F. OPERATOR REPORTS COMPLETION OF TASK.</p>	
<p><u>Comment</u></p>		
<p>NOTE:</p>		

STEP 5 :	VERIFY THE POSITION OF THE RHR HEAT EXCHANGER OUTLET VALVE	<input type="checkbox"/> SAT <input type="checkbox"/> UNSAT
<u>Standard:</u>	SNPO DIRECTED TO VERIFY THAT 3-759A IS OPEN	
<u>Cue</u>	BOOTH OPERATOR RESPOND AS PO/FS AND ON SIMULATOR REPORT 3-759A OPEN	
<u>Comment</u>		
NOTE:		

STEP 6 : ✓	REMOVE THE HHSI PUMPS AND CONTAINMENT SPRAY PUMPS FROM SERVICE	___ SAT ___ UNSAT
<u>Standard:</u>	CONTROL SWITCHES FOR ALL HHSI PUMPS ALIGNED TO UNIT 3 RWST AND THE UNIT 3 CONTAINMENT SPRAY PUMPS POSITIONED TO PULL-TO-LOCK	
<u>Cue</u>		
<u>Comment</u>		
NOTE:		

STEP 7 :	VERIFY RHR COLD LEG INJECTION ISOLATION VALVE OPEN	<input type="checkbox"/> SAT <input type="checkbox"/> UNSAT
<u>Standard:</u>	MOV-3-744A AND/OR MOV-3-744B VERIFIED OPEN	
<u>Cue</u>		
<u>Comment</u>		
NOTE:		

STEP 8 : ✓	ISOLATE THE RHR ALTERNATE DISCHARGE FLOW-PATH	___ SAT ___ UNSAT
<u>Standard:</u>	<ul style="list-style-type: none"> • MOV-3-863A, RHR ALTERNATE DISCHARGE VALVE, CLOSED • MOV-3-863B, RHR ALTERNATE DISCHARGE VALVE, CLOSED 	
<u>Cue</u>		
<u>Comment</u>		
NOTE:		

STEP 9 : √	ALIGN THE RHR RECIRCULATION FLOWPATH	<input type="checkbox"/> SAT <input type="checkbox"/> UNSAT
<u>Standard:</u>	SNPO DIRECTED TO OPEN 3-741A, RHR RECIRC ISOLATION VALVE	
<u>Cue</u>	BOOTH OPERATOR TRIGGERS "OPEN 3-741A" AND REPORT STATUS TO OPERATOR 1-2 MINUTES AFTER ORDER WAS GIVEN	
<u>Comment</u>		
NOTE:		

STEP 10 : ✓	VERIFY STATUS OF CORE EXIT THERMOCOUPLES	___ SAT ___ UNSAT
<u>Standard:</u>	CORE EXIT TEMPERATURES VERIFIED STABLE OR DECREASING	
<u>Cue</u>		
<u>Comment</u>		
NOTE:		

STEP 11 :	CONTINUE LONG-TERM RECOVERY ACTIONS	<input type="checkbox"/> SAT <input type="checkbox"/> UNSAT
<u>Standard:</u>	<ul style="list-style-type: none"> • RESTORATION OF NORMAL HOT LEG RECIRCULATION ATTEMPTED AS DIRECTED BY THE TSC STAFF • INJECTION TO BOTH HOT LEGS AND COLD LEGS VERIFIED • RHR PUMP INJECTION TO HOT AND COLD LEGS MAINTAINED UNTIL NORMAL HOT LEG RECIRCULATION LINEUP IS ESTABLISHED 	
<u>Cue</u>	BOOTH OPERATOR RESPOND AS TSC AND CONFIRM PLAN IS IN PROGRESS TO RESTORE NORMAL HOT LEG INJECTION	
<u>Comment</u>		
NOTE:	OPERATOR SHOULD USE ERDADS SCREEN TO CONFIRM ALTERNATE RHR FLOW	

STEP 12 :	Return To Procedure And Step In Effect	___ SAT ___ UNSAT
<u>Standard:</u>	RETURNED TO 3-EOP-E-1, Loss of Reactor or Secondary Coolant, STEP 15.	
<u>Cue</u>		
<u>Comment</u>		
NOTE:		
Terminating Cue:	The task is complete when the Examinee returns the cue sheet to the examiner.	STOP
Stop Time		

Verification of Completion

Job Performance Measure No. NRC-25-SIM-JPM-C

Examinee's Name: _____

Examiner's Name: _____

Date Performed: _____

Facility Evaluator: _____

Number of Attempts: _____

Time to Complete: _____

Question Documentation:

Question:

Response:

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

JPM BRIEFING SHEET

The examiner will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

- UNIT ON COLD LEG RECIRCULATION (RHR LOOP A)
- 12 HOURS HAVE ELAPSED SINCE EVENT INITIATION
- IDLE RHR TRAIN AVAILABLE (RHR LOOP B)
- POWER AVAILABLE TO BOTH 4 KV BUSES
- 3A HHSI PUMP IS RUNNING
- RHR SUPPLYING COLD LEG RECIRCULATION
- ALL CCW HEAT EXCHANGERS ARE IN SERVICE
- STEP 32 OF 3-EOP-E-1, Loss of Reactor or Secondary Coolant. IS IN PROGRESS
- 3-EOP-E-1, Loss of Reactor or Secondary Coolant. IS OPEN ON THE UNIT SUPERVISOR DESK AND OPEN TO STEP 32 WITH STEP 32 CIRCLED.

INITIATING CUE:

You have been directed to ALIGN SAFETY INJECTION FOR HOT LEG RECIRC AS REQUIRED BY STEP 32 OF 3-EOP-E-1, Loss of Reactor or Secondary Coolant.

Acknowledge to the examiner when you are ready to begin.

HAND THIS PAPER BACK TO YOUR EVALUATOR WHEN YOU HAVE SATISFACTORILY COMPLETED THE ASSIGNED TASK.



Facility:	<u>Turkey Point</u>	Task No:	_____
Task Title:	<u>Respond to a Source Range Nuclear Instrument Malfunction (MODE 6)</u>	Job Performance Measure No:	<u>NRC-25-SIM-JPM-D</u>
K/A Reference:	<u>015 A2.02 (3.1/3.5)</u>		
Examinee:	_____	NRC Examiner:	_____
Facility Evaluator:	_____	Date:	_____
Method of testing:	<u>Simulator / Control Room</u>		
Simulated Performance	_____	Actual Performance	<u>Yes</u>
Classroom	_____	Simulator	<u>Yes</u>
			Plant _____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

1. Unit 3 is in Mode 6.
2. Refueling activities are in progress.
3. NIS Source Ranges N-31 and N-32 are both in service.
4. Both Gamma Metrics Channels are OOS for maintenance.

Task Standard:

1. N-32 selected for audio count rate.
2. Core alterations suspended.

Required Materials:

3-ONOP-059.5, Source Range Nuclear Instrumentation Malfunction

General References:

3-ONOP-059.5, Source Range Nuclear Instrumentation Malfunction

Initiating Cue:

Respond to plant conditions.

Time Critical Task: No

Validation Time: 10 minutes

HAND JPM BRIEFING SHEET TO EXAMINEE AT THIS TIME!

INITIAL CONDITIONS:

1. Unit 3 is in Mode 6.
2. Refueling activities are in progress.
3. NIS Source Ranges are both in service.
4. Both Gamma Metrics are OOS for maintenance.

INITIATING CUE:

Respond to plant conditions.

TERMINATION CUE:

When you feel that you have satisfactorily completed the assigned task, hand your JPM briefing sheet back to me.

Do you have any questions?

You may begin.

NOTES TO EVALUATOR AND BOOTH OPERATOR:

1. Reset to IC 117 Cavity Drain Pre-Req's Complete
2. Place both channels of Gamma-Metrics O.O.S.:
 - a. Schema REACTOR INCORE/EXCORE DETECTORS Detector #9 TFN1WAFL NE801A DETECTOR FAIL LOW TRUE then INSERT
 - b. Detector #10 TFN1WBFL NE801B DETECTOR FAIL LOW TRUE then INSERT
 - c. Place both Gamma-Metric Block Switches to BLOCK on console
3. Select N-31 for Audio Count Rate; Select N-31/N-32 and N-35/N-36 on console NIS Recorder
4. Place CSD Placards on Vertical Panels.
5. Update console placard to read RCS BORON = 2000 ppm
6. Adjust Boric Acid and Primary Water Auto Makeup flow controller potentiometers for 2000 ppm boron concentration (HIC-3-114 = 4.0, FC-3-113 = 8.0)
7. Change ERDADS screen on VPA to P-T display.
8. Provide an extra Operator to acknowledge annunciators and maintain stable plant conditions.
9. **When Operator has received a turnover of plant status, fail Source Range NI N-31 HIGH:**
Schema REACTOR INCORE/EXCORE DETECTORS Detector #1 TFN1SAFH NE101N31 DETECTOR FAIL HIGH TRUE then INSERT

Denote critical steps with a check mark (✓)

Start Time _____

STEP 1 : ✓	Perform Immediate actions of 3-ONOP-059.5, SOURCE RANGE NUCLEAR INSTRUMENTATION MALFUNCTION. 4.0 IMMEDIATE ACTIONS 4.5 Mode 6 – Refueling 4.5.1 Malfunction of ONE channel: 1. Switch the AUDIO COUNT RATE CHANNEL SELECTOR to the operable source range. 2. Verify at least 2 out of 4 Source Range and Backup NIS (Gamma Metrics) channels are operable, with one Source Range having audible count rate in the Control Room and Containment. a. IF the above requirement is not met, THEN suspend all operations involving core alterations OR positive reactivity changes. 3. IF applicable, THEN notify plant personnel of erroneous Containment Evacuation Alarm.	___ SAT ___ UNSAT
<u>STANDARD:</u>	1. Switches AUDIO COUNT RATE CHANNEL SELECTOR from N-31 to N-32. 2. Suspends all operations involving core alterations since only one of four source range NIs are operable. * 3. Notifies plant personnel of erroneous Containment Evacuation Alarm Operator may reference procedure to verify / perform actions.	
CUE:	<i>Respond as Refueling SRO and/or Reactor Engineer/STA if notified to stop refueling activities and store fuel assemblies in a safe location. Report that refueling has stopped and fuel assemblies are all safely located.</i>	
Comment		
NOTE:	Source Range N-31 has failed HIGH.	

STEP 2 :	Operator obtains copy of 3-ONOP-059.5.	___ SAT ___ UNSAT
<u>STANDARD:</u>	1. Operator obtains Simulator copy of 3-ONOP-059.5 2. Operator verifies Immediate Actions are correct.	
<u>Cue</u>		
<u>Comment</u>		
<u>NOTE:</u>		

<p>STEP 3 : √</p>	<p>5.0 <u>SUBSEQUENT ACTIONS</u> 5.5 Mode 6 – Refueling 5.5.1 Malfunction of ONE channel: 1. Place LEVEL TRIP switch on failed channel in BYPASS position. 2. Place HIGH FLUX AT SHUTDOWN switch on failed channel in BLOCK position. 3. Switch an NIS RECORDER to the operable source range. 4. IF one Source Range having audible count rate in the Control Room and Containment, AND 2 out of 4 NIS (NSSS Source Range and Gamma Metrics) Channels are not operable, THEN verify RCS boron concentration is greater than or equal to the required boron concentration at least once per 12 hours. 5. Notify I&C. 6. Monitor Backup NIS (Gamma Metric) Source Range Count Rate.</p>	<p>___ SAT ___ UNSAT</p>
<p><u>STANDARD:</u></p>	<p>Operator removes N-31 from service. 1. Positions LEVEL TRIP switch to BYPASS. 2. Positions HIGH FLUX AT SHUTDOWN switch to BLOCK. 3. Verifies N-32 displayed on console NIS recorder. 4. Contacts Chemistry determines Boron concentration \geq 1950 ppm. 5. Notifies I&C of N-31 failure. 6. Determines both backup NIS (Gamma-Metric) channels OOS.</p>	
<p>CUES:</p>	<p>1.If called as Reactor Engineering, state that the required RCS Boron concentration is > 1950 ppm. 2.If called as Chemistry, confirm Boron concentration is 2000 ppm. 3.Respond as I&C if notified of N-31 failure. 4.Inform the applicant that another operator will continue from this point.</p>	
<p>Comment</p>		
<p>NOTE:</p>	<p><i>Only Standards 1 and 2 are critical.</i></p>	

STEP 4 :	Applicant should return JPM Initial Condition sheet and state that operator actions are complete.	___ SAT ___ UNSAT
Terminating CUE:	If operator attempts any other compensatory actions beyond this point tell operator that JPM has been completed.	STOP

Stop Time _____

Verification of Completion

Job Performance Measure No. NRC-25-SIM-JPM-D

Examinee's Name: _____

Examiner's Name: _____

Date Performed: _____

Facility Evaluator: _____

Number of Attempts: _____

Time to Complete: _____

Question Documentation:

Question:

Response:

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

JPM BRIEFING SHEET

INITIAL CONDITIONS:

1. Unit 3 is in Mode 6.
2. Refueling activities are in progress.
3. NIS Source Ranges are both in service.
4. Both Gamma Metrics are OOS for maintenance.

INITIATING CUE:

Respond to plant conditions.

**HAND THIS PAPER BACK TO YOUR EVALUATOR WHEN YOU FEEL THAT
YOU HAVE SATISFACTORILY COMPLETED THE ASSIGNED TASK.**



Facility:	<u>Turkey Point</u>	Task No:	_____
Task Title:	<u>Purging the PRT to Reduce Oxygen or Hydrogen Concentration (Major Gas Volume)</u>		
JPM No:	<u>007 K1.04 Nitrogen 2.1/2.3</u>	NRC-25-SIM-JPM-E	_____
K/A Reference:	_____		
Examinee:	_____	NRC Examiner:	_____
Facility Evaluator:	_____	Date:	_____
Method of testing:	_____		
Simulated Performance	_____	Actual Performance	_____ X
Classroom	_____	Simulator	_____ X
		Plant	_____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

- Chemistry reports that PRT Oxygen Concentration is 2.5% by Volume
- Unit 3 is in Mode 1 at 100% Power with no equipment out of service.
- 3-NOP-041.3, Pressurizer Relief Tank up to and including step 5.5.11 has been completed by the off-going shift
- You are the oncoming Reactor Operator and have been briefed on the evolution.
- PRT Level is at 80%.

Task Standard:

- Purge the PRT to Reduce Oxygen Concentration to within required specifications.

Required Materials:

- 3-NOP-041.3, Pressurizer Relief Tank

General References:

- 3-NOP-041.3, Pressurizer Relief Tank

Initiating Cue:

- You have been directed to Purge the PRT to Reduce Oxygen Concentration to within required specifications using 3-NOP-041.3, Pressurizer Relief Tank step 5.5.11.
- All prerequisites have been satisfied.
- You are continuing 3-NOP-041.3 after a turnover from the off-going shift.

Time Critical Task: No

Validation Time: 10 minutes

HAND JPM BRIEFING SHEET TO EXAMINEE AT THIS TIME!

SIMULATOR SETUP

Reset to IC #

Load saved IC on Flash Drive XR-043.dat

Load Lesson

Ensure Simulator Operator Checklist is complete

CLOSE Gas waste Disposal V4658A & B

Denote critical steps with a check mark()

Start Time _____

STEP 1 : ✓	11. ENSURE CV-3-549, PRT VENT, is OPEN	___ SAT ___ UNSAT
<u>Standard:</u>	1. Placed PRT Vent Valve, CV-3-549 switch to open. 2. Verified PRT Vent Valve, CV-3-549 Red Light ON Green Light OFF.	
<u>Cue</u>		
<u>Comment</u>		
NOTE:	<i>Standard #2 is not critical.</i>	

STEP 2 : ✓	13. OPEN CV-3-519B, PRT PRIMARY WATER MAKE UP.	___ SAT ___ UNSAT
<u>Standard:</u>	1. Placed PRT Vent Valve, CV-3-519B switch to open. 2. Verified PRT Vent Valve, CV-3-519B Red Light ON Green Light OFF.	
<u>Cue</u>		
<u>Comment</u>		
NOTE:	<i>Standard #2 is not critical.</i>	

<p>STEP 3 : √</p>	<p>5.5 Purging the PRT to Reduce Oxygen or Hydrogen Concentration (Major Gas Volume) (continued)</p> <p>14. WHEN any of the following conditions exists:</p> <ul style="list-style-type: none"> • PRT level approaches 95% on LI-3-470, PRZR RELIEF TK LEVEL • PRT pressure approaches 10 psig on PI-3-472, PRZR RELIEF TK PRESSURE THEN CLOSE CV-3-519B, PRT PRIMARY WATER MAKE UP. 	<p>___ SAT ___ UNSAT</p>
<p><u>Standard:</u></p>	<ol style="list-style-type: none"> 1. When PRT level approaches 95% placed PRT Vent Valve, CV-3-519B switch to close. 2. Verified PRT Vent Valve, CV-3-519B Red Light OFF Green Light ON 	
<p><u>Cue</u></p>		
<p><u>Comment</u></p>		
<p>NOTE:</p>	<ol style="list-style-type: none"> 1. <i>Standard #2 is not critical.</i> 	

STEP 4 :	15. MAINTAIN PRT level at 90 to 95% for 25 to 35 minutes.	___ SAT ___ UNSAT
<u>Standard:</u>		
<u>Cue</u>	1. Tell operator that 35 minutes have elapsed. 2. Tell operator that 3-NOP-041.3 steps 16, 17, and 18 have been completed.	
<u>Comment</u>		
NOTE:		

STEP 5 :		___ SAT ___ UNSAT
<u>Standard:</u>		
<u>Cue</u>		
<u>Comment</u>		
NOTE:		

STEP 6 : √	5.5 Purging the PRT to Reduce Oxygen or Hydrogen Concentration (Major Gas Volume) (continued) 19. WHEN PRT pressure indicated on PI-3-472 has lowered to approximately 6 psig, as controlled by nitrogen supply regulator, THEN CLOSE CV-3-549, PRT VENT.	___ SAT ___ UNSAT
<u>Standard:</u>	1. Placed PRT Vent Valve, CV-3-549 switch to close. 2. Verified PRT Vent Valve, CV-3-549 Red Light OFF Green Light ON	
<u>Cue</u>	Tell operator that Chemistry informs Reactor Operator that PRT oxygen reading is less than 2 percent oxygen by volume.	
<u>Comment</u>		
NOTE:	<i>Standard #2 is not critical.</i>	

STEP 7 : √	21. WHEN Chemistry reports PRT oxygen reading less than 2% by volume, THEN: A. CLOSE CV-3-519A, PRT VENT.	___ SAT ___ UNSAT
<u>Standard:</u>	1. CV-3-519A, Primary Water to Containment Isolation switch taken to close. 2. Verified CV-3-519A Green Light ON, Red Light OFF.	
<u>Cue</u>	After standard #2 has been completed, inform the Reactor Operator that another operator will perform the remainder of the procedure.	
<u>Comment</u>		
NOTE:		
Terminating Cue:	<i>Standard #2 is not critical.</i> The task is complete when the Examinee returns the cue sheet to the examiner.	STOP

Stop Time _____

Verification of Completion

Job Performance Measure No. NRC-25-SIM-JPM-E

Examinee's Name: _____

Examiner's Name: _____

Date Performed: _____

Facility Evaluator: _____

Number of Attempts: _____

Time to Complete: _____

Question Documentation:

Question:

Response:

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

JPM BRIEFING SHEET

The examiner will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

- Chemistry reports that PRT Oxygen Concentration is 2.5% by Volume
- Unit 3 is in Mode 1 at 100% Power with no equipment out of service.
- 3-NOP-041.3, Pressurizer Relief Tank up to and including step 5.5.11 has been completed by the off-going shift
- You are the oncoming Reactor Operator and have been briefed on the evolution.
- PRT Level is at 80%.

Initiating Cue:

- You have been directed to Purge the PRT to Reduce Oxygen Concentration to within required specifications using 3-NOP-041.3, Pressurizer Relief Tank step 5.5.11.
- All prerequisites have been satisfied.
- You are continuing 3-NOP-041.3 after a turnover from the off-going shift.

Acknowledge to the examiner when you are ready to begin.

HAND THIS PAPER BACK TO YOUR EVALUATOR WHEN YOU HAVE SATISFACTORILY COMPLETED THE ASSIGNED TASK.



Facility: Turkey Point Task No: _____

Task Title: INITIATE CONTAINMENT PURGE
029 A4.01 Containment purge flow
rate 2.5/2.5 JPM No: NRC-25-SIM-JPM-F

K/A Reference: _____

Examinee: _____ NRC Examiner: _____

Facility Evaluator: _____ Date: _____

Method of testing: _____

Simulated Performance	Actual Performance	X
Classroom _____	Simulator <u>X</u> _____	Plant _____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

- UNIT 3 IS IN MODE 5 WITH ALL PURGE VALVES CLOSED.
- UNIT 3 EQUIPMENT, PERSONNEL, AND EMERGENCY HATCHES ARE CLOSED.
- UNIT 4 IS IN MODE 1 WITH ALL PURGE VALVES CLOSED AND CONTAINMENT EQUIPMENT, PERSONNEL, AND EMERGENCY HATCHES ARE CLOSED.
- ALL APPLICABLE PREREQUISITES OF 3-NOP-053 ARE SATISFIED.
- CONTAINMENT PURGE RELEASE PERMIT IS APPROVED.
- 3-NOP-053, CONTAINMENT PURGE SYSTEM IS SIGNED OFF AND COMPLETED UP TO STEP 4.1.1.11.

Task Standard:

- ISOLATION VALVES OPEN AND PURGE FANS RUNNING IN ACCORDANCE WITH 3NOP-053, CONTAINMENT PURGE SYSTEM

Required Materials:

- 3-NOP-053, CONTAINMENT PURGE SYSTEM
- APPROVED CONTAINMENT PURGE RELEASE PERMIT

General References:

- 3-NOP-053, CONTAINMENT PURGE SYSTEM

Initiating Cue:

1. A satisfactory shift turnover has been completed.
2. You have been directed to continue with Step 4.1.1.12 of 3-NOP-053, CONTAINMENT PURGE SYSTEM and perform a purge of the Unit 3 Containment.

Time Critical Task: No

Validation Time: 10 minutes

HAND JPM BRIEFING SHEET TO EXAMINEE AT THIS TIME!

SIMULATOR SETUP**Reset to IC #**

Mode 5 IC with Containment Purge Valves CLOSED and Fans OFF

Load Lesson

Ensure Simulator Operator Checklist is complete

Denote critical steps with a check mark()

Start Time _____

<p>STEP 1 : √</p>	<p>4.1.1.12 Open the following valves: 1. Containment Purge Exhaust Isol (O.C.), POV-3-2602 2. Containment Purge Exhaust Isol (I.C.), POV-3-2603</p>	<p>___ SAT ___ UNSAT</p>
<p><u>Standard:</u></p>	<p>1. Containment Purge Exhaust Isol (O.C.), POV-3-2602 switch placed to Open 2. Verified Containment Purge Exhaust Isol (O.C.), POV-3-2602 Red Light On, Green Light Off. 3. Containment Purge Exhaust Isol (I.C.), POV-3-2603 switch placed to Open 4. Verified Containment Purge Exhaust Isol (O.C.), POV-3-2603 Red Light On, Green Light Off.</p>	
<p><u>Cue</u></p>		
<p><u>Comment</u></p>		
<p>NOTE:</p>	<p><i>Standards #2 and #4 not critical</i></p>	

STEP 2 :	4.1.1.13 Prepare to open Containment Purge Supply Isolation Valves	___ SAT ___ UNSAT
<u>Standard:</u>	If both conditions are met then both Unit 3 Containment Purge Supply Valves will be open. 1. Verified Containment Doors/Hatches closed to atmosphere. 2. Verified on opposite Unit that Purge Supply Valves closed or Doors/Hatches are closed to atmosphere	
<u>Cue</u>	Repeat applicable initial conditions if asked: • UNIT 3 EQUIPMENT, PERSONNEL, AND EMERGENCY HATCHES ARE CLOSED. • UNIT 4 IS IN MODE 1 WITH ALL PURGE VALVES CLOSED AND CONTAINMENT EQUIPMENT, PERSONNEL, AND EMERGENCY HATCHES ARE CLOSED.	
<u>Comment</u>		
NOTE:	This information is covered in the Initial Conditions	

STEP 3 : √	4.1.1.13 (contd.) Open the following valves: 1. Containment Purge Supply Isol (O.C.), POV-3-2600 2. Containment Purge Supply Isol (I.C.), POV-3-2601	___ SAT ___ UNSAT
<u>Standard:</u>	1. Containment Purge Supply Isol (O.C.), POV-3-2600 switch placed to Open. 2. Verified Containment Purge Supply Isol (O.C.), POV-3-2600 Red Light On, Green Light Off. 3. Containment Purge Supply Isol (I.C.), POV-3-2601 switch placed to Open. 4. Verified Containment Purge Supply Isol (O.C.), POV-3-2601 Red Light On, Green Light Off.	
<u>Cue</u>		
<u>Comment</u>		
NOTE:	<i>Standards #2 and #4 not critical</i>	

STEP 4 : √	4.1.1.14 Start 3V20: Unit 3 Containment Purge Exhaust Fan.	___ SAT ___ UNSAT
<u>Standard:</u>	1. Control Switch Positioned to Run 2. Verified Fan Red Light On and Green Light Off 3. Verified Damper Red Light On Green Light Off	
<u>Cue</u>	If candidate attempts to have 4V20: Unit 4 Containment Purge Exhaust Fan, tell candidate that the Unit Supervisor desires the Unit 3 Fan to be started.	
<u>Comment</u>		
NOTE:	<i>Standards 2,3, and 4 are not critical</i>	

STEP 5 : √	4.1.1.15 Start 3V9: Unit 3 Containment Purge Supply Fan.	___ SAT ___ UNSAT
<u>Standard:</u>	<ol style="list-style-type: none"> 1. Verify POV-3-2600 and POV-3-2601, Containment Purge Supply Isolations are open. 2. Control Switch Positioned to Run 3. Verified Fan Red Light On and Green Light Off 4. Verified Damper Red Light On Green Light Off 5. Ensures MO-3-3421, Unit 3 Containment Purge Exhaust Damper is OPEN. 	
<u>Cue</u>	Tell candidate that another operator will complete the remainder of the procedure.	
<u>Comment</u>		
NOTE:	<i>Standards #2 and #3 not critical</i>	
Terminating Cue:	<i>The task is complete when the Examinee returns the cue sheet to the examiner.</i>	STOP
Stop Time		

Verification of Completion

Job Performance Measure No. NRC-25-SIM-JPM-F

Examinee's Name: _____

Examiner's Name: _____

Date Performed: _____

Facility Evaluator: _____

Number of Attempts: _____

Time to Complete: _____

Question Documentation:

Question:

Response:

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

JPM BRIEFING SHEET

The examiner will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

- UNIT 3 IS IN MODE 5 WITH ALL PURGE VALVES CLOSED.
- UNIT 3 EQUIPMENT, PERSONNEL, AND EMERGENCY HATCHES ARE CLOSED.
- UNIT 4 IS IN MODE 1 WITH ALL PURGE VALVES CLOSED AND CONTAINMENT EQUIPMENT, PERSONNEL, AND EMERGENCY HATCHES ARE CLOSED.
- ALL APPLICABLE PREREQUISITES OF 3-NOP-053 ARE SATISFIED.
- CONTAINMENT PURGE RELEASE PERMIT IS APPROVED.
- 3-NOP-053, CONTAINMENT PURGE SYSTEM IS SIGNED OFF AND COMPLETED UP TO STEP 4.1.1.11.

INITIATING CUE:

You have been directed to commence with Step 4.1.1.12 of 3-NOP-053, CONTAINMENT PURGE SYSTEM and perform a purge of the Unit 3 Containment.

Acknowledge to the examiner when you are ready to begin.

HAND THIS PAPER BACK TO YOUR EVALUATOR WHEN YOU HAVE SATISFACTORILY COMPLETED THE ASSIGNED TASK.



Facility:	<u>Turkey Point</u>	Task No:	_____
Task Title:	<u>Fill 3A Accumulator 006 A1.13 Accumulator pressure (level, boron concentration)3.5/3.7</u>	JPM No:	<u>NRC-25-SIM-JPM-G</u>
K/A Reference:	_____		
Examinee:	_____	NRC Examiner:	_____
Facility Evaluator:	_____	Date:	_____
Method of testing:	_____		
Simulated Performance	_____	Actual Performance	<u>X</u>
Classroom	_____	Simulator	<u>X</u>
		Plant	_____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

- 3-OP-064 Safety Injection Accumulators, Section 7.1, Adding Make-up to the Safety Injection Accumulators up to 7.1.2.2.2.a has been completed.
- 7.1.2.2.b,c, and d are marked N/A.
- It is desired to use the 3A HHSI Pump for this task

Task Standard:

- Make-up to the 3A Safety Injection Accumulator to 6600 ± 20 gallons.

Required Materials:

- 3-OP-064 Safety Injection Accumulators

General References:

- 3-OP-064 Safety Injection Accumulators

Initiating Cue:

You have been directed to raise 3A Accumulator Level to 6600 ± 20 gallons using 3A SAFETY INJECTION PUMP starting at step: 7.1.2.2.3.

- 3-OP-064 Safety Injection Accumulators, Section 7.1, Adding Make-up to the Safety Injection Accumulators up to 7.1.2.2.2.a has been completed.
- 7.1.2.2.b,c, and d are marked N/A.

Time Critical Task: NO

Validation Time: 15 minutes

HAND JPM BRIEFING SHEET TO EXAMINEE AT THIS TIME!

SIMULATOR SETUP

Reset to IC # 1

Load Lesson

- Open SI Pump 3A and 3B Test Recirc Isolation, 3-899L.
- Open SI Pump 3A Test Recirc Isolation, 3-899K.

Ensure Simulator Operator Checklist is complete

Ensure marked up copy of 3-OP-064 Safety Injection Accumulators, Section 7.1, Adding Make-up to the Safety Injection Accumulators up to 7.1.2.2.2.a has been completed. Steps 7.1.2.2.b,c, and d are marked N/A. Step 7.1.2.3 is circled.

Denote critical steps with a check mark()

Start Time _____

<p>STEP 1 : √</p>	<p>Open the Accumulator Makeup Valve for Accumulator A, CV-3-851A</p>	<p>___ SAT ___ UNSAT</p>
<p><u>Standard:</u></p>	<p>1. Placed Control Switch to Open for Accumulator A, CV-3-851A 2. Verified Red OPEN light ON 3. Verified Green CLOSED light OFF</p>	
<p><u>Cue</u></p>		
<p><u>Comment</u></p>		
<p>NOTE:</p>	<p>Standards 2 and 3 are not critical.</p>	

STEP 2 : √	Start the 3A Safety Injection Pump document the start time on QA Record Page	___ SAT ___ UNSAT
<u>Standard:</u>	1. 3A HHSI Pump Control Switch turned to START 2. 3A HHSI Pump Red Run light is ON 3. 3A HHSI Pump Green Stop light is OFF	
<u>Cue</u>		
<u>Comment</u>		
NOTE:	Standards 2 and 3 are not critical.	

STEP 3 : ✓	Open the Loop 3A and 3B Hot Leg SI Isolation, MOV-3-869 to establish flow to the accumulator.	___ SAT ___ UNSAT
<u>Standard:</u>	1. Opens the Loop 3A and 3B Hot Leg SI Isolation, MOV-3-869. 2. MOV-3-869 Red OPEN light is ON. 3. MOV-3-869 Green CLOSED light is OFF.	
<u>Cue</u>	If Operator asks for the use of another operator tell operator that the evaluator/designated operator will serve in this capacity.	
<u>Comment</u>		
NOTE:	A second operator may be utilized to operate MOV-3-869 to allow sufficient time to perform the self-checking process. Standards 2 and 3 are not critical.	

STEP 4 : √	WHEN accumulator level has increased to 6600 ± 20 gallons, THEN close Loop 3A and 3B Hot Leg SI Isolation, MOV-3-869.	___ SAT ___ UNSAT
<u>Standard:</u>	<ol style="list-style-type: none"> 1. Loop 3A and 3B Hot Leg SI Isolation, MOV-3-869 switch has been taken to CLOSE 2. Loop 3A and 3B Hot Leg SI Isolation, MOV-3-869 CLOSE Green Light is ON. 3. Loop 3A and 3B Hot Leg SI Isolation, MOV-3-869 OPEN RED Light is OFF. 	
<u>Cue</u>		
<u>Comment</u>		
NOTE:	Standards 2 and 3 are not critical.	

STEP 5 : √	Operator Stops the 3A Safety Injection Pump AND verifies the control switch is in the mid position.	___ SAT ___ UNSAT
<u>Standard:</u>	1. 3A HHSI Pump Control Switch turned to Stop and released to Mid 2. 3A HHSI Pump Red Run light is OFF 3. 3A HHSI Pump Green Stop light is ON	
<u>Cue</u>		
<u>Comment</u>		
NOTE:	Standards 2 and 3 are not Critical to this step.	

STEP 6 : √	CLOSE the Accumulator Makeup Valve for Accumulator A, CV-3-851A	___ SAT ___ UNSAT
<u>Standard:</u>	<ol style="list-style-type: none"> 1. Placed CV-3-851A Control Switch to CLOSE and released to MID 2. Verified CV-3-851A RED Open light OFF 3. Verified CV-3-851A GREEN CLOSED Light ON 	
<u>Cue</u>	Once Operator has verified CV-3-851A is CLOSED, tell the operator that the JPM is terminated.	
<u>Comment</u>		
NOTE:	Standards 2 and 3 are not Critical to this step.	
Terminating Cue:	The task is complete when the Examinee returns the cue sheet to the examiner.	STOP

Stop Time _____

Verification of Completion

Job Performance Measure No. NRC-25-SIM-JPM-G

Examinee's Name: _____

Examiner's Name: _____

Date Performed: _____

Facility Evaluator: _____

Number of Attempts: _____

Time to Complete: _____

Question Documentation:

Question:

Response:

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

JPM BRIEFING SHEET

The examiner will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

INITIAL CONDITIONS:

- 3-OP-064 Safety Injection Accumulators, Section 7.1, Adding Make-up to the Safety Injection Accumulators up to 7.1.2.2.2.a has been completed.
- 7.1.2.2.b,c, and d are marked N/A.
- It is desired to use the 3A HHSI Pump for this task

INITIATING CUE:

You have been directed to raise 3A Accumulator Level to 6600 ± 20 gallons using 3A SAFETY INJECTION PUMP starting at step: 7.1.2.2.3.

- 3-OP-064 Safety Injection Accumulators, Section 7.1, Adding Make-up to the Safety Injection Accumulators up to 7.1.2.2.2.a has been completed.
- 7.1.2.2.b,c, and d are marked N/A.

Acknowledge to the examiner when you are ready to begin.

HAND THIS PAPER BACK TO YOUR EVALUATOR WHEN YOU HAVE SATISFACTORILY COMPLETED THE ASSIGNED TASK.



Facility: Turkey Point Task No: _____

Task Title: Perform EDG Normal Start
Test (Alternate Path) JPM No: NRC-25-SIM-JPM-H
064 A2.05 Loading the ED/G
3.1/ 3.2

K/A Reference: _____

Examinee: _____ NRC Examiner: _____

Facility Evaluator: _____ Date: _____

Method of testing: Simulator

Simulated Performance _____ Actual Performance X

Classroom _____ Simulator X Plant _____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

You are the Unit 3 RCO. 3-OSP-023.1, Diesel Generator Operability Test, has been satisfactorily completed through 7.1.2.30.

Task Standard:

1. The EDG will be synchronized to the Bus in accordance with 3-OSP-023.1.
2. The EDG is placed to Emergency Stop when required.

Required Materials:

1. 3-OSP-023.1, "Diesel Generator Operability Test"

General References:

1. 3-OSP-023.1, "Diesel Generator Operability Test"

Initiating Cue:

You have been directed to continue the Monthly EDG Normal Start Test (3A EDG) starting at step 7.1.2.31. 3-OSP-023.1.

Time Critical Task: No

Validation Time: 15 minutes

HAND JPM BRIEFING SHEET TO EXAMINEE AT THIS TIME!

SIMULATOR SETUP**Reset to IC #**

Reset to IC-1.

Load Lesson

1. Open lesson JPM 01023006201.lsn and execute.
2. Ensure 3A EDG has been started and in stable operation.

Ensure Simulator Operator Checklist is complete

STEP 1 : √	Place the EDG Bkr 3AA20 Synchronizing switch to ON.	___ SAT ___ UNSAT
<u>Standard:</u>	1. Placed the EDG Bkr 3AA20 Synchronizing switch to ON. 2. Check that the WHITE synchronizing lights are cycling ON.	
<u>Cue</u>		
<u>Comment</u>		
NOTE:	<i>Standard #2 is not Critical to this step.</i>	

STEP 2 : √	Using the A Diesel Gen Volt Regulator, adjust Incoming voltage to match Running indicated voltage.	___ SAT ___ UNSAT
<u>Standard:</u>	Using the voltage adjust control switch, adjusted the generator voltage on the Bus Voltage Incoming indicator to match the voltage on the Bus Voltage Running indicator.	
<u>Cue</u>		
<u>Comment</u>		
NOTE:		

STEP 3 : √	Using the A Diesel Gen Speed Changer, adjust engine speed so that the pointer on the Synchroscope is rotating slowly in the FAST direction.	___ SAT ___ UNSAT
<u>Standard:</u>	Adjusted engine speed so that the pointer on the synchroscope is rotating slowly in the FAST direction.	
<u>Cue</u>		
<u>Comment</u>		
NOTE:		

STEP 4 : √	Using the A Diesel Gen Volt Regulator, adjust Incoming voltage slightly higher than Running voltage.	___ SAT ___ UNSAT
<u>Standard:</u>	Using the voltage adjust control switch, adjusted the generator voltage on the Bus Voltage Incoming indicator to match the voltage on the Bus Voltage Running indicator.	
<u>Cue</u>		
<u>Comment</u>		
NOTE:		

STEP 5 :	Using the A Diesel Kilovolts indicator and 3A 4KV Bus Voltmeter, verify voltages are approximately equal between the 3A Diesel Generator output and the 3A 4KV Bus for all three phases.	___ SAT ___ UNSAT
<u>Standard:</u>	Verified voltages are approximately equal.	
<u>Cue</u>		
<u>Comment</u>		
NOTE:		

STEP 6 :	Verify 3A Diesel Generator frequency is between 58.8 and 61.2 Hz on the Gen Frequency indicator	___ SAT ___ UNSAT
<u>Standard:</u>	Verified 3A Diesel Generator frequency is between 58.8 and 61.2 Hz on the Gen Frequency indicator	
<u>Cue</u>		
<u>Comment</u>		
NOTE:		

STEP 9 : √	WHEN the synchroscope pointer is at 12 o'clock position, THEN close the diesel generator breaker by placing the EDG Bkr 3AA20 Control Switch to the CLOSE position (spring return to normal).	___ SAT ___ UNSAT
<u>Standard:</u>	<ol style="list-style-type: none"> 1. Closed the diesel generator breaker by placing the EDG Bkr 3AA20 Control Switch to the CLOSE position WHEN the synchroscope pointer reached the 12 o'clock position. 2. Verified the Diesel Generator Breaker 3AA20 has closed (Breaker GREEN light is OFF and RED light is ON). 	
<u>Cue</u>		
<u>Comment</u>		
NOTE:	<i>Standard #2 is not Critical to this step.</i>	

STEP 10 : √	Place the EDG Bkr 3AA20 Synchronizing switch to OFF	___ SAT ___ UNSAT
<u>Standard:</u>	Placed the EDG Bkr 3AA20 Synchronizing switch to OFF	
<u>Cue</u>		
<u>Comment</u>		
NOTE:		

STEP 11 √	Turn the A EDG Speed Changer in the RAISE direction and slowly increase diesel generator load to approximately 1000 KW.	___ SAT ___ UNSAT
<u>Standard:</u>	<ol style="list-style-type: none"> 1. Turned the Governor Control Switch AND slowly loaded diesel generator to approximately 1000 KW. 2. Operator recognizes EDG problem and places EDG to Emergency Stop. 	
<u>Cue</u>	<ol style="list-style-type: none"> 1. If candidate asks tell candidate that vendor has cleared generator power increase to 1000 kw. 2. When the 3A EDG Voltage Regulator is taken to RAISE, SIM OPERATOR initiates a continuous increase in Voltage Regulator setting up to the point where increasing oscillations in Voltage/Load begin. 3. When Operator places EDG to Emergency Stop or EDG trips tell operator that another operator will take over. 4. Tell operator that JPM is complete. 	
<u>Comment</u>		
NOTE:		
Terminating Cue:	<i>The task is complete when the Examinee returns the cue sheet to the examiner.</i>	STOP

Stop Time _____

Verification of Completion

Job Performance Measure No. NRC-25-SIM-JPM-H

Examinee's Name: _____

Examiner's Name: _____

Date Performed: _____

Facility Evaluator: _____

Number of Attempts: _____

Time to Complete: _____

Question Documentation:

Question:

Response:

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

JPM BRIEFING SHEET

The examiner will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

INITIAL CONDITIONS:

You are the Unit 3 RCO. 3-OSP-023.1, Diesel Generator Operability Test, has been satisfactorily completed through 7.1.2.30.

INITIATING CUE:

You have been directed to continue the Monthly EDG Normal Start Test (3A EDG) starting at step 7.1.2.31, 3-OSP-023.1.

Acknowledge to the examiner when you are ready to begin.

HAND THIS PAPER BACK TO YOUR EVALUATOR WHEN YOU HAVE SATISFACTORILY COMPLETED THE ASSIGNED TASK.