ADAMS Accession No.: ML100690309

REQUESTS FOR ADDITIONAL INFORMATION

Prairie Island Nuclear Generating Plant, Units 1 and 2

License Amendment Request (LAR) dated December 28, 2009 for

Measurement Uncertainty Recapture Power Uprate

Docket Nos. 50-282 and 50-306

TAC Nos. ME3015 and ME3016

Office of Nuclear Reactor Regulation
Division of Engineering
Electrical Engineering Branch

1. Provide detailed discussion about the affects (if any) of the measurement uncertainty recapture power uprate on the plant direct current (DC) systems.

2. Provide more detailed discussion of the uprated loadings for each of the main generators with respect to their nameplate ratings. Also, provide the nameplate ratings and the uprated loadings of the generator step up transformers, plant service transformers and the main generator isolated phase bus.

DRAFT