Samp. # 41409 RWP #: 000016 ETN/STN: TP3 Turbine Building; Condemin Tank
BZA DOUG HARTMANN BZA Sample DOUG HARTMAN Printed: 04/23/09 15:21:0
Sample Start 04/23/09 at 13:30 Stop 04/23/09 at 14:30 Volume 2.40E+05 RESP.PF 100 Collect By HLDANIELS/M GILDEA
Sampler SN# 77547 Samp Cal Due 01/20/10 Alpha Cts 0 On #: Count tm 0 Beta Cts 24 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: <2.14E-10 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Hervie Daniels

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 41509 RWP #: 000016 ETN/STN: TP3 Turbine Building; Condemin Tank
GA RESIN REMOVAL 1-5 DEMIN TANK General Area Sample Printed: 04/23/09 15:24:50
Sample Start 04/23/09 at 13:30 Stop 04/23/09 at 14:30 Volume 3.60E+06 RESP.PF 1 Collect By HLDANIELS/MGILDEA
Sampler SN# 1336 Samp Cal Due 12/27/09 Alpha Cts 0 On #: Count tm 0 Beta Cts 65 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 4.08E-11 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Hervie Daniels

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 41409 RWP #: 000016 ETN/STN: TP3 Turbine Building; Condemin Tank
BZA DOUG HARTMANN,1-5 DEMIN TANK BZA Sample DOUG HARTMAN Printed: 04/23/09 15:34:4
Sample Start 04/23/09 at 13:30 Stop 04/23/09 at 14:30 Volume 2.40E+05 RESP.PF 100 Collect By HLDANIELS/M GILDEA
Sampler SN# 77547 Samp Cal Due 01/20/10 Alpha Cts 10 On #:700487 Count tm 10 Beta Cts 24 On #:700488 Count tm 1
Total DAC Frac.: 1.07E+00 Beta Conc: <2.14E-10 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Hervie Daniels

Total DAC-HRs: 1.00E-02 Alpha Conc: 5.37E-12 Alpha DACs: 1.07E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY: Hervie Daniels

Internal Dose: 0.0 mrem TOTAL DAC FRACTION > 0.3 Notify Area RPS HD

Samp. # 41509 RWP #: 000016 ETN/STN: TP3 Turbine Building; Condemin Tank
GA RESIN REMOVAL 1-5 DEMIN TANK General Area Sample Printed: 04/23/09 15:44:33
Sample Start 04/23/09 at 13:30 Stop 04/23/09 at 14:30 Volume 3.60E+06 RESP.PF 1 Collect By HLDANIELS/MGILDEA
Sampler SN# 1336 Samp Cal Due 12/27/09 Alpha Cts 156 On #:700487 Count tm 10 Beta Cts 65 On #:700488 Count tm 1
Total DAC Frac.: 1.49E+00 Beta Conc: 4.08E-11 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Hervie Daniels

Total DAC-HRs: 1.50E+00 Alpha Conc: 7.43E-12 Alpha DACs: 1.49E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY: Hervie Daniels

Internal Dose: 3.7 mrem TOTAL DAC FRACTION > 0.3 Notify Area RPS HD

FM

Samp. # 41409 RWP #: 000016 ETN/STN: TP3 Turbine Building; Condemin Tank
BZA DOUG HARTMANN,1-5 DEMIN TANK BZA Sample DOUG HARTMAN Printed: 04/23/09 22:37:0
Sample Start 04/23/09 at 13:30 Stop 04/23/09 at 14:30 Volume 2.40E+05 RESP.PF 100 Collect By HLDANIELS/M GILDEA
Sampler SN# 77547 Samp Cal Due 01/20/10 Alpha Cts 2 On #:700487 Count tm 10 Beta Cts 24 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: <2.14E-10 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Hervie Daniels

Total DAC-HRs: 0.00E+00 Alpha Conc:<4.23E-12 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY: Kevin Nally

Internal Dose: 0.0 mrem

Samp. # 41509 RWP #: 000016 ETN/STN: TP3 Turbine Building; Condemin Tank
GA RESIN REMOVAL 1-5 DEMIN TANK General Area Sample Printed: 04/23/09 22:39:47
Sample Start 04/23/09 at 13:30 Stop 04/23/09 at 14:30 Volume 3.60E+06 RESP.PF 1 Collect By HLDANIELS/MGILDEA
Sampler SN# 1336 Samp Cal Due 12/27/09 Alpha Cts 4 On #:78465 Count tm 10 Beta Cts 65 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 4.08E-11 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Hervie Daniels

Total DAC-HRs: 0.00E+00 Alpha Conc:<2.60E-13 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY: Kevin Nally

Internal Dose: 0.0 mrem