Samp. # 41909 RWP #: 000100 ETN/STN: TC2 Turbine Building; Heater Bay
ENTRY TO T/O FEED STRING BZA Sample KEVIN NALLY Printed: 04/26/09 02:08:0
Sample Start 04/25/09 at 23:00 Stop 04/25/09 at 23:40 Volume 1.60E+05 RESP.PF 1 Collect By NALLY,K
Sampler SN# 77547 Samp Cal Due 11/20/10 Alpha Cts 0 On #: Count tm 0 Beta Cts 21 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: <3.20E-10 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 42009 RWP #: 000100 ETN/STN: CAA Yard; Cond. Transfer House
N. OF PUMP HOUSE @TRENCH General Area Sample Printed: 04/26/09 02:10:57
Sample Start 04/25/09 at 5:20 Stop 04/25/09 at 20:20 Volume 3.60E+06 RESP.PF 1 Collect By RICHWINE,J
Sampler SN# 75154 Samp Cal Due 07/22/09 Alpha Cts 0 On #: Count tm 0 Beta Cts 22 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: <1.42E-11 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 42109 RWP #: 000100 ETN/STN: TO2 Turbine Building; Operating Floo
AMS3 A/S General Area Sample Printed: 04/26/09 03:06:10
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 2:00 Volume 5.98E+08 RESP.PF 1 Collect By NAUGHTON,M
Sampler SN# 120 Samp Cal Due 12/09/09 Alpha Cts 0 On #: Count tm 0 Beta Cts 265 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 1.36E-12 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 42209 RWP #: 000100 ETN/STN: TE2 Turbine Building; Spare Exciter
LO VOL A/S-ROUTINE General Area Sample Printed: 04/26/09 03:08:48
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 2:15 Volume 2.19E+08 RESP.PF 1 Collect By NAUGHTON,M
Sampler SN# 70249 Samp Cal Due 07/30/09 Alpha Cts 0 On #: Count tm 0 Beta Cts 113 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 1.40E-12 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 42309 RWP #: 000100 ETN/STN: TP2 Turbine Building; Condemin Contr
AMS3 A/S General Area Sample Printed: 04/26/09 03:11:23
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 2:20 Volume 5.99E+08 RESP.PF 1 Collect By NAUGHTON,M
Sampler SN# 70198 Samp Cal Due 07/03/09 Alpha Cts 0 On #: Count tm 0 Beta Cts 138 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 6.52E-13 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

F-66

Samp. # 42409 RWP #: 000100 ETN/STN: TPE Turbine Building; Condemin Region
AMS3 A/S General Area Sample Printed: 04/26/09 03:13:22
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 2:30 Volume 5.99E+08 RESP.PF 1 Collect By NAUGHTON,M
Sampler SN# 70195 Samp Cal Due 07/03/09 Alpha Cts 0 On #: Count tm 0 Beta Cts 180 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 8.85E-13 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 42509 RWP #: 000100 ETN/STN: TF2 Turbine Building; Feedpump Room
AMS3 A/S General Area Sample Printed: 04/26/09 03:15:30
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 2:50 Volume 6.01E+08 RESP.PF 1 Collect By NAUGHTON,M
Sampler SN# 70195 Samp Cal Due 04/14/10 Alpha Cts 0 On #: Count tm 0 Beta Cts 116 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 5.28E-13 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 42609 RWP #: 000100 ETN/STN: YRA New Maintenance Building; genera
RESP MAINT. AMS3 A/S General Area Sample Printed: 04/26/09 06:23:01
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 4:20 Volume 6.06E+08 RESP.PF 1 Collect By DIMOS,M
Sampler SN# 12A Samp Cal Due 07/25/09 Alpha Cts 0 On #: Count tm 0 Beta Cts 178 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 8.65E-13 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 42709 RWP #: 000100 ETN/STN: N3A New Rad Waste; 23 foot level
O/S FILL AISLE AMS3 A/S General Area Sample Printed: 04/26/09 06:25:07
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 3:45 Volume 6.04E+08 RESP.PF 1 Collect By DIMOS,M
Sampler SN# 70182 Samp Cal Due 04/02/10 Alpha Cts 0 On #: Count tm 0 Beta Cts 44 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 1.27E-13 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 42809 RWP #: 000100 ETN/STN: N4Q New Rad Waste; 38 foot level
AMS3 A/S General Area Sample Printed: 04/26/09 06:26:59
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 3:30 Volume 6.03E+08 RESP.PF 1 Collect By DIMOS,M
Sampler SN# 70238 Samp Cal Due 03/04/10 Alpha Cts 0 On #: Count tm 0 Beta Cts 59 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 2.11E-13 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 42909 RWP #: 000100 ETN/STN: WAA Yard; LLRWSF
LOWER LEVEL AMS3 A/S General Area Sample Printed: 04/26/09 06:29:35

Samp. # 42909 RWP #: 000100 ETN/STN: WAA Yard; LLRWSF
LOWER LEVEL AMS3 A/S General Area Sample Printed: 04/26/09 06:29:35
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 3:50 Volume 6.01E+00 RESP.PF 1 Collect By DINOS,M
Sampler SN# 70195 Samp Cal Due 10/17/09 Alpha Cts 0 On #: Count tm 0 Beta Cts 105 On #:700438 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 1.02E-12 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 43009 RWP #: 000100 ETN/STN: WAA Yard; LLRWSF
UPPER LEVEL AMS3 A/S General Area Sample Printed: 04/26/09 06:31:30
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 3:50 Volume 6.01E+00 RESP.PF 1 Collect By DINOS,M
Sampler SN# 70191 Samp Cal Due 09/30/09 Alpha Cts 0 On #: Count tm 0 Beta Cts 192 On #:700439 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 7.84E-13 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 43109 RWP #: 000100 ETN/STN: RDM Reactor Building; 38 foot level
TIP DRIVE AMS2 A/S General Area Sample Printed: 04/26/09 06:34:06
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 3:20 Volume 6.00E+00 RESP.PF 1 Collect By DINOS,M
Sampler SN# 1309 Samp Cal Due 10/01/09 Alpha Cts 0 On #: Count tm 0 Beta Cts 43 On #:700440 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 1.55E-13 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 43209 RWP #: 000100 ETN/STN: N48 New Rad Waste; 48 foot level
AMS3 A/S General Area Sample Printed: 04/26/09 06:35:56
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 13:40 Volume 6.40E+00 RESP.PF 1 Collect By DINOS,M
Sampler SN# 71940 Samp Cal Due 12/10/09 Alpha Cts 0 On #: Count tm 0 Beta Cts 53 On #:700469 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 1.67E-13 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 43309 RWP #: 000100 ETN/STN: AYF AOG; 23 foot level
AMS3 A/S General Area Sample Printed: 04/26/09 06:37:41
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 4:00 Volume 6.05E+00 RESP.PF 1 Collect By DINOS,M
Sampler SN# 71960 Samp Cal Due 12/06/09 Alpha Cts 0 On #: Count tm 0 Beta Cts 68 On #:700459 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 2.16E-13 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 43409 RWP #: 000100 ETN/STN: A2C AOG; 38 foot level

Samp. # 43409 RWP #: 000100 ETN/STN: AZC AOG; 38 foot level
AMS3 A/S General Area Sample Printed: 04/26/09 06:39:22
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 4:05 Volume 6.05E+08 RESP.PF 1 Collect By DIMOS,M
Sampler SN# 062 Samp Cal Due 12/08/09 Alpha Cts 0 On #: Count tm 0 Beta Cts 41 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 1.11E-13 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 43509 RWP #: 000100 ETN/STN: DAA New Maintenance Building; genera
CHEM LAB AMS3 A/S General Area Sample Printed: 04/26/09 06:41:53
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 4:40 Volume 6.07E+08 RESP.PF 1 Collect By DIMOS,M
Sampler SN# 686 Samp Cal Due 02/24/10 Alpha Cts 0 On #: Count tm 0 Beta Cts 72 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 2.81E-13 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 43609 RWP #: 000100 ETN/STN: RGU Reactor Building; 95 foot level
AMS3 A/S General Area Sample Printed: 04/26/09 06:43:47
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 4:55 Volume 6.03E+08 RESP.PF 1 Collect By DIMOS,M
Sampler SN# 71901 Samp Cal Due 02/24/10 Alpha Cts 0 On #: Count tm 0 Beta Cts 114 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 5.11E-13 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 43709 RWP #: 000100 ETN/STN: REY Reactor Building; 51 foot level
AMS3 A/S General Area Sample Printed: 04/26/09 06:45:34
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 4:45 Volume 6.08E+08 RESP.PF 1 Collect By DIMOS,M
Sampler SN# 71906 Samp Cal Due 12/10/09 Alpha Cts 0 On #: Count tm 0 Beta Cts 39 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 9.90E-14 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 43809 RWP #: 000100 ETN/STN: MAA New Maintenance Building; Hot Ma
AMS3 A/S General Area Sample Printed: 04/26/09 06:47:07
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 4:30 Volume 6.07E+08 RESP.PF 1 Collect By DIMOS,M
Sampler SN# 71972 Samp Cal Due 02/24/10 Alpha Cts 0 On #: Count tm 0 Beta Cts 176 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 8.53E-13 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 43909 RWP #: 000100 ETN/STN: RHX Reactor Building; 119 foot level

Internal Dose: 0.0 mrem

Samp. # 43909 RWP #: 000100 ETN/STN: RHX Reactor Building; 119 foot level
AMS3 A/S General Area Sample Printed: 04/26/09 06:48:40
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 5:05 Volume 6.09E+08 RESP.PF 1 Collect By DIMOS,M
Sampler SN# 71959 Samp Cal Due 03/31/10 Alpha Cts 0 On #: Count tm 0 Beta Cts 111 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 4.94E-13 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem

Samp. # 44009 RWP #: 000100 ETN/STN: RFQ Reactor Building; 75 foot level
AMS3 A/S General Area Sample Printed: 04/26/09 06:49:57
Sample Start 04/19/09 at 4:00 Stop 04/26/09 at 5:10 Volume 6.09E+08 RESP.PF 1 Collect By DIMOS,M
Sampler SN# 617 Samp Cal Due 02/20/10 Alpha Cts 0 On #: Count tm 0 Beta Cts 118 On #:700488 Count tm 1
Total DAC Frac.: 0.00E+00 Beta Conc: 5.32E-13 Beta DACs: 0.00E+00 Gamma Part DACs: 0.00E+00 BETA COUNT BY: Martin Naughton

Total DAC-HRs: 0.00E+00 Alpha Conc: 0.00E+00 Alpha DACs: 0.00E+00 Gamma Char DACs: 0.00E+00 ALPHA COUNT BY:

Internal Dose: 0.0 mrem