

## PMVogtleCOLPEm Resource

---

**From:** Simms, Tanya  
**Sent:** Monday, March 15, 2010 4:29 PM  
**To:** PMVogtleCOLPEm Resource  
**Cc:** Joshi, Ravindra  
**Subject:** Telcon Summary - Telcon with Vogtle 3/11/10

On March 11, 2010 NRC staff (Tanya Simms, Gordon Curran, and John Segala ) participated in a telephone conference call with Vogtle representatives and observers (see below) regarding the staff's detailed review of the Vogtle Units 3 and 4 COL application. The purpose of the call was to discuss the possible need to issue a requests for additional information (RAI).

The discussion focused on addressing COL Information Item 9.2.11.2 regarding the waste water retention basin and ensuring potentially radioactive effluents draining to the water basin will be monitored prior to disposition as reviewed in FSAR chapter 9, Section 9.2.9.

At the conclusion of the call, Vogtle requested an RAI be issued detailing the information staff requested to ensure the response is addressed correctly.

SNC reps  
Amy Aughtman  
Fred Mizell  
William Smith  
Phil Moore  
John Prebula  
Bob Prunty  
Mike Bronson  
Jim Hesler  
Bruce Kobel

DCWG reps  
Bob Hirmanpour  
Eddie Grant  
Chase Thomas  
Bob Mohr  
Bobby Dean  
Mary Shipley  
Ray Burski

**Hearing Identifier:** Vogtle\_COL\_Public  
**Email Number:** 427

**Mail Envelope Properties** (192BB59294514E41B5305C3C8286760809C916F703)

**Subject:** Telcon Summary - Telcon with Vogtle 3/11/10  
**Sent Date:** 3/15/2010 4:29:14 PM  
**Received Date:** 3/15/2010 4:29:17 PM  
**From:** Simms, Tanya

**Created By:** Tanya.Simms@nrc.gov

**Recipients:**

"Joshi, Ravindra" <Ravindra.Joshi@nrc.gov>

Tracking Status: None

"PMVogtleCOLPEm Resource" <PMVogtleCOLPEm.Resource@nrc.gov>

Tracking Status: None

**Post Office:** HQCLSTR02.nrc.gov

| <b>Files</b> | <b>Size</b> | <b>Date &amp; Time</b> |
|--------------|-------------|------------------------|
| MESSAGE      | 1105        | 3/15/2010 4:29:17 PM   |

**Options**

**Priority:** Standard

**Return Notification:** No

**Reply Requested:** Yes

**Sensitivity:** Normal

**Expiration Date:**

**Recipients Received:**