



plant status daily archives enter daily plant status safety meeting information branch chief reports focus items pita search guid

Crystal River Information for 10/08/2009 (Modify/Update)

Unit 3 status: (no commas, please)
 Mode 6; GREEN

RCS Leak:

9:15 mtg. Yes No

Routine Activities / TS Activities:

Significant TS / Issues:

9:15 mtg. Yes No [add attachment](#)

Risk Significant / Emergent Activities:

The plant is in mode 6, green risk. Reactor head is removed and the water level is 158 feet (23 feet above RV flange) and 99F. Fuel in vessel with time to boil at 404 minutes. The equipment hatch is open. Defueling started last night and thirty assemblies have been removed. Offload scheduled to be completed by 23:00 on 10/9.

Containment Hydro-demolition of concrete was completed. Licensee planning to perform a modification to support outside lift system as a result of cracks identified in concrete. A root cause investigation is in progress. Sargent and Lundy is involved with the investigation and corrective actions. An NRC/Licensee conference call to discuss the containment issues and licensee actions is scheduled for today at 15:00.

Yesterday the licensee made a voluntary notification to NRC to describe containment concrete issues.

9:15 mtg. Yes No

| delete | delete | delete
 100_0081.jpg 100_0082.jpg 100_0083.jpg

[add attachment](#)

Findings and Observations:

9:15 mtg. Yes No

AHB

Site Visits:

A. Alen onsite for 5 week training rotation.
R. Chou is onsite with his SGR team.
Chairman visit planned for October 9th.

9:15 mtg. Yes No 

[add attachment](#)

Other:

No significant findigs with chou inspection
Site coverage provided by both residents for the weekend.

9:15 mtg. Yes No 

[add attachment](#)

Last updated: 10/08/2009 | 8:59 AM