

plant status daily
archives

enter daily plant status

safety meeting
information

branch chief reports

focus items

pita search

guid

Crystal River Information for 10/09/2009 (Modify/Update)

Unit 3 status: (no commas, please)

Mode 6; GREEN

RCS Leak:

9:15 mtg. ☐ Yes ☒ No

Routine Activities / TS Activities:

Significant TS / Issues:

9:15 mtg. ☐ Yes ☒ No ☒[add attachment](#)

Risk Significant / Emergent Activities:

The plant is in mode 6, green risk. The equipment hatch is open. Water temperature is 99F, time to boil at 2064 minutes. Defueling is in progress and is 90% complete. Full core off load completion is scheduled for this afternoon.

An NRC/Licensee conference call was held yesterday to discuss the containment issues and licensee actions. A special inspection is planned to start next week.

9:15 mtg. ☐ Yes ☒ No ☒[add attachment](#)

Findings and Observations:

9:15 mtg. ☐ Yes ☒ No

Site Visits:

A. Alen onsite for 5 week training rotation.
R. Chou is onsite with his SGR team.
Chairman and Luis Reyes site visit planned for today.


9:15 mtg. ☐ Yes ☒ No ☒[add attachment](#)

A-6D

Other:

No significant findings with chow inspection

Site coverage provided by both residents for the weekend.

9:15 mtg. ☐ Yes ☒ No 

[add attachment](#)

[Update](#)

Last updated: 10/09/2009 | 7:19 AM