PMVogtleCOLPEm Resource

From: Simms, Tanya
Sent: Tuesday, March 16, 2010 1:54 PM
To: 'wasparkm@southernco.com'; 'AGAUGHTM@SOUTHERNCO.COM'; Bob Hirmanpour; Eddie R Grant - EXCEL Services
Cc: PMVogtleCOLPEm Resource; Joshi, Ravindra
Subject: RAI Letter No. 050 Related to SRP Section 9.3.3 for Vogtle Units 3 and 4
Attachments: VOG-RAI-LTR-050.pdf

To All,

Attached is RAI Letter No. 050 Related to SRP Section 9.3.3 for Vogtle Units 3 and 4. The ADAMS accession numbers are ML100750300.

Tanya Simms
Project Manager
New Reactor Licensing
U.S. Nuclear Regulatory Commission
11555 Rockville Pike
Rockville, Maryland 20852-2738
301-415-1387
Tanya.Simms@nrc.gov

Hearing Identifier: Vogtle_COL_Public
Email Number: 431

Mail Envelope Properties (192BB59294514E41B5305C3C8286760809C916F9C5)

Subject: RAI Letter No. 050 Related to SRP Section 9.3.3 for Vogtle Units 3 and 4
Sent Date: 3/16/2010 1:54:11 PM
Received Date: 3/16/2010 1:54:12 PM
From: Simms, Tanya

Created By: Tanya.Simms@nrc.gov

Recipients:
"PMVogtleCOLPEm Resource" <PMVogtleCOLPEm.Resource@nrc.gov>
Tracking Status: None
"Joshi, Ravindra" <Ravindra.Joshi@nrc.gov>
Tracking Status: None
"'wasparkm@southernco.com'" <wasparkm@southernco.com>
Tracking Status: None
"'AGAUGHTM@SOUTHERNCO.COM'" <AGAUGHTM@SOUTHERNCO.COM>
Tracking Status: None
"Bob Hirmanpour" <bob.hirmanpour@excelservices.com>
Tracking Status: None
"Eddie R Grant - EXCEL Services" <Eddie.Grant@EXCELServices.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	**Size**	**Date & Time**
MESSAGE	418	3/16/2010 1:54:12 PM
VOG-RAI-LTR-050.pdf	127503	

Options
Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received:

VogtlecolRAIsPEm Resource

From: Simms, Tanya
Sent: Tuesday, March 16, 2010 12:11 PM
To: VogtlecolRAIsPEm Resource
Subject: Request for Additional Information Letter No. 050 Related to SRP Section 09.03.03 for the Vogtle Units 3 and 4 Combined License Application
Attachments: VOG-RAI-LTR-050.doc

Hearing Identifier: Vogtle_COL_eRAIs
Email Number: 52

Mail Envelope Properties (192BB59294514E41B5305C3C8286760809C916F92A)

Subject: Request for Additional Information Letter No. 050 Related to SRP Section 09.03.03 for the Vogtle Units 3 and 4 Combined License Application
Sent Date: 3/16/2010 12:10:58 PM
Received Date: 3/16/2010 12:10:59 PM
From: Simms, Tanya

Created By: Tanya.Simms@nrc.gov

Recipients:
"VogtlecolRAIsPEm Resource" <VogtlecolRAIsPEm.Resource@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	**Size**	**Date & Time**
MESSAGE	3	3/16/2010 12:10:59 PM
VOG-RAI-LTR-050.doc	53242	

Options
Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received:

March 16, 2010

Mr. Joseph A. (Buzz) Miller
Senior Vice President
Southern Nuclear Operating Company
P.O. Box 1295
Birmingham, AL 35201

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 050 RELATED TO SRP SECTION 09.03.03 FOR THE VOGTLE ELECTRIC GENERATING PLANT UNITS 3 AND 4 COMBINED LICENSE APPLICATION

Dear Mr. Miller:

By letter dated March 28, 2008, Southern Nuclear Operating Company (SNC), submitted its application to the U. S. Nuclear Regulatory Commission (NRC) for a combined license (COL) for two AP1000 advance passive pressurized water reactors pursuant to 10 CFR Part 52. The NRC staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

To support the review schedule, you are requested to respond within 30 days of the date of this letter. If changes are needed to the final safety analysis report, the staff requests that the RAI response include the proposed wording changes.

If you have any questions or comments concerning this matter, you may contact me at 301-415-1387 or you may contact Ravindra Joshi, the lead project manager for the Vogtle Electric Generating Plan combined license at 301-415-6191.

Sincerely,

/**RA**/

Tanya Simms, Project Manager
AP1000 Projects Branch 1
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-025
52-026

Enclosure:
Request for Additional Information

CC: see next page

If you have any questions or comments concerning this matter, you may contact me at 301-415-1387 or you may contact Ravindra Joshi, the lead project manager for the Vogtle Electric Generating Plan combined license at 301-415-6191.

Sincerely,

/**RA**/

Tanya Simms, Project Manager
AP1000 Projects Branch 1
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-025
52-026
eRAI Tracking No. 4497

Enclosure:
Request for Additional Information

Distribution:

Public	AHodgdon	BHughes
RidsNroDnrlNwe1	MSpencer	MComar
RidsNroLAKGoldstein	TSimms	GCurran
RidsOgcMailCenter	BAnderson	RJoshi
SGoetz	TSpicher	JSegala
RidsRgn2MailCenter	RidsAcrsAcnwMailCenter	RidsNroDnrlNwe2

NRO-002

OFFICE	SBPA/BC	NWE1/PM	NWE1/L-PM
NAME	JSegala*	TSimms*	RJoshi*
DATE	3/12/10	3/12/10	3/16/10

*Approval captured electronically in the electronic RAI system.

OFFICIAL RECORD COPY

Request for Additional Information No. 4497 Revision 0
Vogtle
Southern Nuclear Operating Co.
Docket No. 52-0025 and 52-0026
SRP Section: 09.03.03 - Equipment and Floor Drainage System
Application Section: Section 9.2.9

QUESTION from Balance of Plant Branch 1 (SBPA)

09.03.03-1

In AP1000 DCD, Revision 15, the waste water retention basin design features were included as part of the AP1000 certified design. In Revision 16, Westinghouse removed the waste water retention basin from the DCD and identified it as COL Information Item 9.2.11.2, “Waste Water Retention Basins.” COL Information Item 9.2.11.2 states that "the Combined License applicant will address the final design and configuration of the plant waste water retention basins and associated discharge piping, including piping design pressure, basin transfer pump size, basin size, and location of the retention basins."

In Vogtle FSAR Section 9.2.9.2.2, “Component Description,” a description of the wastewater retention basin was added to address AP1000 DCD COL Information Item 9.2.11.2. The information provided discusses the location and routing of the wastewater system, but does not address all of the details requested in the COL information item.

In order to meet GDC 60, applicant should demonstrate suitable control of the release of radioactive materials in liquid effluent. Provide a discussion on whether all site-specific potentially radioactive effluents draining into and downstream of the water basin will be monitored prior to disposition. Provide justification for not providing water level instrumentation and radiation monitoring in the wastewater retention basin and blowdown sump.

Also, provide additional details on the method proposed for transfer of inventory from wastewater settling basin to the discharge canal and provide a description of the associated components (ie. transfer pumps, size of basin, basin lining, etc…) as requested in the COL information item. Verify that all site-specific potentially radioactive effluents will be monitored prior to disposition. Or provide a justification for why this information is not necessary. Update FSAR accordingly.