

TELEPHONE CONVERSATION RECORD		Date: May 1, 2002	Time: 9:18
Mail Control No.: 022192		License No.: 20-15285-03E	Docket No.: 030-32498
Person Called: Chris Mousseau & Bill Sawyer, RSO		Organization: Kidde-Fenwal, Inc.	Telephone Number: (508)881-2000x2641 or x2746
Person Calling: Anthony S. Kirkwood			
Subject: 1/24/02, RAI on Renewal request dated 8/22/2001 (Received 10/01/01)			
<p>Summary: Asked Mr. Mousseau whether the reply to our 1/24/02, RAI was on the way since the 30 day response time has past. He said he thought it was, but would also check with Bill Sawyer to be sure. I gave him my fax number and email address. I told him I also left the same message on Bill Sawyer's voice mail.</p> <p><u>Questions that need to be addressed are:</u> 1) If Models CPD-702X & 704X contain dual ion chambers then the activity on the license needs to be increased (1.5 x 2 = 3 uCi) 2) Is the Model CPD-705X a dual chamber device (0.6 x 2 = 1.2 uCi)? 3) Has the Model CPD-705X been manufactured other than in Japan, contrary to the registry sheet (NR-0668-D-101-E, 4/27/92)? 4) What device uses the 0.6 uCi ion chamber and what device uses the 2.5 uCi ion chamber as indicated in the 8/22/01, renewal application?</p> <p>ASKirkwood ASK</p>			
Action Required/Taken: Copy to file.			
Signature: /RA/		Date: 02/26/2002	

B-18