

From: Jonathan Rivera
To: Terrill.Garland@kidde-fenwal.com
Date: 4/11/05 1:38PM
Subject: Re: SSD review for new Model No. 7054, Certificate No. NR-668-D-101-E

Terry,

Thank you for the information.

Per our phone conversation last week, regarding the addition of a new model designation for the same smoke detector device to the exempt distribution license and SSD certificate, please provide the following information. An email response would be sufficient:

1. The exact model designation that will be used, including any spaces or dashes.
2. A description of the differences between Model No. CPD-7054 and the new model to be added.
3. An explanation of how the information submitted as part of the original application for Model No. CPD-7054 would apply to the new model.
4. An explanation of how the device labels will differentiate between Model No. CPD-7054 and the new model.

If you have any questions, please feel free to contact me.

Jonathan Rivera
Materials Safety & Inspection Branch
U.S. Nuclear Regulatory Commission
Phone: (301) 415-5810
Email: jxr4@nrc.gov

>>> <Terrill.Garland@kidde-fenwal.com> 04/11/05 10:34AM >>>

Jonathan,

I received the following remaining information from our manufacturer in Japan, concerning the JRIA test:

Type: S-1371A
Window Thickness: 100 micro meter (beryllium window)
Sensitivity: Counting Efficiency 24%
Condition: At ordinary room temperature (25C 50% Relative Humidity)

I believe this answers all of the remaining questions you had asked, concerning the SSD review for our Models CPD-7054 and CPD-7054D.

Please let me know if there is any additional info. you need from me to complete this review.

Regards,

Terry Garland

B-40

Manager, D&A Project Development
Kidde-Fenwal, Inc.

Tel: (508) 881-2000 Ext. 2364

Fax: (508) 231-2015

e-mail: Terrill.Garland@kidde-fenwal.com

The information contained in this message or any of its attachments may be privileged and confidential and intended for the exclusive use of the addressee. Any views or opinions expressed in this e-mail are those of the individual and not necessarily of Kidde plc. If you are not the intended recipient, any disclosure, reproduction, distribution or other dissemination or use of this communications is strictly prohibited. If you have received this transmission in error, please contact the IT Help Desk on +44 (0) 1753 766380.

CC: Anthony Kirkwood; John Jankovich

Mail Envelope Properties (425AB62C.55C : 18 : 20473)

Subject: Re: SSD review for new Model No. 7054, Certificate No.
NR-668-D-101-E

Creation Date: 4/11/05 1:38PM

From: Jonathan Rivera

Created By: JXR4@nrc.gov

Recipients	Action	Date & Time
kidde-fenwal.com Terrill.Garland (Terrill.Garland@kidde-fe	Transferred	04/11/05 01:38PM
nrc.gov twf4_po.TWFN_DO ASK CC (Anthony Kirkwood)	Delivered Opened	04/11/05 01:38PM 04/11/05 01:39PM
JPJ2 CC (John Jankovich)	Opened	04/11/05 01:39PM
JXR4 BC (Jonathan Rivera)	Opened	04/11/05 01:38PM

Post Office	Delivered	Route
twf4_po.TWFN_DO	04/11/05 01:38PM	kidde-fenwal.com nrc.gov

Files	Size	Date & Time
MESSAGE	4842	04/11/05 01:38PM

Options

Auto Delete: No

Expiration Date: None

Notify Recipients: Yes

Priority: Standard

Reply Requested: No

Return Notification: None

Concealed Subject: No

Security: Standard

To Be Delivered: Immediate

Status Tracking: Delivered & Opened