

Ayala, Juan

From: Moore, Ross
Sent: Wednesday, November 25, 2009 8:51 AM
To: Montgomery, Richard; Kern, Ludwig
Subject: FW: PNO-I-09-006: Three Mile Island Unit 1 - Contamination Event (Update)
Attachments: PNO-I-09-006 - TMI Contamination Event.doc

A very fancy way of saying that somebody is going to the bathroom. See paragraph 3 in the subject section.

"The number of personnel with residual contamination continued to decrease as normal biological elimination processes of internally deposited radioactivity takes place."

From: Thompson, Margaret
Sent: Tuesday, November 24, 2009 4:28 PM
To: R1-DL-PN; PN_Distribution
Subject: PNO-I-09-006: Three Mile Island Unit 1 - Contamination Event (Update)

To All:

Attached is Preliminary Notification for Three Mile Island, Unit 1

ADAMS: ML093280879

Exelon Generation Company, LLC
Three Mile Island, Unit 1
Middletown, PA
Docket: 50-289

SUBJECT: PNO-I-09-006: Three Mile Island Unit 1 - Contamination Event (Update)

72
B/75

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-I-09-006

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

<u>Facility</u>	<u>Licensee Emergency Classification</u>
Exelon Generation Company, LLC	<input type="checkbox"/> Notification of Unusual Event
Three Mile Island, Unit 1	<input type="checkbox"/> Alert
Middletown, PA	<input type="checkbox"/> Site Area Emergency
Docket: 50-289	<input type="checkbox"/> General Emergency
	<input checked="" type="checkbox"/> Not Applicable

SUBJECT: THREE MILE ISLAND UNIT 1 CONTAMINATION EVENT (UPDATE)

This preliminary notification updates information previously communicated in a commissioner's technical assistant briefing, NRC Event Notification (EN 45514) and NRC Press Release (No. I 09-046).

At about 4:00 p.m., on November 21, while shut down for a refueling outage and steam generator (SG) replacement, TMI experienced local alarms inside the containment building due to airborne radioactivity levels.

As a precaution in response to the alarms, approximately 175 workers exited the containment. Several workers alarmed the portal monitors while leaving the radiologically controlled area around the containment building due to contamination levels, and were whole body counted to assess their radiation dose. Of these workers, initially 19 workers received doses ranging from 10 mrem to 38 mrem, which is a very small fraction of the annual federal occupational exposure limit (5000 mrem/yr). The number of personnel with residual contamination continued to decrease as normal biological elimination processes of internally deposited radioactivity takes place. It is not unusual for contamination events to occur during refueling outages and workers to be processed as they were in this event.

Exelon attributed the cause of the contamination event to a change in air pressure inside the containment building that dislodged loose surface contamination in primary piping systems. Some of the contamination became airborne and was detected by local containment air monitors. Exelon surveyed the area around the containment construction opening and did not detect any contamination. The airborne radioactivity readings returned to pre-event levels 4 to 6 hours after the initial alarms.

There was no effect on public health and safety as a result of this event. This event did not result in exceeding any emergency action levels, nor were any formal event notification criteria met. The workers that were affected by this event received radiation doses that were a small percentage of the annual occupational exposure limit. As a conservative measure, Exelon withheld these workers from future exposure pending detailed evaluation.

A number of Region I personnel and Headquarters personnel have responded to this event over the weekend. The Resident Inspectors, Health Physics Specialist Inspectors, and the Public Affairs Officer responded to the site to investigate the event and to address media inquiries. Exelon issued two press releases, and the NRC issued one press release on the event. The Region I Public Affairs Officers have responded to numerous media inquiries. Region I is

DISTRIBUTION: (by email)

Chairman Jazcko
Comm. Klein
Comm. Svinicki
OIP
OCA
OGC
OPA
EDO
OE
NRR
SECY
IRO
NMSS
ACRS
OIG
RES
NSIR
NRO
PDR
RSLO
Regional Offices

By Fax:

DOT:Trans
INPO
NSAC
RI Resident Office

Licensee: Exelon Generation Company LLC
Three Mile Island, Unit 1

ADAMS Accession Number: **ML093280879**

SUNSI Review Complete: GSB (Reviewer's Initials)

DOCUMENT NAME: G:\DRP\PNs\PNO-I-09-006 - TMI Contamination Event.doc

After declaring this document "An Official Agency Record" it **will** be released to the Public.

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure, "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RI/DRP	RI/SLO	RI/PAO	RI/DRP	RI/ORA
NAME	SBarber/GSB	DTiff/DT	DScrenci/DS	JClifford/JWC	SCollins/SJC
DATE	11/24/09	11/24/09	11/24/09	11/24/09	11/24/09

OFFICIAL RECORD COPY