

17

Cartwright, William

From: Brown, Michael
Sent: Monday, December 21, 2009 10:17 AM
To: Brown, Michael; Haskell, Russell; Beltz, Terry; Bernardo, Robert; Boyle, Patrick; Chapman, Travis; Craffey, Ryan; Criscione, Lawrence; DeMarshall, Joseph; Dority, Dayna; Garmon-Candelaria, David; Gaslevic, James; Giantelli, Joseph; Goldfeiz, Eliezer; Gray, Kathy; Jardaneh, Mahmoud; Jennings, Jason; Kauffman, John; King, Mark; Klee, Edmund; LaVera, Ronald; Le, Hien; Pannier, Stephen; Reisifard, Mehdi; Robles, Jesse; Scully, Derek; Sigmon, Rebecca; Tabatabai, Omid; Thomas, Eric; Thorp, John; Vaughn, Stephen; Webb, Michael; Wegner, Mary
Subject: Region I Morning Call Notes for Monday, December 21, 2009
Attachments: Attachment 1 - Radiation Found Outside TMI.pdf; Millstone3 Electrical.PNG

INFORMATION SENSITIVITY CAUTION -- This e-mail contains preliminary, pre-decisional information and notes gathered in the Region Morning Call discussions. It may also contain proprietary information or photographs. It is restricted to NRC internal use only by Clearinghouse screening meeting participants and is NOT to be distributed further nor used for management decisions. Information from these notes that has been screened by the team may appear in the daily IOEB OpE Screening Summary e-mail, which can be subscribed to by anyone in NRC via the "Reactor OpE Information Gateway" link on the NRR home webpage.

Event Notifications: Two (2)

EN 45514 - RADIATION RELEASE IN CONTAINMENT ASSOCIATED WITH STEAM GENERATOR REMOVAL (Recommend Screen Out)

Power Reactor	Event Number: 45514
Facility: THREE MILE ISLAND Region: 1 State: PA Unit: [1] [] [] RX Type: [1] B&W-L-LP, [2] B&W-L-LP NRC Notified By: ROGER BARNES HQ OPS Officer: BILL HUFFMAN	Notification Date: 11/22/2009 Notification Time: 01:13 [ET] Event Date: 11/21/2009 Event Time: 22:45 [EST] Last Update Date: 12/18/2009
Emergency Class: NON EMERGENCY 10 CFR Section: 50.72(b)(2)(xi) - OFFSITE NOTIFICATION	Person (Organization): RAYMOND MCKINLEY (R1DO) SAMSON LEE (NRR) SAM COLLINS (R1 R) JOHN GROBE (NRR) MICHAEL JOHNSON (EDO) BRIAN McDERMOTT (IRD) COMM ASSTS BRIEFING ()

Unit	SCRAM Code	RX CRIT	Initial PWR	Initial RX Mode	Current PWR	Current RX Mode
1	N	N	0	Refueling	0	Refueling

Event Text

RADIATION RELEASE IN CONTAINMENT ASSOCIATED WITH STEAM GENERATOR REMOVAL

"This event is being reported via the ENS to the NRC Operations Center within four hours after notifications were made to the Pennsylvania Emergency Management Agency and local counties for an event of potential public interest. This notification was made at 22:45 on November 21, 2009, after the occurrence of an event related to the safety and health of onsite personnel for which a press release has been made. The press release was made

417

following the event of potential public interest notifications. This report is being made under 10 CFR 72.75(b)(2).

"At approximately 16:00 on Saturday November 21, 2009, low levels of radiation activity were measured on radiation monitors installed in the TMI-1 reactor building. Personnel were directed to immediately leave the reactor building until the source of the activity could be identified. Surveys directly outside of the reactor building construction opening indicated a slight increase in activity. Levels have returned to normal. No contamination was identified outside of the reactor building. Approximately 150 workers were monitored for exposure to the radiation activity. No worker approached or exceeded any exposure limits. The sources of the activity are believed to be from maintenance tasks related to cutting lines in preparation for removal of the 'B' Steam Generator."

The licensee is still investigating the cause of the event but indicated that the radiation release is no longer in progress. Containment Ventilation is established to provide an inflow into containment to the extent possible (considering the openings in containment).

The licensee contacted state and local authorities and the Pennsylvania Emergency Management Agency (PEMA). The licensee notified the NRC Resident Inspector. The licensee has also issued a press release.

* * * UPDATE FROM NEFF TO TEAL AT 1824 EST ON 12/18/2009 * * *

"This provides an update to notification EN #45514 that reported a non-emergency offsite notification for an event on November 21, 2009, at the Three Mile island Nuclear Station.

"Updated news release and notifications to local, state and federal elected and regulatory officials were performed today, December 18, 2009, that provide an outage update as well as communication the results of analysis of Offsite Environmental Monitors following the November 21, 2009 event."

The licensee notified NRC Region I. Notified R1DO (Barkley).

Outside of Scope

Preliminary Notifications: None

Region I Morning Call Notes:

EN 45514 - RADIATION RELEASE IN CONTAINMENT ASSOCIATED WITH STEAM GENERATOR REMOVAL

Exelon made a Press release on 12/18/09 (See Attachment 1 for a copy of the news article) reporting that a monitor about a mile away from TMI picked up trace amounts of radiation during the same week workers were exposed to contamination at the plant. Between 11/18/09 and 11/24/09, one of TMI's seven remote monitors detected an increase of 0.02 millirems.

The Region mentioned that the radiation released was Cobalt 58, the releases were well below any regulatory limit and that Exelon plans to report them during their next Radiological Environmental Monitoring Report. *(Recommend Screen out - Forward to TRG's for Emergency Preparedness; Jeffrey Temple, Health Physics; Steven Garry, Dose Assessment; Mark Blumberg and Public Affairs; Scott Burnell)*

Outside of Scope

Outside of Scope

INFORMATION SENSITIVITY CAUTION -- This e-mail contains preliminary, pre-decisional information and notes gathered in the Region Morning Call discussions. It may also contain proprietary information or photographs. It is restricted to NRC internal use only by Clearinghouse screening meeting participants and is NOT to be distributed further nor used for management decisions. Information from these notes that has been screened by the team may appear in the daily IOEB OpE Screening Summary e-mail, which can be subscribed to by anyone in NRC via the "Reactor OpE Information Gateway" link on the NRR home webpage.

CR + d. SQA
Mike Brown
Reactor Systems Engineer
NRR/DIRS/IOEB
email - michael.brown@nrc.gov
phone - 301-415-4096
(b)(6)
office - O-7E11