

Newport, Christopher

From: Kern, David  
Sent: Thursday, December 31, 2009 2:39 PM  
To: Newport, Christopher; Bellamy, Ronald; Barber, Scott; Greives, Jonathan  
Cc: Brand, Javier; Bamford, Peter; Nimitz, Ronald  
Subject: TMI Update (Outside of Scope and RB Intake Issues)

Chris:

Outside of Scope

Per your request here is the latest update on the 11/21 (RB Airborne Contamination) and  
Outside of Scope issues:

(RB Airborne Contamination)

- as of 12/31/09, 6 workers who received internal uptakes continue to set off the portal monitor alarm. TMI expects they will clear soon, but noted the activity decay rate has decreased.
- preliminary analysis indicates that none of the workers are likely to have received  $\geq 10$  mrem exposure from the event. Per TMI procedures, this means no associated dose from the event is required to be assigned to the workers.

Outside of Scope

Dave