From: Kalyanam, Kaly
Sent: Tuesday, March 23, 2010 4:42 PM
To: STEELMAN, WILLIAM J; MURILLO, ROBERT J
Cc: Lingam, Siva; Feintuch, Karl; Lent, Susan; Burkhardt, Janet
Subject: Acceptance Review Report to Waterford 3 on LAR to reflect SI 4052 modifications - TAC No. ME3421

Billy:

By letter dated February 22, 2010, Entergy Operations, Inc. (Entergy) submitted a License Amendment Request (LAR) to add valve SI-4052A (Reactor Coolant (RC) Loop 2 Shutdown Cooling (SDC) suction inside containment bypass isolation) and valve SI-4052B (RC Loop 1 SDC suction inside containment bypass isolation)) to Technical Specification Table 3.4-1.

The purpose of this letter is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staffs acceptance review of this LAR. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the staff to proceed with its detailed technical review and make an independent assessment regarding the acceptability of the proposed LAR in terms of Code/Regulatory requirements and the protection of public health and safety and the environment. If additional information is needed for the staff to complete its technical review, you will be advised by separate correspondence.

If you have any questions, please contact me at (301) 415-1480.

N. Kalyanam

E-mail Properties

Mail Envelope Properties ()

Subject: Acceptance Review Report to Waterford 3 on LAR to reflect SI 4052 modifications - TAC No. ME3421
Sent Date: 3/23/2010 4:13:34 PM
Received Date: 3/23/2010 4:42:00 PM
From: Kalyanam, Kaly

Created By: Kaly.Kalyanam@nrc.gov

Recipients:
wsteelm@entergy.com (STEELMAN, WILLIAM J)
Tracking Status: None
RMURILL@entergy.com (MURILLO, ROBERT J)

Tracking Status: None
Siva.Lingam@nrc.gov (Lingam, Siva)
Tracking Status: None
Karl.Feintuch@nrc.gov (Feintuch, Karl)
Tracking Status: None
Susan.Lent@nrc.gov (Lent, Susan)
Tracking Status: None
Janet.Burkhardt@nrc.gov (Burkhardt, Janet)
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	10062	3/23/2010

Options
Expiration Date:
Priority: olImportanceNormal
ReplyRequested: False
Return Notification: False

Sensitivity: olNormal
Recipients received: