

Attachment 02.04.03-08Q
TVA letter dated February 2, 2010
RAI Response

ASSOCIATED ATTACHMENTS/ENCLOSURES:

Attachment 02.04.03-8Q: Dam Rating Curves, Nottely

(106 Pages including Cover Sheet)

NPG CALCULATION COVERSHEET/CCRIS UPDATE

REV 0 EDMS/RIMS NO. L58:081211.801		EDMS TYPE: Calculations (nuclear)	EDMS ACCESSION NO. (N/A for REV. 0) L 58 091230 028					
Calc Title: Dam Rating Curve, Nottely								
CALC ID	TYPE	ORG	PLANT	BRANCH	NUMBER	CUR REV	NEW REV	REVISION APPLICABILITY: Entire calc <input checked="" type="checkbox"/> Selected pages <input type="checkbox"/>
CURRENT	CN	NUC	GEN	CEB	CDQ000020080016	1	2	
NEW								
ACTION	NEW REVISION <input checked="" type="checkbox"/>	DELETE RENAME <input type="checkbox"/>	SUPERSEDE DUPLICATE <input type="checkbox"/>	CCRIS UPDATE ONLY <input type="checkbox"/> (Verifier Approval Signatures Not Required)	No CCRIS Changes <input type="checkbox"/> (For calc revision, CCRIS been reviewed and no CCRIS changes required)			
UNITS N/A	SYSTEMS N/A	UNIDS N/A						
DCN, EDC, N/A *See below	APPLICABLE DESIGN DOCUMENT(S): N/A			CLASSIFICATION E				
QUALITY RELATED? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	SAFETY RELATED? (If yes, QR = yes) Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	UNVERIFIED ASSUMPTION Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	SPECIAL REQUIREMENTS AND/OR LIMITING CONDITIONS? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	DESIGN OUTPUT ATTACHMENT? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	SAR/TS and/or ISFSI SAR/CoC AFFECTED? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>			
PREPARER ID J. B. Mauter	PREPARER PHONE NO. 205-298-6074	PREPARING ORG (BRANCH) CEB	VERIFICATION METHOD Design Review	NEW METHOD OF ANALYSIS <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No				
PREPARER SIGNATURE Janie B. Mauter <i>Janie B. Mauter</i>	DATE 12/14/09	CHECKER SIGNATURE Andrew C. Murr <i>Andrew C. Murr</i>	DATE 12/14/09					
VERIFIER SIGNATURE Andrew C. Murr <i>Andrew C. Murr</i>	DATE 12/14/09	APPROVAL SIGNATURE <i>K.R. Spates</i>	DATE 12/23/09					
STATEMENT OF PROBLEM/ABSTRACT <i>W. P. ...</i> Headwater rating curves for 20 dams are required as inputs to TVA's SOCH and TRBROUTE models, which perform flood-routing calculations for the Tennessee River and tributaries. The headwater rating curves for each dam provide total dam discharge as a function of headwater elevation. This calculation presents the headwater rating curve for Nottely Dam. This calculation contains electronic attachments and must be stored in EDMS as an ADOBE .pdf file to maintain the ability to retrieve the electronic attachments. *EDCN 22404A (SQN), EDCN 54018A (WBN), EDCN Later (BFN)								
MICROFICHE/EFICHE Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> FICHE NUMBER(S)								
<input type="checkbox"/> LOAD INTO EDMS AND DESTROY <input checked="" type="checkbox"/> LOAD INTO EDMS AND RETURN CALCULATION TO CALCULATION LIBRARY. ADDRESS: LP4D-C <input type="checkbox"/> LOAD INTO EDMS AND RETURN CALCULATION TO:								

L58 081211 001

TVA CALCULATION COVERSHEET/CCRIS UPDATE

REV 0 EDMS/RIMS NO. L58081211801		EDMS TYPE: Calculations (nuclear)		EDMS ACCESSION NO (N/A for REV. 0) N/A				
Calc Title: Dam Rating Curves, Nottely								
CALC ID	TYPE	ORG	PLANT	BRANCH	NUMBER	CUR REV	NEW REV	REVISION APPLICABILITY Entire calc <input type="checkbox"/> Selected pages <input type="checkbox"/>
CURRENT	CN	NUC						
NEW	CN	NUC	GEN	CEB	CDQ000020080016	N/A	0	
ACTION	NEW REVISION <input checked="" type="checkbox"/>	DELETE RENAME <input type="checkbox"/>	SUPERSEDE DUPLICATE <input type="checkbox"/>	CCRIS UPDATE ONLY <input type="checkbox"/>	(Verifier Approval Signatures Not Required)			No CCRIS Changes <input type="checkbox"/> (For calc revision, CCRIS been reviewed and no CCRIS changes required)
UNITS 000	SYSTEMS N/A		UNIDS N/A					
DCN,EDC,N/A N/A		APPLICABLE DESIGN DOCUMENT(S) N/A				CLASSIFICATION E		
QUALITY RELATED? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	SAFETY RELATED? (If yes, QR = yes) Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	UNVERIFIED ASSUMPTION Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	SPECIAL REQUIREMENTS AND/OR LIMITING CONDITIONS? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		DESIGN OUTPUT ATTACHMENT? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	SAR/TS and/or ISFSI SAR/CoC AFFECTED Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		
PREPARER ID A. T. Tinsley	PREPARER PHONE NO. 885-220-4418	PREPARING ORG.(BRANCH) CEB	VERIFICATION METHOD Design Review	NEW METHOD OF ANALYSIS <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No				
PREPARER SIGNATURE <i>A. T. Tinsley</i>	DATE 12/9/08	CHECKER SIGNATURE <i>JANIE B. MAITRE</i>	DATE 12/9/08					
VERIFIER SIGNATURE <i>Andrew C. Murr</i>	DATE 12/9/08	APPROVAL SIGNATURE <i>L. P. [Signature]</i>	DATE 12/10/08					
STATEMENT OF PROBLEM/ABSTRACT								
<p>Headwater rating curves for 20 dams are required as inputs to TVA's SOCH and TRBROUTE models, which perform flood-routing calculations for the Tennessee River and tributaries. The headwater rating curves for each dam provide total dam discharge as a function of headwater elevation. This calculation presents the headwater rating curve for Nottely Dam.</p> <p>This calculation contains electronic attachments and must be stored in EDMS as an ADOBE .pdf file to maintain the ability to retrieve the electronic attachments.</p>								
MICROFICHE/EFICHE Yes <input type="checkbox"/> No <input type="checkbox"/> FICHE NUMBER(S)								
<input checked="" type="checkbox"/> LOAD INTO EDMS AND DESTROY <input checked="" type="checkbox"/> LOAD INTO EDMS AND RETURN CALCULATION TO CALCULATION LIBRARY. ADDRESS: LP4D-C <input type="checkbox"/> LOAD INTO EDMS AND RETURN CALCULATION TO:								

TVAN CALCULATION COVERSHEET/CCRIS UPDATE

REV 0 EDMS/RIMS NO. L58 081211 801		EDMS TYPE: Calculations (nuclear)		EDMS ACCESSION NO (N/A for REV. 0) L58 090216 003				
Calc Title: Dam Rating Curves, Nottely								
<u>CALC ID</u>	<u>TYPE</u>	<u>ORG</u>	<u>PLANT</u>	<u>BRANCH</u>	<u>NUMBER</u>	<u>CUR REV</u>	<u>NEW REV.</u>	<u>REVISION APPLICABILITY</u> Entire calc <input checked="" type="checkbox"/> Selected pages <input type="checkbox"/>
CURRENT	CN	NUC	GEN	CEB	CDQ000020080016	0	1	
NEW								
<u>ACTION</u>	NEW REVISION <input checked="" type="checkbox"/>	DELETE RENAME <input type="checkbox"/>	SUPERSEDE DUPLICATE <input type="checkbox"/>	CCRIS UPDATE ONLY <input type="checkbox"/>	No CCRIS Changes <input type="checkbox"/> (For calc revision, CCRIS been reviewed and no CCRIS changes required)			
<u>UNITS</u> 000	<u>SYSTEMS</u> N/A	<u>UNIDS</u> N/A		<u>DCN,EDC,N/A</u> N/A		<u>APPLICABLE DESIGN DOCUMENT(S)</u> N/A		<u>CLASSIFICATION</u> E
<u>QUALITY RELATED?</u> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	<u>SAFETY RELATED?</u> (If yes, QR = yes) Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	<u>UNVERIFIED ASSUMPTION</u> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	<u>SPECIAL REQUIREMENTS AND/OR LIMITING CONDITIONS?</u> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	<u>DESIGN OUTPUT ATTACHMENT?</u> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	<u>SAR/TS and/or ISFSI SAR/CoC AFFECTED?</u> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>			
<u>PREPARER ID</u> A. T. Tinsley	<u>PREPARER PHONE NO</u> 865-220-4418	<u>PREPARING ORG (BRANCH)</u> CEB	<u>VERIFICATION METHOD</u> Design Review	<u>NEW METHOD OF ANALYSIS</u> <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No				
<u>PREPARER SIGNATURE</u> <i>Andrew Tinsley</i>	<u>DATE</u> 1/23/09	<u>CHECKER SIGNATURE</u> <i>SARA MARTINEZ</i>	<u>DATE</u> 1-23-09	<u>VERIFIER SIGNATURE</u> <i>Joe V. Peyton</i>	<u>DATE</u> 1/23/09	<u>APPROVAL SIGNATURE</u> <i>K.R. Spates</i>	<u>DATE</u> 2/13/09	
<u>STATEMENT OF PROBLEM/ABSTRACT</u>								
<p>Headwater rating curves for 20 dams are required as inputs to TVA's SOCH and TRBROUTE models, which perform flood-routing calculations for the Tennessee River and tributaries. The headwater rating curves for each dam provide total dam discharge as a function of headwater elevation. This calculation presents the headwater rating curve for Nottely Dam.</p> <p>This calculation contains electronic attachments and must be stored in EDMS as an ADOBE .pdf file to maintain the ability to retrieve the electronic attachments.</p>								
<u>MICROFICHE/EFICHE</u> Yes <input type="checkbox"/> No <input type="checkbox"/>		<u>FICHE NUMBER(S)</u>						
<input type="checkbox"/> LOAD INTO EDMS AND DESTROY <input checked="" type="checkbox"/> LOAD INTO EDMS AND RETURN CALCULATION TO CALCULATION LIBRARY. ADDRESS: LP4D-C <input type="checkbox"/> LOAD INTO EDMS AND RETURN CALCULATION TO:								

NPG CALCULATION COVERSHEET/CCRIS UPDATE

<u>CALC ID</u>	<u>TYPE</u>	<u>ORG</u>	<u>PLANT</u>	<u>BRANCH</u>	<u>NUMBER</u>	<u>REV</u>
	CN	NUC	GEN	CEB	CDQ000020080016	2

ALTERNATE CALCULATION IDENTIFICATION

<u>BLDG</u>	<u>ROOM</u>	<u>ELEV</u>	<u>COORD/AZIM</u>	<u>FIRM BWSC</u>	Print Report Yes <input type="checkbox"/>
CATEGORIES NA					

KEY NOUNS (A-add, D-delete)

<u>ACTION (A/D)</u>	<u>KEY NOUN</u>	<u>A/D</u>	<u>KEY NOUN</u>

CROSS-REFERENCES (A-add, C-change, D-delete)

<u>ACTION (A/C/D)</u>	<u>XREF CODE</u>	<u>XREF TYPE</u>	<u>XREF PLANT</u>	<u>XREF BRANCH</u>	<u>XREF NUMBER</u>	<u>XREF REV</u>
A	P	EN	WBN	CEB	54018	
A	P	EN	SQN	CEB	22404	
A	S	CN	GEN	CEB	CDQ000020080053	

CCRIS ONLY UPDATES:
 Following are required only when making keyword/cross reference CCRIS updates and page 1 of form NEDP-2-1 is not included:

<u>PREPARER SIGNATURE</u>	<u>DATE</u>	<u>CHECKER SIGNATURE</u>	<u>DATE</u>
<u>PREPARER PHONE NO.</u>	<u>EDMS ACCESSION NO.</u>		

NPG CALCULATION RECORD OF REVISION	
CALCULATION IDENTIFIER CDQ000020080016	
Title Dam Rating Curve, Nottely	
Revision No.	DESCRIPTION OF REVISION
0	Initial issue
1	Revised Calculation to include Turbine Flow. Revised pages 1-11, 15, and 17-22. Revised Attachment 1. Added Attachments 7, 13, 16, and 22 (renumbered accordingly as necessary). 38 total pages after revision including R0 cover sheet as page 1a.
2	<p>This calculation was revised to address the following:</p> <ul style="list-style-type: none"> • PER 203951. The verification of the original calculation was completed by personnel who had not completed the required NEDP-7 Job Performance Record (JPR). A verification JPR is now in place for all personnel engaged in verification tasks. Checking includes only changes made in this revision as the checking of the calculation was not impacted by PER 203951. The verification is inclusive of work completed prior to this revision. • PER 203872. Replace NEDP-2 forms on pages 1 through 6 with the forms from the NEDP-2 revision in effect at the time of calculation issuance. • UVA 3.2.1. Removed and replaced with Assumption 3.1.4 based on Reference 2.8. • UVA 3.2.2. Removed and replaced with Assumption 3.1.5 based on Reference 2.9. • Add Assumption 3.1.6 based on Technical Justification. • Updated Figure 8 and Table 5. • Add Case 2 for gate failure without turbine flow. • Add Figure 5 and Table 4. <p>Significant changes to text in Revision 2 are marked with a right-hand margin revision bar. Administrative changes and typos are excluded.</p> <p>Pages Deleted: None Pages Revised: 1 – 7, 9-19, 22-25 New Pages added: 1b, 5</p> <p>Total hardcopy pages Revision 2: 42</p> <p>Additional Comments:</p> <ul style="list-style-type: none"> • Rev. 1 coversheet is page 1b • Added Verification Form as page 5 • Updated page numbers • Include number of pages per attachment in Table of Contents

NPG CALCULATION TABLE OF CONTENTS		
Calculation Identifier: CDQ000020080016		Revision: 2
TABLE OF CONTENTS		
SECTION	TITLE	PAGE
	Coversheet	1
	Revision 0 Coversheet	1a
	Revision 1 Coversheet	1b
	CCRIS Update Sheet	2
	Revision Log	3
	Table of Contents	4
	Calculation Verification Form	5
	Computer Input Sheet	6
1	Purpose	7
2	References	9
3	Assumptions & Methodology	10
4	Design Input	18
5	Special Requirements/Limiting Conditions	19
6	Calculations	20
7	Results/Conclusions	24
Figures		
1	Nottely Dam, General Plan and Elevation (Ref. 2.1.1)	8
2	Case 1 Illustration	11
3	Nottely Spillway Discharge Curve	12
4	Transition Region – Not Touching Gate	13
5	Transition Region – Touching Gate	13
6	Case 3 Illustration	14
7	Linear Regression fit for Data in Table 1	15
8	Headwater Rating Curves	25
Tables		
1	Interpolation of C_0 from Figure 257 of Reference 2.6	15
2	Case 1 Calculations	20
3	Case 1a Calculations	21
4	Case 2 Calculations	22
5	Headwater Rating Results	24
Attachments		
1	Nottely Tailwater Rating Curve (Ref. 2.7)	2 pages
2	Nottely Project Spillway Discharge Study, November 1942 (Ref. 2.4)	1 page
3	Nottely Spillway Discharge Study, April 2004 (Ref. 2.2)	2 pages
4	Figure 257 from Design of Small Dams (Ref. 2.6)	1 page
5	Hydraulic Design Chart 711 from USACE (Ref. 2.5)	1 page
6	Excerpt from Nottely Blue Book (Ref. 2.8)	1 page
7	Turbine Discharge (Ref. 2.8)	1 page
8	TVA Drawing # 10W200 (Ref. 2.1.1)	1 page
9	TVA Drawing # 54W320 (Ref. 2.1.2)	1 page
10	TVA Drawing # 21E205-1 (Ref. 2.1.3)	1 page
11	TVA Drawing # 54N310 (Ref. 2.1.4)	1 page
12	TVA Drawing # 58N202 (Ref. 2.1.5)	1 page
13	TVA Drawing # 41W600 (Ref. 2.1.6)	1 page
14	Nottely DRC Calcs_Rev2.xls Spreadsheet for headwater rating curve calculations	N/A
15	Electronic Copy of Reference 2.2	11 pages
16	Electronic Copy of Reference 2.8	46 pages
17-22	High Resolution Electronic Copies of References 2.1.1 through 2.1.6	1 page each

NPG CALCULATION VERIFICATION FORM

Calculation Identifier CDQ000020080016

Revision 2

Method of verification used:

1. Design Review
2. Alternate Calculation
3. Qualification Test


 Verifier Andrew C. Murr

Date

12/14/2009

Comments:

This calculation entitled, "Dam Rating Curve, Nottely" was verified by independent design review. The process involved a critical review of the calculation to ensure that it is correct and complete, uses appropriate methodologies, and achieves its intended purpose. The inputs were reviewed and determined to be appropriate inputs for this calculation. The results of the calculation were reviewed and were found to be reasonable and consistent with the inputs provided. Backup files and documents were consulted as necessary to verify data and analysis details found in the calculation.

Detailed comments and editorial suggestions for the changes made in this revision were transmitted to the author and reviewer by email along with a marked up copy of the calculation.

(Note: The design verification of this calculation revision is for the total calculation, not just the changes made in the revision. This complete re-verification is performed to disposition PER 203951 as described in the Calculation Revision Log on Page 3.)

**NPG COMPUTER INPUT FILE
STORAGE INFORMATION SHEET**

Document CDQ000020080016

Rev. 2

Plant: GEN

Subject:
Dam Rating Curve, Nottely

Electronic storage of the input files for this calculation is not required. Comments:

There are no electronic input/output files associated with this calculation.

Input files for this calculation have been stored electronically and sufficient identifying information is provided below for each input file. (Any retrieved file requires re-verification of its contents before use.)

These files are electronically attached to the parent ADOBE. PDF calculation file. All files are therefore stored in an unalterable medium and are retrievable through the EDMS number for this calculation.

Attachment 14: Nottely DRC Calcs_Rev2.xls Spreadsheet for headwater rating curve calculations

Attachment 15: Electronic Copy of Reference 2.2

Attachment 16: Electronic Copy of Reference 2.8

Attachments 17-22: High Resolution Electronic Copies of References 2.1.1 through 2.1.6

Microfiche/eFiche

TVA

Calculation No. CDQ000020080016	Rev: 2	Plant: GEN	Page: 7
Subject: Dam Rating Curve, Nottely	Prepd: JBM		
	Checked: ACM		

1. Purpose

Headwater rating curves for twenty dams geographically located on the Tennessee River and its tributaries above the existing Bellefonte Nuclear facility are required as inputs to TVA's SOCH and TRBROUTE models, which perform flood-routing calculations. The headwater rating curves for each dam provide total dam discharge as a function of headwater elevation. This calculation presents the headwater rating curve for Nottely Dam.

TVA developed methods of analysis, procedures, and computer programs for determining design basis flood levels for nuclear plant sites in the 1970's. Determination of maximum flood levels included consideration of the most severe flood conditions that may be reasonably predicted to occur at a site as a result of both severe hydrometeorological conditions and seismic activity. This process was followed to meet Nuclear Regulatory Guide 1.59. At that time, there were no computer programs available that would handle unsteady flow and dam failure analysis. As a result of this early work and method development TVA developed a runoff and stream course modeling process for the TVA reservoir system. This process provided a basis for currently licensed plants (Sequoyah Nuclear Plant, Watts Bar Nuclear Plant, and Browns Ferry Nuclear Plant). The Bellefonte Nuclear Plant (BLN) Units 1 & 2 Final Safety Analysis Report (FSAR) was also based on this process.

BLN Unit 3 & 4 Combined Operating License Application (COLA) was submitted using data and analysis that was determined for the original BLN FSAR (Unit 1 and Unit 2) and was documented in a 1998 reassessment. In 1998, the analysis process and documentation was brought under the nuclear quality assurance process for the first time. A quality assurance audit conducted by NRC staff in early 2007 raised several questions related to the documentation of past work regarding design basis flood level determinations. This calculation supports a portion of the effort to improve the design basis documentation.

Preparation of all calculations supporting nuclear development and licensing are subject to TVA Standard Department Procedure NEDP-2. This standard dictates the process in which calculations are prepared, checked, verified, stored, and cross referenced in a goal to provide the highest quality nuclear design input and output possible.

Figure 1 is a plan and elevation view of Nottely dam (Reference 2.1.1). For headwaters in the normal operating range, discharge is passed through the Unit 1 turbine or over the spillway. The spillway consists of fifty (50) vertical lift spillway gates, each with a rectangular gate to control discharge. During a PMF event, headwater rises above the normal operating range and discharge passes over the spillway crest assuming all fifty gates are in the up and stored configuration. As the headwater level increases, flow is un-restricted until the free flowing nappe first contacts the bottoms of the raised gates. The discharge under the gates is predicted by orifice flow equations. As the headwater elevation continues to rise, it will eventually flow over the raised gates. At this point discharge is occurring both above and below the raised gates. The dam embankment elevation was raised in 1988 to accommodate the PMF to ensure no overflow of the dam.

This headwater rating curve is based on the configuration of the Nottely Dam as defined on the current design drawings. The purpose of this calculation does not evaluate the design loading conditions for the dam.

Headwater rating curves are computed for three separate scenarios as follows:

- Case 1 – Headwater Rating Curve with Turbine Flow
- Case 1a – Headwater Rating Curve without Turbine Flow
- Case 2 – Headwater Rating Curve with Gate Failure and without Turbine Flow

Previous revisions included curves with and without turbine flow in which the gates remained in the stored position. In Revision 2, a third scenario is added in which the gates fail in the open stored position, without turbine flow, due to a PMF event.

Calculation No. CDQ000020080016	Rev: 1	Plant: GEN	Page: 8
Subject: Dam Rating Curve, Nottely	Prepd: A.T. Tinsley		
	Checked: SEM		




Figure 1 – Nottely Dam, General Plan and Elevation (Reference 2.1.1)

TVA

Calculation No. CDQ000020080016	Rev: 2	Plant: GEN	Page: 9
Subject: Dam Rating Curve, Nottely	Prepd: JBM		
	Checked: ACM		

2. References**2.1. TVA Drawings**

- 2.1.1. 10W200, R18 (Attachments 8 and 17)
- 2.1.2. 54W320, R3 (Attachments 9 and 18)
- 2.1.3. 21E205-1, R4 (Attachments 10 and 19)
- 2.1.4. 54N310, R1 (Attachments 11 and 20)
- 2.1.5. 58N202, R1 (Attachments 12 and 21)
- 2.1.6. 41W600, R7 (Attachments 13 and 22)
- 2.2. "Nottely Dam Spillway Discharge Tables", River Operations, Tennessee Valley Authority, 2004 (Attachments 3 and 15)
- 2.3. "Hydraulic Design Criteria", USACE (U.S. Army Corp of Engineers), U. S. Army Engineer Waterways Experiment Station, Eighteenth Issue, Vicksburg, MS, 1998.
- 2.4. Tennessee Valley Authority. "Spillway Discharge Studies: Nottely Project Rating Curve." Engineering Lab Project Files. Box 53760 (K04K070). ASF 590. (Attachment 2)
- 2.5. Hydraulic Design Chart 711 (HDC 711) from Reference 2.3 (Attachment 5).
- 2.6. U.S. Department of the Interior. "Design of Small Dams." U.S. Government Printing Office. 1977.
- 2.7. TVA Files, Binder "River Scheduling: Tailwater Rating Curves by Project." (Attachment 1)
- 2.8. TVA Water Control Project Blue Book. Nottely Dam. July 2001. Page 41. (Attachments 6, 7 and 16)
- 2.9. "Basis for Dam Spillway Gate/Outlet Open Configuration for Flood Analyses," Tennessee Valley Authority, May 29, 2009 (EDMS No. L58 090529 800).

TVA

Calculation No. CDQ000020080016	Rev: 2	Plant: GEN	Page: 10
Subject: Dam Rating Curve, Nottely	Prepd: JBM		
	Checked: ACM		

3. Assumptions & Methodology

The headwater rating curves developed in these calculations will be used in simulations of probable maximum flood events. Consequently, the rating curves have been calculated well above the normal operating range.

3.1. Assumptions

- 3.1.1. **Assumption:** The Unit 1 turbine will be operating during the PMF event for tailwater elevations of less than 1643 feet.
Technical Justification: The unit 1 turbine will be in operation until there is a technical reason to shut off the turbine. The elevation of the powerhouse and switchyard (Reference 2.1.1 and Reference 2.1.6) is lower than the anticipated tailwater levels shown in Attachment 1 (Reference 2.7). Therefore, the switchyard and powerhouse will be submerged whenever the tailwater levels exceed approximately 1643 feet. If the tailwater elevation is less than 1643 feet, the turbine will be assumed to be operating at a maximum sustainable discharge of 1800 cfs as indicated in Attachment 7.
- 3.1.2. **Assumption:** Tailwater does not affect spill discharge at Nottely.
Technical Justification: See Attachment 1 for tailwater curve plot of discharge versus elevation which indicates that the maximum tailwater elevation would be much less than the spillways crest elevation of 1775.0 thereby not affecting the discharge.
- 3.1.3. **Assumption:** The tailwater rating curve provided as Attachment 1 is used in the evaluation of headwater rating curve calculations.
Technical Justification: This curve was produced by TVA's River Operations Flood Risk Group. The maximum estimated overflow presented in this calculation is 166,000 cfs which places the tailwater elevation at approximately 1666 feet. Since the crest elevation is located at approximately 1775 feet, there is a possibility for over 100 feet of error in the tailwater rating curve before it affects the overflow of the dam. Since a flood of this magnitude would be highly unlikely as well as incredibly destructive, it is assumed that the tailwater will have no effect on the overflow of the dam. Reference 2.1.1 also shows that the dam was designed for a maximum tailwater elevation of 1638.7 at a flow of 57,000 cfs, a minimum tailwater elevation of 1605.6 at no flow and a normal tailwater elevation of 1613.5 at a flow of 1730 cfs. These values correlate well with the curve and show that the model used to predict the tailwater curve is accurate enough to make this assumption.
- 3.1.4. **Assumption:** The embankments will not be overtopped during a PMF event.
Technical Justification: The dam safety modifications completed in the late 1980s were designed to ensure that the embankments will not be overtopped during a PMF event (Reference 2.8, relevant pages included in Attachment 6).
- 3.1.5. **Assumption:** All spillway gates will remain operable and will be set to the maximum openings specified in the spillway discharge tables.
Technical Justification: For technical justification, see Reference 2.9, "Basis for Dam Spillway Gate/Outlet Open Configuration for Flood Analyses."
- 3.1.6. **Assumption:** The position of the Nottely spillway gates will not be significantly changed at headwater levels up to 1789.8 feet (transition point from free flow to orifice flow). The spillway gates will remain in place when the headwater level is at or below 1789.8 feet. The spillway gates' stability is indeterminate for water levels above elevation 1789.8 feet and the gates will be considered to fail (total washout).
Technical Justification: There are no structural evaluations that confirm the structural integrity of the spillway gates in their stored position. Headwater levels above this value results in water forces directly impacting the lower portion of the raised gate. In the fully raised stored position, only the lower rollers are in contact with the gate guides. At headwater levels at or above 1789.8 feet, the gate is in the flow path. The gate has been judged to be wedged at the lower roller within the guide, and any structural failure of the gate was judged to be bending; not a total washout of the gate. However, even if a total washout of the gate occurred, the remaining orifices that would allow flow through would represent only a minor increase in flow capacity from the calculated values, and would have discernable impact on downstream PMF levels. Once the water reaches the midpoint of the gate, the

TVA

Calculation No. CDQ000020080016	Rev: 2	Plant: GEN	Page: 11
Subject: Dam Rating Curve, Nottely	Prepd: JBM		
	Checked: ACM		

gate stresses increase significantly and it is uncertain the gates will remain in place. For conservatism, the gates will be considered to fail (total washout) when water elevations rise above 1789.08 feet on the gate (midpoint of fully raised stored gate), which corresponds to a headwater elevation of 1789.8 feet.

3.2 Unverified Assumptions (UVA)

None.

3.3 Methodology -- Discharge Equations

3.3.1 Case 1 – Free Flow through Spillways ($1775' < H_w < H_T$)

As water level rises and gates are opened, water will crest the spillway and flow as a weir flow as shown in Figure 2 above $H_w = 1775'$. This type of flow will continue until the water level reaches H_T . H_T is the height at which the nappe touches the bottoms of the raised gates and will be discussed further in Section 3.3.2.




Figure 2 – Case 1 Illustration

Standard flow computations are not utilized for this scenario as a rating curve giving Q_f vs. Headwater Elevation is available from the TVA Spillway Discharge Study dated November 4, 1942 for the Nottely Project (Reference 2.4, Attachment 2). This free discharge curve can be modeled using the following polynomial:

$$Q_f = 0.4163H_c^4 - 16.551H_c^3 + 413.75H_c^2 + 602.98H_c \quad (1)$$

Where H_c is the head over crest (ft)

Figure 3 shows the scaled points and the fit derived from the data. Also note that the rating curve in Attachment 2 is still in use in the most updated spillway discharge tables by TVA (Reference 2.2, Attachment 3) and correlates very well with the current data.

TVA

Calculation No. CDQ000020080016	Rev: 2	Plant: GEN	Page: 12
Subject: Dam Rating Curve, Nottely	Prepd: JBM		
	Checked: ACM		

Note that this curve was derived from model data. The preliminary measured flows were less than 2000 cfs (see note on attachment) and the rest of the curve was fit by scale model simulations.

Submergence factors and related calculations are unnecessary as there are no tailwater effects (Assumption 3.1.2).




Figure 3– Nottely Spillway Discharge Curve

3.3.2 Case 2 - Transition Region ($H_{bottom} < H_w < H_T$)

The flow does not transform into orifice flow as soon as the water height reaches the elevation of the bottoms of the gates (See Figure 4). There is a transition zone in which unknown behavior of the flow is anticipated. Attachment 11 (Dwg. 54N310, View-Typical Section Thru Centerline of Gate) shows a water elevation of 1788.5 ($H_c=13.5'$) and a height of nappe at the crest equal to 1785.4' ($H_n=10.4'$). The ratio of these values is taken to develop a relationship between the water elevation and nappe height for a given crest geometry.

$$\frac{H_c}{H_n} = \frac{13.5'}{10.4'} = 1.30 \tag{2}$$

Where H_n is the height of the nappe directly beneath the spillway gates.

This ratio can be assumed as constant for the same crest. Therefore, $H_T = 1.3(d) = 1.3 * 11.4' = 14.8'$ over the crest or a headwater elevation of 1789.8'. Note that $d=11.4'$ comes from Attachment 9, Elevation A-A/B-B.

The headwater elevation will remain relatively constant as the nappe gradually rises to equal the previously determined H_T value. At this point, the flow is no longer in the transition region and the headwater will continue to rise (see Figure 5).

Calculation No. CDQ000020080016 Subject: Dam Rating Curve, Nottely	Rev: 2	Plant: GEN	Page: 13
	Prepd: JBM		
	Checked: ACM		




Figure 4 – Transition Region – Not Touching Gate




Figure 5 – Transition Region – Touching Gate

TVA

Calculation No. CDQ000020080016	Rev: 2	Plant: GEN	Page: 14
Subject: Dam Rating Curve, Nottely	Prepd: JBM		
	Checked: ACM		

3.3.3 Case 3 – Orifice flow through gates ($H_T < H_W < H_{MAX}$)

As headwater rises, it eventually reaches a level beyond the transition zone (See Figure 6). For headwaters above that level, discharge is predicted using an orifice type equation. Model data for the gated flow at Nottely are not available, but Reference 2.6 provides a relationship between C_o (the orifice discharge coefficient) and d/H that may be used as an approximation in the following equation for orifice discharge, Q_o :

$$Q_o = \frac{2}{3} \sqrt{2g} C_o L [H_c^{1.5} - (H_c - d)^{1.5}] \tag{3}$$

with C_o taken from Fig 257 (Attachment 4) out of Reference 2.6, L = Overflow Length (ft), d = height of orifice, and g =the acceleration due to gravity. See Figure 4 for graphical representation of equation terms. All other terms are defined in Figure 5.




Figure 6 – Case 3 Illustration

Interpolation of C_o values from the chart in Attachment 4, yields values shown in Table 1. A linear regression fit shown in Figure 7 indicates a satisfactory estimate of C_o can be yielded for a range of H_c values from 16.29' to 32.57' for Cases 1 and 1a (in the actual figure, H_1 is equivalent to H_c in this calculation), and 15.4' to 34.29' for Case 2. The equation developed from the linear regression is shown in Equation 4 and will be used to estimate the values of C_o for a range of $16.29' < H_c < 32.57'$ for Cases 1 and 1a, and a range of $15.4' < H_c < 34.29'$ for Case 2.

Calculation No. CDQ000020080016	Rev: 2	Plant: GEN	Page: 15
Subject: Dam Rating Curve, Nottely	Prepd: JBM		
	Checked: ACM		

Table 1: Interpolation of C_o from Figure 257 of Reference 2.6

d/H _c	C	Cases 1&1a		Case 2	
		H _c	H _w	H _c	H _w
0.78	0.638	14.63	1789.63	15.40	1790.40
0.75	0.641	15.20	1790.20	16.00	1791.00
0.70	0.646	16.29	1791.29	17.14	1792.14
0.65	0.651	17.54	1792.54	18.46	1793.46
0.60	0.656	19.00	1794.00	20.00	1795.00
0.55	0.662	20.73	1795.73	21.82	1796.82
0.50	0.667	22.80	1797.80	24.00	1799.00
0.45	0.672	25.33	1800.33	26.67	1801.67
0.40	0.6775	28.50	1803.50	30.00	1805.00
0.35	0.6825	32.57	1807.57	34.29	1809.29

Note that the maximum d/H_c on Attachment 4 is 0.70 which translates into a minimum H_c of 16.29' (i.e. d=11.4', therefore at d/H_c=0.7, H_c=11.4'/0.7=16.29') for Cases 1 and 1a. However, a value of 0.78 was needed for Case 2, giving a minimum H_c of 15.4'. Therefore, the value was extrapolated. The minimum d/H_c of 0.35 was all that was necessary to provide the data for the range of headwater elevations required by this calculation.




Figure 7 – Linear Regression fit for Data in Table 1

$$C_o = -0.105 \frac{d}{H_c} + 0.7194$$

(4)

TVA

Calculation No. CDQ000020080016	Rev: 2	Plant: GEN	Page: 16
Subject: Dam Rating Curve, Nottely	Prepd: JBM		
	Checked: ACM		

3.3.4 Case 4 – Combined Orifice Flow through Gates and Weir Flow Over Gates ($H_w > H_{Top}$)

As the headwater continues to rise, it will eventually overtop the raised gates at elevation 1791.4. This flow can be computed as a weir flow over the top of the gates. The C_w coefficient can be computed using USACE Hydraulic Design Criteria, specifically Hydraulic Design Chart 711 (Attachment 5, Reference 2.5). The governing weir equation is a slightly modified form of the basic weir equation and is taken as (Reference 2.5):

$$Q_w = C_w L_w (H_w - 1791.4)^{1.5} \quad (5)$$

where L_w is the length of the weir, H_w is the elevation of the headwater, and C_w is the discharge coefficient of the weir.

The upper plot of HDC 711 (Attachment 5, Reference 2.5) shows that C_w is about 2.65 for very broad crests ($H_1/B < 0.4$ where $H_1 = H_c$ and B = streamwise length of the crest) and gradually increases to 3.3, the maximum value for a “sharp crested” weir. The flood gates are approximately 4.25”** wide (Attachment 11, Reference 2.1.4). The water level can range from 0-16.1’ over the top of these gates given the analysis elevations of this calculation. This yields an H_1/B ranging from 0 to 45.5, indicating that the weir will likely behave as a sharp crested weir. Since the estimation of discharge over the top of various sections of the dam is an approximation, small variations of C_w with H_c are not modeled. Consequently, for all overflows C_w will be assigned a single value taken as the maximum of 3.3 since this is the value indicated for a sharp crested weir. Neglecting minor variations in C_w values has negligible impact on the dam rating curve.

**Gate is made of a 4” wide C-Channel and covered with a ¼” skin plate for a total width of approximately 4.25”.

In Case 2, the gates fail as water reaches the midpoint of the gate at 1789.08 feet, when the headwater is at an elevation of 1789.8 feet. When the gates fail, the water overtops the gate machinery at elevation 1790.4 feet. This flow can be computed as a weir flow. The C_w coefficient can be computed using USACE Hydraulic Design Chart 711. The governing weir equation is a slightly modified form of Equation 5:

$$Q_w = C_w L_w (H_w - 1790.4)^{1.5} \quad (6)$$

where L_w is the length of the weir, H_w is the elevation of the headwater, and C_w is the discharge coefficient of the weir.

The gate machinery is approximately 11” wide (Attachment 9, Reference 2.1.2). The weir will likely behave as a sharp crested weir. Consequently, for all overflows C_w will be assigned a single value taken as the maximum of 3.3. Neglecting minor variations in C_w values has negligible impact on the dam rating curve.

TVA

Calculation No. CDQ000020080016	Rev: 2	Plant: GEN	Page: 17
Subject: Dam Rating Curve, Nottely	Prepd: JBM		
	Checked: ACM		

4. Design Input

Sect.	Input Parameter	Source	Symbol	Value
4.1	Acceleration of gravity	Common knowledge	g	32.2 ft/sec ²
4.2	Spillway crest parameters			
4.2.1	Crest length	50, 6' wide gates, Reference 2.1.4, Key Plan View	L	300 feet
4.2.2	Crest elevation	Reference 2.1.1, Downstream Elevation View	Z _c	1775 feet
4.2.3	Free discharge curve	Polynomial fit to model data demonstrated in Figure 3 (Reference 2.7)	Q _r	Equation 1
4.3	Spillway gate parameters – Gates remain in place			
4.3.1	Vertical opening	Reference 2.1.2, Elevation A-A and B-B, also Fig. 4	d	11.4 feet
4.3.4	Headwater elevation at which nappe touches gates	Justification in Section 3.3.2	H _T	1789.8 feet
4.3.5	Orifice discharge coefficient	Estimated by Equation 4 in Section 3.3.3	C _O (H _c)	Equation 4
4.3.6	Bottom Elevation of Raised Gates	Reference 2.1.2, Elevation A-A and B-B	H _{bottom}	1786.4 feet
4.3.7	Height of Gates	Reference 2.1.4, Section B-B	V	5.0 feet
4.3.8	Top Elevation of Raised Gates	Bottom Elevation of Raised Gates plus the gate height	H _{top}	1791.4 feet
4.3A	Spillway gate parameters – Gates fail			
4.3A.1	Vertical opening	Reference 2.1.2, Elevation A-A and B-B, also Fig. 4	d	12 feet
4.3A.4	Headwater elevation at which gates fail	Justification in Section 3.3.2	H _T	1789.8 feet
4.3A.5	Orifice discharge coefficient	Estimated by Equation 4 in Section 3.3.3	C _O (H _c)	Equation 4
4.4	Spillway gate overflow			
4.4.1	Overflow discharge coeff.	Justification in Section 3.3.4	C _w	3.3
4.4.2	Overflow elevation – Gates Remain	Bottom Elevation of Raised Gates plus the gate height	Z _w	1791.4 feet
	Overflow elevation – Gates fail	Reference 2.1.2, Elevation D-D	Z _w	1790.4 feet
4.4.3	Overflow length	Reference 2.1.5, Plan View	L _w	325 feet
4.4A	Overflow weir Discharge – Gates remain	Justification in Section 3.3.4	Q _w	Equation 5
4.4B	Overflow weir Discharge – Gates fail	Justification in Section 3.3.4	Q _w	Equation 6
4.5	Tailwater Rating Curve			
4.5.1	TW vs. total discharge, Q	Reference 2.7	TW(Q)	Equation 7
4.6	Upper Limit on Headwater Elevation for Rating	Top of Dam Elevation	H _{max}	1807.5
4.7	Turbine Flow			
4.7.1	Turbine Flow when TW ≤ 1643 feet	Assumption 3.1.1 and Attachment 7	Q _T	1800 cfs
4.7.2	Turbine Flow when TW > 1643 feet	Assumption 3.1.1	Q _T	0 cfs

TVA

Calculation No. CDQ000020080016	Rev: 2	Plant: GEN	Page: 18
Subject: Dam Rating Curve, Nottely	Prepd: JBM		
	Checked: ACM		

4.8 Tailwater rating curve

The tailwater rating curve used in this calculation is shown in Attachment 1-1. Attachment 1-2 lists points scaled from this plot and shows a polynomial fit to the result. The polynomial indicated in Attachment 1-2 and repeated below is used for the dam rating curve calculations.

$$TW = 1611.1148 + 0.8083Q - 6.807 \times 10^{-3}Q^2 + 3.305 \times 10^{-5}Q^3 - 5.759 \times 10^{-8}Q^4 \quad (7)$$

in which Q = total discharge past the dam in cfs divided by 1000 ("1000 cfs").

5. Special Requirements/Limiting Conditions

N/A

TVA

Calculation No. CDQ000020080016	Rev: 2	Plant: GEN	Page: 19
Subject: Dam Rating Curve, Nottely	Prepd: JBM		
	Checked: ACM		

6. Calculations

The calculations consist of computing spillway and overflow discharges (from Equations 1 through 4) for a list of headwater elevations ranging from the minimum for which discharge exceeds zero up to 1807.5. The headwater rating curve is a plot of headwater elevation versus total dam discharge.

Table 2 shows the spreadsheet calculations for the headwater rating curve (spreadsheet included as Attachment 14). The final result, the rating curve, is defined by the first two columns, HW vs. Total Discharge and is shown in Figure 7.

The calculations presented in Table 2 are a reflection of the methodologies outlined in Section 3. The Free Flow column is computed using the spillway discharge curve shown in Figure 3 and represented by Equation 1. C_T is obtained by utilizing Equation 2 and the flow is calculated using Equation 1.

There are no particular calculations shown for the transition region. The geometry of this dam's crest and height of the spillway gates gives a transition area of less than 6". Therefore, it was judged that calculations would not be required in this region.

The orifice flow columns calculate the flow once the water level exceeds H_T and the flow transforms into orifice flow versus a free discharge as before. C_O is calculated utilizing Equation 4 and the flow is calculated by Equation 3.

The Overtopping Flow in Cases 1 and 1a is the flow over the tops of the raised gates. It is combined with the orifice flow in the final discharge rating curve as both flows will be occurring simultaneously. Flow is calculated using Equation 5. C_W for this case was selected as a constant value of 3.3 and is justified in Section 3.3.4.

The Overtopping Flow in Case 2 is the flow over the top of the gate machinery at a headwater elevation of 1790.4 feet when the gates fail. It is combined with the orifice flow in the final discharge rating curve as both flows will be occurring simultaneously. Flow is calculated using Equation 6. C_W for this case was selected as a constant value of 3.3 and is justified in Section 3.3.4.

The turbine flow is calculated as outlined in Assumption 3.1.1 and section 4.7

The Total Discharge column provides the final discharge curve values in 1000 cfs and is simply a summation of flows in the appropriate flow regimes as outlined above.

Table 3 shows the calculations for case 1a which are performed identical to case 1 with the omission of the turbine flow.

Table 4 shows the calculations for Case 2 which are performed similar to Case 1a but with gate failure.

TVA

Calculation No. CDQ000020080016	Rev: 1	Plant: GEN	Page: 20
Subject: Dam Rating Curve, Nottely	Prepd: A.T. Tinsley		
	Checked: SEM		

Nottely Dam Headwater Rating Curve - With Turbine Flow

Spill Way Parameters

L= 300 feet
 Z_c= 1775 feet
 d= 11.4 feet
 L_w= 325 feet

HW Elev (feet)	Total Discharge (1000 cfs)	TW Elev (feet)	Hc (feet)	d/Hc	Free Flow	Orifice Flow		Overtopping Flow		Turbine Flow
					Q _F (cfs)	C _O	Q _O (cfs)	C _w	Q _w (cfs)	Q _T (cfs)
1775	1.80	1612.5	0	0.00	0	-	0	-	0	1800
1777	4.54	1614.6	2	5.70	2735	-	0	-	0	1800
1779	9.88	1618.5	4	2.85	8079	-	0	-	0	1800
1781	17.28	1623.2	6	1.90	15477	-	0	-	0	1800
1783	26.33	1628.3	8	1.43	24535	-	0	-	0	1800
1785	36.82	1633.2	10	1.14	35017	-	0	-	0	1800
1786.4	44.96	1636.5	11.4	1.00	43155	-	0	-	0	1800
1787	48.65	1637.8	12	0.95	46848	-	0	-	0	1800
1789	61.91	1642.1	14	0.81	60113	-	0	-	0	1800
1789.8	65.87	1643.2	14.8	0.77	65870	-	0	-	0	0
1791.29	56.95	1640.6	16.29	0.70	0	0.6459	56950	-	0	0
1791.4	57.31	1640.7	16.4	0.70	0	0.6464	57305	-	0	0
1793	64.43	1642.8	18	0.63	0	0.6529	62258	3.3	2171	0
1795	75.31	1645.6	20	0.57	0	0.6596	67984	3.3	7326	0
1797	87.51	1648.5	22	0.52	0	0.6650	73300	3.3	14213	0
1799	100.75	1651.3	24	0.48	0	0.6695	78283	3.3	22471	0
1801	114.89	1654.2	26	0.44	0	0.6734	82988	3.3	31901	0
1803	129.83	1657.3	28	0.41	0	0.6767	87455	3.3	42373	0
1805	145.51	1660.6	30	0.38	0	0.6795	91718	3.3	53791	0
1807	161.88	1664.2	32	0.36	0	0.6820	95801	3.3	66082	0
1807.5	166.08	1665.2	32.5	0.3508	0	0.6826	96796	3.3	69285	0

Table 2 – Case 1 Calculation

TVA

Calculation No. CDQ000020080016	Rev: 1	Plant: GEN	Page: 21
Subject: Dam Rating Curve, Nottely	Prepd: A.T. Tinsley		
	Checked: SEM		

Nottely Dam Headwater Rating Curve - No Turbine Flow

Spill Way Parameters

L= 300 feet
 Z_c= 1775 feet
 d= 11.4 feet
 L_w= 325 feet

HW Elev (feet)	Total Discharge (1000 cfs)	TW Elev (feet)	Hc (feet)	d/Hc	Free Flow	Orifice Flow		Overtopping Flow	
					Q _F (cfs)	C _O	Q _O (cfs)	C _w	Q _w (cfs)
1775	0.00	1611.1	0	0.00	0	-	0	-	0
1777	2.74	1613.3	2	5.70	2735	-	0	-	0
1779	8.08	1617.2	4	2.85	8079	-	0	-	0
1781	15.48	1622.1	6	1.90	15477	-	0	-	0
1783	24.53	1627.3	8	1.43	24535	-	0	-	0
1785	35.02	1632.4	10	1.14	35017	-	0	-	0
1786.4	43.16	1635.8	11.4	1.00	43155	-	0	-	0
1787	46.85	1637.2	12	0.95	46848	-	0	-	0
1789	60.11	1641.5	14	0.81	60113	-	0	-	0
1789.8	65.87	1643.2	14.8	0.77	65870	-	0	-	0
1791.29	56.95	1640.6	16.29	0.70	0	0.6459	56950	-	0
1791.4	57.31	1640.7	16.4	0.70	0	0.6464	57305	-	0
1793	64.43	1642.8	18	0.63	0	0.6529	62258	3.3	2171
1795	75.31	1645.6	20	0.57	0	0.6596	67984	3.3	7326
1797	87.51	1648.5	22	0.52	0	0.6650	73300	3.3	14213
1799	100.75	1651.3	24	0.48	0	0.6695	78283	3.3	22471
1801	114.89	1654.2	26	0.44	0	0.6734	82988	3.3	31901
1803	129.83	1657.3	28	0.41	0	0.6767	87455	3.3	42373
1805	145.51	1660.6	30	0.38	0	0.6795	91718	3.3	53791
1807	161.88	1664.2	32	0.36	0	0.6820	95801	3.3	66082
1807.5	166.08	1665.2	32.5	0.3508	0	0.6826	96796	3.3	69285

Table 3 – Case 1a Calculation

Calculation No. CDQ000020080016	Rev: 2	Plant: GEN	Page: 22
Subject: Dam Rating Curve, Nottely	Prepd: JBM		
	Checked: ACM		

Nottely Dam Headwater Rating Curve - Gate Failure Without Turbine Flow

Spill Way Parameters

L= 300 feet
 Z_c= 1775 feet
 d= 11.4 feet
 d= 12 feet (bottom of walkway at 1781.0') after gates fail at HW = 1789.8'
 L_w= 325 feet

HW Elev (feet)	Total Discharge (1000 cfs)	TW Elev (feet)	Hc (feet)	d/Hc	Free Flow	Orifice Flow		Overtopping Flow	
					Q _F (cfs)	C _O	Q _O (cfs)	C _w	Q _w (cfs)
1775	0.00	1611.1	0	0.00	0	-	0	-	0
1777	2.74	1613.3	2	5.70	2735	-	0	-	0
1779	8.08	1617.2	4	2.85	8079	-	0	-	0
1781	15.48	1622.1	6	1.90	15477	-	0	-	0
1783	24.53	1627.3	8	1.43	24535	-	0	-	0
1785	35.02	1632.4	10	1.14	35017	-	0	-	0
1786.4	43.16	1635.8	11.4	1.00	43155	-	0	-	0
1787	46.85	1637.2	12	0.95	46848	-	0	-	0
1789	60.11	1641.5	14	0.81	60113	-	0	-	0
1789.8	65.87	1643.2	14.8	0.77	65870	-	0	-	0
1790	52.28	1639.1	15	0.80	0	0.6354	52280	-	0
1790.4	53.66	1639.5	15.4	0.78	0	0.6376	53656	-	0
1791	56.16	1640.3	16	0.75	0	0.6407	55663	3.3	498
1792	61.04	1641.8	17	0.71	0	0.6453	58868	3.3	2171
1793	66.42	1643.3	18	0.67	0	0.6494	61924	3.3	4496
1795	78.24	1646.4	20	0.60	0	0.6564	67660	3.3	10581
1797	91.17	1649.3	22	0.55	0	0.6621	72985	3.3	18185
1799	105.02	1652.2	24	0.50	0	0.6669	77976	3.3	27049
1801	119.70	1655.2	26	0.46	0	0.6709	82689	3.3	37013
1803	135.13	1658.4	28	0.43	0	0.6744	87165	3.3	47968
1805	151.27	1661.9	30	0.40	0	0.6774	91434	3.3	59831
1807	168.06	1665.6	32	0.38	0	0.6800	95524	3.3	72537
1807.5	172.36	1666.6	32.5	0.37	0	0.6806	96521	3.3	75839

Table 4 – Case 2 Calculation

TVA

Calculation No. CDQ000020080016	Rev: 2	Plant: GEN	Page: 23
Subject: Dam Rating Curve, Nottely	Prepd: JBM		
	Checked: ACM		

7. Results/Conclusions

For convenience, the headwater rating results, separate from the calculation details provided above, are tabulated as total discharge in cfs vs. headwater elevation in feet in Table 5. The headwater rating curve is plotted in Figure 8.

Note the discontinuity that appears in Figure 8 at a headwater elevation of just under 1790.4'. This is the result of the flow transitioning from free flow over the dam crest to orifice flow through the flood gates. The discontinuity was anticipated and is typical for this type of flow transition.

The headwater rating curves developed in this calculation provide Nottely total dam discharge vs. headwater elevation for use in TVA's SOCH and TRBROUTE models for simulation conditions satisfying the assumptions in [3.1]. In particular, the spillway gates must all be fully raised.

TVA

Calculation No. CDQ000020080016	Rev: 2	Plant: GEN	Page: 24
Subject: Dam Rating Curve, Nottely	Prepd: JBM		
	Checked: ACM		

Case 1		Case 1a		Case 2	
HW (ft)	Discharge (1000 cfs)	HW	Discharge (1000 cfs)	HW	Discharge (1000 cfs)
1775	1.80	1775	0.00	1775	0.00
1777	4.54	1777	2.74	1777	2.74
1779	9.88	1779	8.08	1779	8.08
1781	17.28	1781	15.48	1781	15.48
1783	26.33	1783	24.53	1783	24.53
1785	36.82	1785	35.02	1785	35.02
1786.4	44.96	1786.4	43.16	1786.4	43.16
1787	48.65	1787	46.85	1787	46.85
1789	61.91	1789	60.11	1789	60.11
1789.8	65.87	1789.8	65.87	1789.8	65.87
1791.29	56.95	1791.29	56.95	1790	52.28
1791.4	57.31	1791.4	57.31	1790.4	53.66
1793	64.43	1793	64.43	1791	56.16
1795	75.31	1795	75.31	1792	61.04
1797	87.51	1797	87.51	1793	66.42
1799	100.75	1799	100.75	1795	78.24
1801	114.89	1801	114.89	1797	91.17
1803	129.83	1803	129.83	1799	105.02
1805	145.51	1805	145.51	1801	119.70
1807	161.88	1807	161.88	1803	135.13
1807.5	166.08	1807.5	166.08	1805	151.27
				1807	168.06
				1807.5	172.36

Table 5 – Headwater Rating Results

Calculation No. CDQ000020080016	Rev: 2	Plant: GEN	Page: 25
Subject: Dam Rating Curve, Nottely	Prepd: JBM		
	Checked: ACM		





Figure 8 – Headwater Rating Curves

Nottely Tailwater Rating




Nottely Tailwater Rating

Points from Riverware Rating from Attachment 1-1


This Page Added in R1

Riverware Rating			TW
Q*1000	Q	Elevation	Fit
0	0	1606.55	1611.115
0.05	50	1606.66	1611.155
1.4	1,400	1611.5	1612.233
3	3,000	1617	1613.479
5	5,000	1619	1614.99
10	10,000	1622	1618.55
20	20,000	1626.5	1624.813
30	30,000	1630.5	1630.083
40	40,000	1633.6	1634.523
50	50,000	1636.8	1638.284
60	60,000	1640.1	1641.5
75	75,000	1644.5	1645.568
100	100,000	1651.4	1651.165
125	125,000	1657.2	1656.281
150	150,000	1662.7	1661.586
175	175,000	1667.7	1667.208
200	200,000	1672	1672.735
225	225,000	1676	1677.216
250	250,000	1680	1679.159

$$TW = -5.759 \times 10^{-8} Q^4 + 3.305 \times 10^{-5} Q^3 - 6.807 \times 10^{-3} Q^2 + 0.8083Q + 1611.1148$$
 Where TW = Tailwater Elevation in Feet
 Q = Discharge through Dam in 1000 cfs



Source: Reference 2.4



TENNESSEE VALLEY AUTHORITY
 HYDRAULIC DATA DIVISION
 HYDRAULIC LABORATORY SECTION

SPILLWAY DISCHARGE STUDIES
 NOTTELY PROJECT
 RATING CURVE

NOVEMBER 4, 1942 ASF-590


DRAWN BY: MAIB-5921
CHECKED BY:

SUBMITTED *[Signature]*
 APPROVED *[Signature]*
 APPROVED *[Signature]*

4 Source: Reference 2.2

NOTTELY DAM

LOCATION OF SPILLWAY GATES



NOTTELY DAM

SPILLWAY GATE ARRANGEMENTS

Arrange-ment Number	Gate Number																																																								
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50							
1	R	-	R	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-						
2	R	R	-	R	-	R	-	R	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-					
3	R	R	-	R	-	R	-	R	-	R	-	R	-	R	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
4	R	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R			
5	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R		
6	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R		
7	R	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	
8	R	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	
9	R	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	
10	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R
11	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R
12	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R
13	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R
14	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R
15	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R
16	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R
17	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R
18	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R
19	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R
20	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R
21	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R
22	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R
23	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R
24	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R
25	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R	R

GATE OPENINGS

Figures in columns under each gate number refer to gate opening indicator reading
dash (-) indicates closed gate
"R" indicates gate raised above water surface and dogged
"R" indicates first use of each gate




Figure 257. Coefficient of discharge for flow under gates. 288-D-2417.

is the inflow per foot of length of weir crest. The momenta³ at the two sections therefore will be:

$$\text{Upstream, } M_u = \frac{Qv}{g} \quad (8)$$

$$\text{Downstream, } M_d = \frac{[Q + q(\Delta x)]}{g} [v + \Delta v] \quad (9)$$

Subtracting equation (8) from equation (9):

$$\Delta M = \frac{Q(\Delta v)}{g} + \frac{q(\Delta x)}{g} [v + \Delta v] \quad (10)$$

Dividing by Δx :

$$\frac{\Delta M}{\Delta x} = \frac{Q(\Delta v)}{g(\Delta x)} + \frac{q}{g} [v + \Delta v] \quad (11)$$

³ The weight of 1 cubic foot of water is taken as a unit force to eliminate the necessity of multiplying all forces and momenta by 62.5 to convert them into pounds.


The rate of change of momentum with respect to time being v times the rate of change with respect to x , and considering the average velocity to be $[v + \frac{1}{2}(\Delta v)]$, equation (11) can be written:

locity to be $[v + \frac{1}{2}(\Delta v)]$, equation (11) can be written:

$$\frac{\Delta M}{\Delta t} = \frac{Q(\Delta v)}{g(\Delta x)} [v + \frac{1}{2}(\Delta v)] + \frac{q}{g} [v + \Delta v] [v + \frac{1}{2}(\Delta v)] \quad (12)$$

As $\frac{\Delta M}{\Delta t}$ is the accelerating force, which is equal to the slope of the water surface $\frac{\Delta y}{\Delta x}$ times the average discharge, equation (12) becomes:

$$\frac{\Delta y}{\Delta x} [Q + \frac{1}{2}(\Delta Q)] = \frac{Q(\Delta v)}{g(\Delta x)} [v + \frac{1}{2}(\Delta v)] + \frac{q}{g} [v + \Delta v] [v + \frac{1}{2}(\Delta v)] \quad (13)$$



Source: Reference 2.8

RESERVOIR RELEASES IMPROVEMENTS

The aeration and minimum flow equipment at Nottely Dam is part of the implementation of TVA's Lake Improvement Plan (LIP) approved by the Board of Directors in 1991. One of the goals of the Lake Improvement Plan is to improve the dissolved oxygen (DO) levels and minimum flows of the releases of 16 dams. Minimum flow releases of 55 cfs at Nottely were obtained by the installation of a small hydroturbine unit which is operated whenever the main unit is off. At Nottely testing showed the target minimum DO content of the release (4 mg/L) to be best achieved by the installation of air injection equipment. Blower and compressor systems inject air at the large and small hydroturbines respectively. The blower system consists of two blowers (250 hp each), controls, piping, and valves designed to inject air into the water flow through the large unit. The air compressor system consists of two air compressors, controls, piping, and valves designed to inject air into the flow through the small unit. The air compressors are rated at 25 hp each.

SAFETY MODIFICATIONS FOR PROBABLE MAXIMUM FLOOD

Chronology

Safety analysis studies for Chatuge Dam for the probable maximum flood (PMF) were started on July 29, 1976, and completed in May 1984. Final design was completed in January 1988. Onsite construction began in July 1986, and was completed on June 20, 1988.

Cost of Modifications

Design costs for the capital safety modifications to Chatuge Dam were \$1,520,000. Construction costs were \$13,680,000. The total project cost was \$15,200,000. This total does not include costs for dam safety evaluation studies which resulted in the modifications.



Controlling Features

The embankments at Nottely were modified in order to safety pass the probable maximum flood. The embankments were raised to elevation 1807 by the addition of rockfill. A new bridge was built with a 30 ft. width of asphalt roadway. These PMF modifications will prevent overtopping and erosion of the embankments and thus prevent breach and failure of the dam.

RESERVOIR AND POWER DATA

Nottely			Best Efficiency				Maximum Sustainable		
Elevation (feet)	Area (acre*1000)	Volume (ac-ft*1000)	Gross Head (feet)	Plant Output (mW)	Turbine Discharge (cfs)	kW/CFS	Plant Output (mW)	Turbine Discharge (cfs)	kW/CFS
1780	4.32	174.3	167.4	17.2	1,390	12.44	20.0	1,630	12.25
1779	4.18	170.1	166.4	17.1	1,390	12.35	20.0	1,650	12.16
1778	4.05	165.9	165.4	17.0	1,390	12.26	20.0	1,660	12.06
1777	3.93	162.0	164.3	16.9	1,390	12.17	20.0	1,670	11.96
1776	3.83	158.1	163.3	16.8	1,390	12.08	20.0	1,690	11.86
1775	3.73	154.3	162.3	16.7	1,400	11.99	20.0	1,700	11.76
1774	3.65	150.6	161.2	16.6	1,400	11.90	20.0	1,710	11.66
1773	3.56	147.0	160.2	16.5	1,400	11.81	20.0	1,730	11.56
1772	3.48	143.5	159.2	16.4	1,400	11.72	19.9	1,740	11.46
1771	3.39	140.0	158.2	16.3	1,400	11.62	19.8	1,740	11.36
1770	3.31	136.7	157.1	16.2	1,410	11.53	19.7	1,750	11.26
1769	3.23	133.4	156.1	16.1	1,410	11.44	19.6	1,760	11.15
1768	3.15	130.2	155.1	16.0	1,410	11.34	19.5	1,760	11.05
1767	3.07	127.1	154.1	15.9	1,410	11.25	19.4	1,770	10.95
1766	2.99	124.1	153.1	15.8	1,420	11.16	19.3	1,780	10.85
1765	2.92	121.1	152.1	15.7	1,420	11.06	19.2	1,790	10.75
1764	2.85	118.3	151.0	15.6	1,420	10.97	19.1	1,790	10.65
1763	2.78	115.4	150.0	15.5	1,420	10.88	19.0	1,800	10.54
1762	2.71	112.7	149.0	15.4	1,430	10.81	18.9	1,800	10.49
1761	2.65	110.0	148.0	15.3	1,430	10.73	18.8	1,800	10.43
1760	2.59	107.4	147.0	15.2	1,430	10.66	18.7	1,800	10.38
1759	2.53	104.8	146.0	15.1	1,430	10.59	18.6	1,800	10.33
1758	2.47	102.3	145.0	15.0	1,430	10.52	18.5	1,800	10.27
1757	2.42	99.9	144.0	14.9	1,430	10.45	18.4	1,800	10.22
1756	2.36	97.5	143.0	14.8	1,430	10.38	18.3	1,800	10.16
1755	2.31	95.2	142.0	14.7	1,430	10.31	18.2	1,800	10.11
1754	2.26	92.9	141.0	14.6	1,430	10.24	18.1	1,800	10.06
1753	2.21	90.6	140.0	14.5	1,430	10.17	18.0	1,800	10.00
1752	2.17	88.4	139.0	14.4	1,420	10.11	17.8	1,790	9.94

NOTE: Energy in storage data not included



- NOTES:**
- 1. COMPONENT UNIT NUMBERING SCHEME:
NAME UNIT FUNCTION SYSTEM STORAGE WA.
NTH SP DAM SIZE STRUCT
 - 2. UNITS ARE LISTED IN WHOLE ON THIS DRAWING WHEN IT IS PRACTICAL. OTHER COMPONENT UNITS ONLY LIST THE SEQUENCE NUMBER TO FIT ON THIS PAGE FOR EXAMPLE TO NAME THE COMPLETE UNIT NUMBER FOR AN INTAKE TOWER AND THE PREFIX "SP-DAM-210" TO THE SEQUENCE NUMBER.
 - 3. COMPONENT UNIT NUMBERS USE THE FOLLOWING SYSTEM AND FUNCTION CODES:
SYSTEM NUMBER - SYSTEM NAME
110 = SLUICE GENERATOR SYSTEM DAM - DAM STRUCTURE
300 = FACILITIES & GROUNDS BLDG - POWERHOUSE
303 = GRADING & HOISTS CRN - SLUICE GENERATOR
323 = INTAKE SYSTEM INT - INTAKE
328 = DAM CRN - GRADE
338 = SPILLWAY TRM - TRUSS BRACK
SIR - SPILLWAY
GAT - SPILLWAY GATE
 - 4. FOR PROBABLE MAXIMUM FLOOD MODIFICATIONS, SEE DRAWINGS 10W203-SERIES - MAIN DAM FUNDAMENTAL MODIFICATIONS.

REVISIONS

NO.	DATE	DESCRIPTION	BY	CHKD
1	02/20/00	ISSUE FOR CONSTRUCTION	J.F.W.	S.O.C.
2	02/20/00	ISSUE FOR CONSTRUCTION	J.F.W.	S.O.C.

REFERENCE DRAWINGS:
10W203 - SLUICE GENERATOR

SCALE 1" = 200'

SCALE 300' = 1" PLAN & ELEVATION

SCALE 60' = 1" SECTIONS A-A, B-B & C-C

SCALE 50' = 1" SECTIONS D-D, E-E & F-F

MAIN DAM WORKS

**GENERAL PLAN
ELEVATION AND SECTION**


PROJECT NO.: J.F.W. / S.O.C. / W.R.B. / M.L.D. / G.H.R. / T.B.P.

NOTEL PROJECT
TENNESSEE VALLEY AUTHORITY
FRESH AND HYBRID ENGINEERING

AUTOCAD R 2000 9-12-01 18 c TOW200 R 10

ELECTRONICALLY RESTORED DRAWING
THIS DRAWING HAS BEEN COMPLETELY RE-DRAWN
AND SUPERSEDES (105200 R16)

PLOT FACTOR: 2400
R. IVA
C.A.D. DRAWING
DO NOT ALTER MANUALLY



- NOTES
1. ALL GREASE BUSHINGS TO HAVE FIGURE 8 GREASE GROOVES INSIDE A MINIMUM SPODES ON FLANGES AND BUSHINGS TO HAVE ADA CLASSE 1C. FIT IN HOLES & CLASS 888 FIT IN HOLES WITH CLASS 888 PER ADA STD. 34. 1-1986. PREFERRED LIMITS A FIT FOR CYLINDRICAL PARTS. BRASS SCREWS TO HOLD BUSHINGS FROM TURNING IN HOLES. ALL BOLT HEADS & NUTS TO BE AMERICAN STD. MODULAR SERIES. FINISHED HEXAGON ALL THREAD TO BE AMERICAN STD. COARSE THREAD SERIES. CLASS 2A FIT FOR BOLTS & CLASS 888 FIT FOR NUTS.
 2. FOR MANUFACTURER'S DETAILS OF GANTRY CRANE SEE CYCLOPS BROW MONS FILE, TRC CONTRACT NO. 83C34-30327.
 3. FOR FIELD TO FURNISH MATERIALS & INSTALL AT CONCRETE LOCATIONS FOR: 1) TYING DOWN LIFTING BEAM ON CRANE DECK FOR STORAGE; 2) MISSING GATE; 3) TYPING POSITION SHOWN IN A-4, B-3) PREVENTING CRANE MOVEMENT WHEN NOT IN USE.
- COMPONENT UNITS NUMBERING SCHEME
- | PLANT | UNIT | FUNCTION | SYSTEM | SEQUENCE NO. |
|-------|------|----------|--------|--------------|
| 18 | SH | HST | 338 | 001 |
| 18 | SH | HST | 338 | 002 |
| 18 | SH | HST | 338 | 003 |
| 18 | SH | HST | 338 | 004 |
| 18 | SH | HST | 338 | 005 |
| 18 | SH | HST | 338 | 006 |
| 18 | SH | HST | 338 | 007 |
| 18 | SH | HST | 338 | 008 |
| 18 | SH | HST | 338 | 009 |
| 18 | SH | HST | 338 | 010 |
| 18 | SH | HST | 338 | 011 |
| 18 | SH | HST | 338 | 012 |
| 18 | SH | HST | 338 | 013 |
| 18 | SH | HST | 338 | 014 |
| 18 | SH | HST | 338 | 015 |
| 18 | SH | HST | 338 | 016 |
| 18 | SH | HST | 338 | 017 |
| 18 | SH | HST | 338 | 018 |
| 18 | SH | HST | 338 | 019 |
| 18 | SH | HST | 338 | 020 |
| 18 | SH | HST | 338 | 021 |
| 18 | SH | HST | 338 | 022 |
| 18 | SH | HST | 338 | 023 |
| 18 | SH | HST | 338 | 024 |
| 18 | SH | HST | 338 | 025 |
| 18 | SH | HST | 338 | 026 |
| 18 | SH | HST | 338 | 027 |
| 18 | SH | HST | 338 | 028 |
| 18 | SH | HST | 338 | 029 |
| 18 | SH | HST | 338 | 030 |
- UNITS ARE LISTED IN INCHES ON THIS DRAWING.
- COMPONENT UNITS NUMBERS USE THE FOLLOWING SYSTEM AND FUNCTION CODES:
- | SYSTEM NUMBER | FUNCTION CODE | FUNCTION CODE NAME |
|---------------|---------------|---------------------------|
| 338 | 001 | HST - SPILLWAY GATE HOIST |

DATE	BY	CHKD	APPD	REV	DESCRIPTION
11/11/16	18 SH	18 SH	18 SH	1	ISSUED FOR CONSTRUCTION
11/11/16	18 SH	18 SH	18 SH	2	REVISED FOR CONSTRUCTION
11/11/16	18 SH	18 SH	18 SH	3	REVISED FOR CONSTRUCTION
11/11/16	18 SH	18 SH	18 SH	4	REVISED FOR CONSTRUCTION
11/11/16	18 SH	18 SH	18 SH	5	REVISED FOR CONSTRUCTION
11/11/16	18 SH	18 SH	18 SH	6	REVISED FOR CONSTRUCTION
11/11/16	18 SH	18 SH	18 SH	7	REVISED FOR CONSTRUCTION
11/11/16	18 SH	18 SH	18 SH	8	REVISED FOR CONSTRUCTION
11/11/16	18 SH	18 SH	18 SH	9	REVISED FOR CONSTRUCTION
11/11/16	18 SH	18 SH	18 SH	10	REVISED FOR CONSTRUCTION
11/11/16	18 SH	18 SH	18 SH	11	REVISED FOR CONSTRUCTION
11/11/16	18 SH	18 SH	18 SH	12	REVISED FOR CONSTRUCTION

SCALE: 3'-1'-0"

EXCEPT AS NOTED


SPILLWAY

2 TON GANTRY CRANE ARRANGEMENT & DETAILS

NOTELY PROJECT
TENNESSEE VALLEY AUTHORITY
PLANT AND WORK NUMBERING

AUTOCAD 2000 11/11/16 18 SH 54W320 R 3

Source: Reference 2.1.3



NOTE:
FIELD TO SLOPE BORROW AREAS ± 2% FOR DRAINAGE

NOTE A1:
TOWNSHIP BERM AT EL. 1775 SHALL BE CHANGED WITH COARSE FILTER MATERIAL AS REQUIRED TO PROVIDE ACCESS ALONG THIS BERM FOR PLANT VEHICLES.

NOTE B1:
FIELD TO LOCATE ACCESS ROAD APPROXIMATELY AS SHOWN WITH A MAXIMUM GRADE OF 10%.

NOTE C1:
FIELD SHALL EXTEND EXISTING PIEZOMETERS 5.0' ABOVE EXISTING SLOPE OF RAISED DAM. FIELD TO PROVIDE THE SAME TYPE OF MATERIAL USED IN THE ORIGINAL INSTALLATION. SEE DETAIL A1 AS SPECIAL CARE TO BE TAKEN IN REMOVING EXISTING FACE OF DAM AND IN PLACING NEW EMBANKMENT AROUND PIEZOMETERS.

NOTE F1:
AFTER STRIPPING, PLACE 10' COARSE FILTER. SEE NOTE 6. PRIOR TO PLACING RIPRAP AND QUARRY RUN ROCK.


NOTE D1:
TOP OF RAISED EMBANKMENT EL. VARIES 1807.5 TO 1808.0 FROM GRADING OF TOP OF EMBANKMENT. SEE 21E200 AND 21E202.

NOTE E1:
FOR DETAILS OF EXISTING EMBANKMENT, SEE 21E200 AND 21E202.


NOTES:
1. FOR GENERAL NOTES SEE 21E205-3.
2. FOR POSITION OF SLICE GENERATOR TO BEGIN IN 1993, SEE 10E004-1 AND 2.

COMPANION DRAWINGS: 21E205-2 & 21E205-3	
DATE: 11/16/93	BY: [Signature]
SCALE: 1"=30'	EXCEPT AS NOTED
MAIN EMBANKMENT	
INCREASE HEIGHT OF DAM PLAN, SECTIONS & DETAILS	
DESIGNED BY: B. PARKS	CHECKED BY: A. BOYD
ENGINEERED BY: C. VARNER	APPROVED BY: B. HENRY
NOTED BY: J. BARNETT	
DRAWN BY: S. BUCHANAN	
PROJECT: HOTEL PROJECT TENNESSEE VALLEY AUTHORITY	
FOSSIL AND HYDRO ENGINEERING	
AUTOCAD R12	2-20-96 18 C 21E205-1 R 4
ELECTRONICALLY RESTORED DRAWING THIS DRAWING HAS BEEN COMPLETELY RE-DRAWN AND SUPERSEDES (1-21E205-1) (3)	
PLOT FACTOR: 360 E.T.V.	
C & G DRAWING DO NOT ALTER MANUALLY	

Source: Reference 2.1.4



SPILLWAY		
GATES & LIFTING BEAMS ARRANGEMENT & DETAILS		
NOTTLEY PROJECT		
TENNESSEE VALLEY AUTHORITY		
DIVISION OF DESIGN		
SUBMITTED	RECOMMENDED	APPROVED
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>
INNOVATION	10-19-99	SH 4 54N510a
RECORD DRAWING AS CONTRACTOR		



NOTES:
 All piece marks to have per 58N203-1
 For steel in place refer to 58N203-1
 All work not noted to be 58N203-1
 Note 1:
 In cutting existing concrete for crane leg clearance, care shall be taken to avoid overbreak. Dimensions shown are finished outside. Result of form and plaster with good mortar to finished dimensions. Cut surface shall be thoroughly sanded with water before mortar is applied. Clean face edges.
 For mfr's details refer to Nashville Bridge Co. Inc. TVA contract 60C52-3525.

FOR 1991 REVISION SEE,
 58N203-1 & 58N203-2

Scale 1/4"=0'
 Except as noted


SPILLWAY

**STRUCTURAL STEEL
 GATE GUIDES & HOIST TRACK**

**NOTTELY PROJECT
 TENNESSEE VALLEY AUTHORITY
 DIVISION OF DESIGN**

SUBMITTED 9.8.90	RECOMMENDED 9.11.90	APPROVED 9.11.90
KNOXVILLE	9 28 90	18 5H * 58N202-R1

SECOND DRAWING AS CONSTRUCTED



FEB 11 2006

NO. 1	REVISED TO SHOW 10" DIA. PENETRATOR AND 3" DIA. S.C. ACCESS	DATE	BY	CHKD BY	APP'D BY
NO. 2	REVISED TO SHOW 10" DIA. PENETRATOR AND 3" DIA. S.C. ACCESS	DATE	BY	CHKD BY	APP'D BY
NO. 3	REVISED TO SHOW 10" DIA. PENETRATOR AND 3" DIA. S.C. ACCESS	DATE	BY	CHKD BY	APP'D BY
NO. 4	REVISED TO SHOW 10" DIA. PENETRATOR AND 3" DIA. S.C. ACCESS	DATE	BY	CHKD BY	APP'D BY
NO. 5	REVISED TO SHOW 10" DIA. PENETRATOR AND 3" DIA. S.C. ACCESS	DATE	BY	CHKD BY	APP'D BY
NO. 6	REVISED TO SHOW 10" DIA. PENETRATOR AND 3" DIA. S.C. ACCESS	DATE	BY	CHKD BY	APP'D BY
NO. 7	REVISED TO SHOW 10" DIA. PENETRATOR AND 3" DIA. S.C. ACCESS	DATE	BY	CHKD BY	APP'D BY
NO. 8	REVISED TO SHOW 10" DIA. PENETRATOR AND 3" DIA. S.C. ACCESS	DATE	BY	CHKD BY	APP'D BY
NO. 9	REVISED TO SHOW 10" DIA. PENETRATOR AND 3" DIA. S.C. ACCESS	DATE	BY	CHKD BY	APP'D BY
NO. 10	REVISED TO SHOW 10" DIA. PENETRATOR AND 3" DIA. S.C. ACCESS	DATE	BY	CHKD BY	APP'D BY
NO. 11	REVISED TO SHOW 10" DIA. PENETRATOR AND 3" DIA. S.C. ACCESS	DATE	BY	CHKD BY	APP'D BY
NO. 12	REVISED TO SHOW 10" DIA. PENETRATOR AND 3" DIA. S.C. ACCESS	DATE	BY	CHKD BY	APP'D BY

POWERHOUSE

GENERAL ARRANGEMENT
PLANS & SECTIONS

DESIGNED BY	DRAWN BY	CHECKED BY	APPROVED BY	DATE

NOTELLY PROJECT
TENNESSEE VALLEY AUTHORITY
FOSSIL AND HYDRO ENGINEERING DIV.

OFFICIAL ROOM NO. 15-3-03 18 | C 41W600 R 7

ELECTRONICALLY RESTORED DRAWING
THIS DRAWING HAS BEEN COMPLETELY REDRAWN
AND SUPERSEDES (4376500.RB)

PLOT FACTOR: 86
SCALE: 1/8" = 1'-0"

C.A.R. DRAWING
DO NOT ALTER MANUALLY

**TENNESSEE VALLEY AUTHORITY
RIVER SYSTEM OPERATIONS & ENVIRONMENT
RIVER OPERATIONS**

NOTTELY DAM

SPILLWAY DISCHARGE TABLES

APRIL 2004

CONTENTS

	Page
Instructions for Use of Tables.....	2
Location of Spillway Gates.....	4
Spillway Gate Arrangement Tables	5
Spillway Discharge Tables	6-10
 Headwater Range	
1775 - 1777	6
1777 - 1779	7
1779 - 1781	8
1781 - 1783	9
1783 - 1789	10

INSTRUCTIONS FOR USE OF TABLES

1. Tables Update

These tables supersede the tables issued in January 1961. The revised discharges, which are only slightly different from those in the 1961 tables, were generated using the computer code SPILLQ. SPILLQ is a computer code used in TVA software for monitoring spill discharges and determining gate arrangements.

2. Purpose of Tables

These tables provide a means for setting required spillway discharges and for determining the discharge when a specific arrangement of gates is in use. The tabulated discharges are based on test results from a 1:45 scale model of Nottely spillway supplemented by prototype measurements, which were used to establish the lower end of the rating.

The specific gate arrangements in the tables were determined from model tests in which consideration was given to obtaining satisfactory flow conditions throughout the length of the spillway chute. Any deviation from the specified arrangements may cause overtopping of the chute walls.

3. Range of Tables

The tables cover a discharge range from 0 to 60,040 cubic feet per second. Headwater elevations range from 1775 feet to 1789 feet. The tailwater does not affect the discharges from this spillway.

4. Arrangement of Tables

The tables show spillway discharges in cubic feet per second. Headwater elevations in 0.1-foot increments are shown at the top of

each column. The headwater range is shown at the bottom of each page.

The discharge is tabulated under the headwater elevations for specific arrangements of gate openings, which are indicated by number in the left and right columns of each page. The numbered arrangements are defined in the table of Spillway Gate Arrangements on page 5. Reference to this table and to the drawing showing the location of the gates on page 4 will determine the gates to be raised for any particular discharge given in the tables.

5. Discharge Intervals

The tables have been prepared so that the incremental discharge between the tabulated values for consecutive gate arrangements is adequate for all situations. Therefore it will not be necessary to interpolate between values given in these tables.

When the exact headwater elevation does not appear in the tables, the discharge for the headwater elevation closest to it is used. For example, the column headed 1776.2 is used for actual headwater elevations between 1776.15 feet and 1776.24 feet inclusive. When the actual headwater elevation is exactly halfway between tabular values, the larger value is used.

6. Spillway Gate Operation

The spillway gates are used to control discharges up to headwater elevation 1780 feet, which is the top elevation of the closed gates. To prevent gate overflow, all spillway gates should be raised before the headwater elevation exceeds 1780 feet. However, to provide for accidental operation in which some gates have not been raised, the tabulated discharges include the total discharge, under the raised

gates and over the closed gates, for headwater elevations from 1780 feet to 1783 feet.

Either one or two cranes may be used to open and close the spillway gates. It has been estimated that all gates can be raised in approximately 3 hours using one crane and in 1½ hours using two cranes.

7. Use of Tables

The tables can be used in two ways: (1) to determine the arrangement of gates needed to pass a required discharge at a given headwater elevation, and (2) to determine the discharge for a given arrangement of gates and headwater elevation.

Example 1 -- What gate arrangement is necessary to pass a discharge of 1,000 cubic feet per second with the headwater at elevation 1777.84 feet?

The first step is to find the table in which the headwater elevation appears. Referring to the contents page, we find that headwater elevations between 1777 feet and 1779 feet are found on page 7. The headwater elevation closest to 1777.84 feet is 1777.8 feet. In the column headed 1777.8 the discharge nearest to the required 1,000 cubic feet per second is 920 cubic feet per second. By tracing the horizontal line in which 920 cubic feet per second appears, to either side of the page, we find that gate arrangement 5 is the one for producing the discharge closest to 1,000 cubic feet per second at headwater elevation 1777.8 feet. Referring to page 5 it is found that for gate arrangement 5, gates 1, 3, 5, 7, 9, 11, 13, 15, 17, and 19 are raised.


After the gates are raised, suppose it is necessary to increase the discharge from 1,000 cubic feet per second to 2,000 cubic feet per second. Assume the headwater elevation remains at 1777.8 feet. In the column headed 1777.8 feet on page 7, the discharge closest to the required 2,000 cubic feet per second is 2,030 cubic feet per second

for gate arrangement 11. To change from gate arrangement 5 to gate arrangement 11, gates 21, 23, 25, 26, 28, 30, 32, 34, 36, 38, 40, and 42 are raised in addition to those gates already opened.

Example 2 -- Suppose the operating records show that the headwater is at elevation 1779.5 feet, and gate arrangement 21 is in use. The headwater is found on page 8 which is marked "Headwater 1779 to 1781." In the column headed 1779.5 opposite gate arrangement 21, the discharge is found to be 8,240 cubic feet per second.

NOTTELY DAM

LOCATION OF SPILLWAY GATES



NOTTELY DAM

SPILLWAY GATE ARRANGEMENTS

Arrangement Number	Gate Number																																																												
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50											
1	R	-	R	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-										
2	R	R	-	R	-	R	-	R	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-									
3	R	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-						
4	R	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-						
5	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-					
6	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-					
7	R	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-				
8	R	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-				
9	R	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-		
10	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-			
11	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-			
12	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-			
13	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-			
14	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	
15	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	
16	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	
17	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	
18	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	
19	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	
20	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	
21	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	
22	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	
23	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	
24	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	
25	R	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-	R	-

GATE OPENINGS

Figures in columns under each gate number refer to gate opening indicator reading
 dash (-) indicates closed gate
 "R" indicates gate raised above water surface and dogged
 "R" indicates first use of each gate

NOTTELY DAM SPILLWAY DISCHARGE IN CUBIC FEET PER SECOND

GATE ARRANGE- MENT	HEADWATER ELEVATION																				GATE ARRANGE- MENT	
	1775.0	1775.1	1775.2	1775.3	1775.4	1775.5	1775.6	1775.7	1775.8	1775.9	1776.0	1776.1	1776.2	1776.3	1776.4	1776.5	1776.6	1776.7	1776.8	1776.9		1777.0
1	0	0	5	5	10	10	15	20	25	30	35	40	50	55	60	70	75	85	90	100	110	1
2	0	0	5	10	20	25	35	40	50	60	75	85	95	110	120	140	150	170	180	200	220	2
3	0	5	10	15	25	35	50	60	75	90	110	130	140	160	180	210	230	250	270	300	320	3
4	0	5	10	25	35	50	65	85	100	120	150	170	190	220	250	270	300	330	370	400	430	4
5	0	5	15	30	45	60	80	100	130	150	180	210	240	270	310	340	380	420	460	500	540	5
6	0	5	20	35	55	75	100	120	150	180	220	250	290	330	370	410	460	500	550	600	650	6
7	0	10	20	40	60	85	110	150	180	220	250	290	340	380	430	480	530	580	640	700	760	7
8	0	10	25	45	70	100	130	170	200	250	290	340	390	440	490	550	610	670	730	800	860	8
9	0	10	30	50	80	110	150	190	230	280	330	380	430	490	550	620	680	750	820	900	970	9
10	0	10	30	55	90	120	160	210	260	310	360	420	480	550	610	690	760	840	910	1,000	1,080	10
11	0	10	35	60	95	140	180	230	280	340	400	460	530	600	680	750	830	920	1,010	1,100	1,190	11
12	0	15	35	70	110	150	200	250	310	370	440	510	580	660	740	820	910	1,000	1,100	1,190	1,300	12
13	0	15	40	75	110	160	210	270	330	400	470	550	630	710	800	890	990	1,090	1,190	1,290	1,400	13
14	0	15	45	80	120	170	230	290	360	430	510	590	680	770	860	960	1,060	1,170	1,280	1,390	1,510	14
15	0	15	45	85	130	190	250	310	380	460	540	630	720	820	920	1,030	1,140	1,250	1,370	1,490	1,620	15
16	0	15	50	90	140	200	260	330	410	490	580	670	770	880	980	1,100	1,210	1,340	1,460	1,590	1,730	16
17	0	20	50	95	150	210	280	350	440	520	620	720	820	930	1,040	1,160	1,290	1,420	1,550	1,690	1,840	17
18	0	20	55	100	160	220	300	370	460	550	650	760	870	980	1,110	1,230	1,370	1,500	1,650	1,790	1,940	18
19	0	20	60	110	170	240	310	400	490	580	690	800	920	1,040	1,170	1,300	1,440	1,590	1,740	1,890	2,050	19
20	0	20	60	110	180	250	330	420	510	620	730	840	960	1,090	1,230	1,370	1,520	1,670	1,830	1,990	2,160	20
21	0	25	65	120	180	260	340	440	540	650	760	880	1,010	1,150	1,290	1,440	1,590	1,750	1,920	2,090	2,270	21
22	0	25	65	120	190	270	360	460	560	680	800	930	1,060	1,200	1,350	1,510	1,670	1,840	2,010	2,190	2,380	22
23	0	25	70	130	200	280	380	480	590	710	830	970	1,110	1,260	1,410	1,580	1,750	1,920	2,100	2,290	2,480	23
24	0	25	75	140	210	300	390	500	610	740	870	1,010	1,160	1,310	1,480	1,640	1,820	2,000	2,190	2,390	2,590	24
25	0	25	75	140	220	310	410	520	640	770	910	1,050	1,210	1,370	1,540	1,710	1,900	2,090	2,290	2,490	2,700	25

NOTTELY DAM
SPILLWAY DISCHARGE
 IN CUBIC FEET PER SECOND

GATE APERTURE FEET	HEADWATER ELEVATION																			GATE APERTURE FEET		
	1777.0	1777.1	1777.2	1777.3	1777.4	1777.5	1777.6	1777.7	1777.8	1777.9	1778.0	1778.1	1778.2	1778.3	1778.4	1778.5	1778.6	1778.7	1778.8		1778.9	1779.0
1	110	120	130	130	140	150	160	170	180	190	210	220	230	240	250	260	280	290	300	310	330	1
2	220	230	250	270	290	310	330	350	370	390	410	430	460	480	500	530	550	570	600	620	650	2
3	320	350	380	400	430	460	490	520	550	580	620	650	680	720	750	790	830	860	900	940	980	3
4	430	470	500	540	580	620	660	700	740	780	820	870	910	960	1,000	1,050	1,100	1,150	1,200	1,250	1,300	4
5	540	580	630	670	720	770	820	870	920	970	1,030	1,080	1,140	1,200	1,260	1,310	1,380	1,440	1,500	1,560	1,630	5
6	650	700	750	810	870	920	980	1,040	1,110	1,170	1,230	1,300	1,370	1,440	1,510	1,580	1,650	1,720	1,800	1,870	1,950	6
7	760	820	880	940	1,010	1,080	1,150	1,220	1,290	1,360	1,440	1,520	1,600	1,680	1,760	1,840	1,930	2,010	2,100	2,190	2,280	7
8	860	930	1,010	1,080	1,150	1,230	1,310	1,390	1,470	1,560	1,650	1,730	1,820	1,920	2,010	2,100	2,200	2,300	2,400	2,500	2,600	8
9	970	1,050	1,130	1,210	1,300	1,390	1,470	1,570	1,660	1,750	1,850	1,950	2,050	2,160	2,260	2,370	2,480	2,590	2,700	2,810	2,930	9
10	1,080	1,170	1,260	1,350	1,440	1,540	1,640	1,740	1,840	1,950	2,060	2,170	2,280	2,390	2,510	2,630	2,750	2,870	3,000	3,120	3,250	10
11	1,190	1,280	1,380	1,480	1,590	1,690	1,800	1,910	2,030	2,140	2,260	2,380	2,510	2,630	2,760	2,890	3,030	3,160	3,300	3,440	3,580	11
12	1,300	1,400	1,510	1,620	1,730	1,850	1,970	2,090	2,210	2,340	2,470	2,600	2,740	2,870	3,010	3,160	3,300	3,450	3,600	3,750	3,900	12
13	1,400	1,520	1,630	1,750	1,880	2,000	2,130	2,260	2,400	2,530	2,680	2,820	2,960	3,110	3,260	3,420	3,580	3,730	3,900	4,060	4,230	13
14	1,510	1,630	1,760	1,890	2,020	2,160	2,290	2,440	2,580	2,730	2,880	3,040	3,190	3,350	3,520	3,680	3,850	4,020	4,200	4,370	4,550	14
15	1,620	1,750	1,880	2,020	2,160	2,310	2,460	2,610	2,770	2,920	3,090	3,250	3,420	3,590	3,770	3,940	4,130	4,310	4,500	4,690	4,880	15
16	1,730	1,870	2,010	2,160	2,310	2,460	2,620	2,780	2,950	3,120	3,290	3,470	3,650	3,830	4,020	4,210	4,400	4,600	4,800	5,000	5,200	16
17	1,840	1,980	2,140	2,290	2,450	2,620	2,790	2,960	3,130	3,310	3,500	3,690	3,880	4,070	4,270	4,470	4,680	4,880	5,100	5,310	5,530	17
18	1,940	2,100	2,260	2,430	2,600	2,770	2,950	3,130	3,320	3,510	3,700	3,900	4,100	4,310	4,520	4,730	4,950	5,170	5,400	5,620	5,850	18
19	2,050	2,220	2,390	2,560	2,740	2,930	3,110	3,310	3,500	3,700	3,910	4,120	4,330	4,550	4,770	5,000	5,230	5,460	5,700	5,940	6,180	19
20	2,160	2,330	2,510	2,700	2,890	3,080	3,280	3,480	3,690	3,900	4,120	4,340	4,560	4,790	5,020	5,260	5,500	5,750	6,000	6,250	6,500	20
21	2,270	2,450	2,640	2,830	3,030	3,230	3,440	3,650	3,870	4,090	4,320	4,550	4,790	5,030	5,270	5,520	5,780	6,030	6,290	6,560	6,830	21
22	2,380	2,570	2,760	2,970	3,170	3,390	3,610	3,830	4,060	4,290	4,530	4,770	5,020	5,270	5,520	5,790	6,050	6,320	6,590	6,870	7,160	22
23	2,480	2,680	2,890	3,100	3,320	3,540	3,770	4,000	4,240	4,480	4,730	4,990	5,240	5,510	5,780	6,050	6,330	6,610	6,890	7,190	7,480	23
24	2,590	2,800	3,020	3,240	3,460	3,700	3,930	4,180	4,420	4,680	4,940	5,200	5,470	5,750	6,030	6,310	6,600	6,900	7,190	7,500	7,810	24
25	2,700	2,920	3,140	3,370	3,610	3,850	4,100	4,350	4,610	4,870	5,140	5,420	5,700	5,990	6,280	6,570	6,880	7,180	7,490	7,810	8,130	25

NOTTELY DAM SPILLWAY DISCHARGE IN CUBIC FEET PER SECOND

GATE ARRANGEMENT	HEADWATER ELEVATION																			GATE ARRANGEMENT	
	1779.0	1779.1	1779.2	1779.3	1779.4	1779.5	1779.6	1779.7	1779.8	1779.9	1780.0	1780.1	1780.2	1780.3	1780.4	1780.5	1780.6	1780.7	1780.8		1780.9
0*	0	0	0	0	0	0	0	0	0	0	15	55	110	190	280	380	500	620	750	890	0*
1	330	340	350	360	380	390	410	420	430	450	460	490	550	620	710	810	920	1,050	1,180	1,330	1,480
2	650	680	700	730	760	780	810	840	870	900	930	970	1,040	1,120	1,220	1,340	1,460	1,600	1,750	1,900	2,060
3	980	1,010	1,050	1,090	1,140	1,180	1,220	1,260	1,300	1,350	1,390	1,450	1,530	1,630	1,740	1,870	2,000	2,150	2,310	2,470	2,640
4	1,300	1,350	1,410	1,460	1,510	1,570	1,620	1,680	1,740	1,800	1,860	1,930	2,020	2,130	2,260	2,390	2,540	2,700	2,870	3,050	3,230
5	1,630	1,690	1,760	1,820	1,890	1,960	2,030	2,100	2,170	2,250	2,320	2,410	2,510	2,630	2,770	2,920	3,080	3,250	3,430	3,620	3,810
6	1,950	2,030	2,110	2,190	2,270	2,350	2,440	2,520	2,610	2,690	2,780	2,880	3,000	3,140	3,290	3,450	3,620	3,810	4,000	4,190	4,400
7	2,280	2,370	2,460	2,550	2,650	2,750	2,840	2,940	3,040	3,140	3,250	3,360	3,490	3,640	3,810	3,980	4,160	4,360	4,560	4,770	4,980
8	2,600	2,710	2,810	2,920	3,030	3,140	3,250	3,360	3,480	3,590	3,710	3,840	3,990	4,150	4,320	4,510	4,700	4,910	5,120	5,340	5,560
9	2,930	3,040	3,160	3,280	3,410	3,530	3,660	3,780	3,910	4,040	4,170	4,320	4,480	4,650	4,840	5,040	5,240	5,460	5,680	5,910	6,150
10	3,250	3,380	3,510	3,650	3,780	3,920	4,060	4,200	4,350	4,490	4,640	4,800	4,970	5,160	5,350	5,560	5,780	6,010	6,240	6,480	6,730
11	3,580	3,720	3,870	4,010	4,160	4,310	4,470	4,620	4,780	4,940	5,100	5,270	5,460	5,660	5,870	6,090	6,320	6,560	6,810	7,060	7,320
12	3,900	4,060	4,220	4,380	4,540	4,710	4,870	5,040	5,220	5,390	5,570	5,750	5,950	6,160	6,390	6,620	6,860	7,110	7,370	7,630	7,900
13	4,230	4,400	4,570	4,740	4,920	5,100	5,280	5,460	5,650	5,840	6,030	6,230	6,440	6,670	6,900	7,150	7,400	7,660	7,930	8,200	8,480
14	4,550	4,740	4,920	5,110	5,300	5,490	5,690	5,880	6,080	6,290	6,490	6,710	6,930	7,170	7,420	7,680	7,940	8,210	8,490	8,780	9,070
15	4,880	5,070	5,270	5,470	5,680	5,880	6,090	6,300	6,520	6,740	6,960	7,190	7,430	7,680	7,940	8,210	8,480	8,770	9,060	9,350	9,650
16	5,200	5,410	5,620	5,840	6,060	6,280	6,500	6,730	6,950	7,190	7,420	7,660	7,920	8,180	8,450	8,730	9,020	9,320	9,620	9,920	10,240
17	5,530	5,750	5,980	6,200	6,430	6,670	6,910	7,150	7,390	7,630	7,880	8,140	8,410	8,690	8,970	9,260	9,560	9,870	10,180	10,500	10,820
18	5,850	6,090	6,330	6,570	6,810	7,060	7,310	7,570	7,820	8,080	8,350	8,620	8,900	9,190	9,490	9,790	10,100	10,420	10,740	11,070	11,400
19	6,180	6,430	6,680	6,930	7,190	7,450	7,720	7,990	8,260	8,530	8,810	9,100	9,390	9,690	10,000	10,320	10,640	10,970	11,300	11,640	11,990
20	6,500	6,770	7,030	7,300	7,570	7,840	8,120	8,410	8,690	8,980	9,280	9,570	9,880	10,200	10,520	10,850	11,180	11,520	11,870	12,220	12,570
21	6,830	7,100	7,380	7,660	7,950	8,240	8,530	8,830	9,130	9,430	9,740	10,050	10,370	10,700	11,040	11,380	11,720	12,070	12,430	12,790	13,150
22	7,160	7,440	7,730	8,030	8,330	8,630	8,940	9,250	9,560	9,880	10,200	10,530	10,870	11,210	11,550	11,900	12,260	12,620	12,990	13,360	13,740
23	7,480	7,780	8,080	8,390	8,710	9,020	9,340	9,670	10,000	10,330	10,670	11,010	11,360	11,710	12,070	12,430	12,800	13,180	13,550	13,940	14,320
24	7,810	8,120	8,440	8,760	9,080	9,410	9,750	10,090	10,430	10,780	11,130	11,490	11,850	12,210	12,590	12,960	13,340	13,730	14,120	14,510	14,910
25	8,130	8,460	8,790	9,120	9,460	9,810	10,150	10,510	10,870	11,230	11,590	11,960	12,340	12,720	13,100	13,490	13,880	14,280	14,680	15,080	15,490

HEADWATER 1779 to 1781

* Arrangement "0" indicates that all spillway gates are closed.
Discharge is spillway gate overflow.

APRIL 2004

NOTTELY DAM SPILLWAY DISCHARGE

IN CUBIC FEET PER SECOND

GATE ARRANGEMENT	HEADWATER ELEVATION																				GATE ARRANGEMENT	
	1781.0	1781.1	1781.2	1781.3	1781.4	1781.5	1781.6	1781.7	1781.8	1781.9	1782.0	1782.1	1782.2	1782.3	1782.4	1782.5	1782.6	1782.7	1782.8	1782.9		1783.0
0*	890	1,040	1,190	1,360	1,530	1,710	1,900	2,090	2,290	2,500	2,700	2,890	3,070	3,220	3,340	3,420	3,430	3,360	3,200	2,920	2,500	0*
1	1,480	1,630	1,800	1,970	2,150	2,340	2,540	2,750	2,960	3,170	3,380	3,580	3,770	3,940	4,070	4,160	4,190	4,150	4,010	3,760	3,380	1
2	2,060	2,230	2,400	2,590	2,780	2,980	3,190	3,400	3,620	3,840	4,060	4,280	4,480	4,660	4,800	4,910	4,960	4,940	4,830	4,610	4,260	2
3	2,640	2,820	3,010	3,200	3,410	3,620	3,830	4,060	4,290	4,520	4,750	4,970	5,180	5,370	5,540	5,660	5,730	5,730	5,640	5,450	5,140	3
4	3,230	3,420	3,610	3,820	4,030	4,250	4,480	4,710	4,950	5,190	5,430	5,670	5,890	6,090	6,270	6,400	6,490	6,510	6,450	6,290	6,020	4
5	3,810	4,010	4,220	4,430	4,660	4,890	5,120	5,370	5,620	5,870	6,120	6,360	6,590	6,810	7,000	7,150	7,260	7,300	7,270	7,140	6,900	5
6	4,400	4,610	4,820	5,050	5,280	5,520	5,770	6,020	6,280	6,540	6,800	7,050	7,300	7,530	7,730	7,900	8,020	8,090	8,080	7,980	7,780	6
7	4,980	5,200	5,430	5,660	5,910	6,160	6,410	6,680	6,940	7,210	7,480	7,750	8,010	8,250	8,460	8,650	8,790	8,870	8,890	8,820	8,660	7
8	5,560	5,800	6,030	6,280	6,530	6,790	7,060	7,330	7,610	7,890	8,170	8,440	8,710	8,960	9,190	9,390	9,550	9,660	9,700	9,670	9,540	8
9	6,150	6,390	6,640	6,900	7,160	7,430	7,700	7,990	8,270	8,560	8,850	9,140	9,420	9,680	9,920	10,140	10,320	10,450	10,520	10,510	10,420	9
10	6,730	6,980	7,240	7,510	7,780	8,060	8,350	8,640	8,940	9,240	9,540	9,830	10,120	10,400	10,660	10,890	11,080	11,240	11,330	11,350	11,300	10
11	7,320	7,580	7,850	8,130	8,410	8,700	8,990	9,300	9,600	9,910	10,220	10,530	10,830	11,120	11,390	11,640	11,850	12,020	12,140	12,200	12,180	11
12	7,900	8,170	8,450	8,740	9,030	9,330	9,640	9,950	10,270	10,580	10,900	11,220	11,530	11,830	12,120	12,380	12,620	12,810	12,960	13,040	13,060	12
13	8,480	8,770	9,060	9,360	9,660	9,970	10,280	10,600	10,930	11,260	11,590	11,920	12,240	12,550	12,850	13,130	13,380	13,600	13,770	13,880	13,930	13
14	9,070	9,360	9,660	9,970	10,280	10,600	10,930	11,260	11,590	11,930	12,270	12,610	12,940	13,270	13,580	13,880	14,150	14,380	14,580	14,730	14,810	14
15	9,650	9,960	10,270	10,590	10,910	11,240	11,570	11,910	12,260	12,610	12,960	13,300	13,650	13,990	14,310	14,620	14,910	15,170	15,390	15,570	15,690	15
16	10,240	10,550	10,870	11,200	11,540	11,870	12,220	12,570	12,920	13,280	13,640	14,000	14,350	14,700	15,040	15,370	15,680	15,960	16,210	16,410	16,570	16
17	10,820	11,150	11,480	11,820	12,160	12,510	12,860	13,220	13,590	13,950	14,320	14,690	15,060	15,420	15,780	16,120	16,440	16,750	17,020	17,260	17,450	17
18	11,400	11,740	12,080	12,430	12,790	13,150	13,510	13,880	14,250	14,630	15,010	15,390	15,770	16,140	16,510	16,870	17,210	17,530	17,830	18,100	18,330	18
19	11,990	12,340	12,690	13,050	13,410	13,780	14,150	14,530	14,920	15,300	15,690	16,080	16,470	16,860	17,240	17,610	17,970	18,320	18,650	18,950	19,210	19
20	12,570	12,930	13,290	13,660	14,040	14,420	14,800	15,190	15,580	15,980	16,380	16,780	17,180	17,580	17,970	18,360	18,740	19,110	19,460	19,790	20,090	20
21	13,150	13,520	13,900	14,280	14,660	15,050	15,440	15,840	16,240	16,650	17,060	17,470	17,880	18,290	18,700	19,110	19,510	19,890	20,270	20,630	20,970	21
22	13,740	14,120	14,500	14,890	15,290	15,690	16,090	16,500	16,910	17,320	17,740	18,160	18,590	19,010	19,430	19,850	20,270	20,680	21,080	21,480	21,850	22
23	14,320	14,710	15,110	15,510	15,910	16,320	16,740	17,150	17,570	18,000	18,430	18,860	19,290	19,730	20,160	20,600	21,040	21,470	21,900	22,320	22,730	23
24	14,910	15,310	15,710	16,120	16,540	16,960	17,380	17,810	18,240	18,670	19,110	19,550	20,000	20,450	20,900	21,350	21,800	22,260	22,710	23,160	23,610	24
25	15,490	15,900	16,320	16,740	17,160	17,590	18,030	18,460	18,900	19,350	19,800	20,250	20,700	21,160	21,630	22,100	22,570	23,040	23,520	24,010	24,490	25

* Arrangement "0" indicates that all spillway gates are closed.
Discharge is spillway gate overflow.

NOTTELY DAM SPILLWAY DISCHARGE IN CUBIC FEET PER SECOND

GATE ARRANGE- MENT	HEADWATER ELEVATION																				GATE ARRANGE- MENT	
	1783.0	1783.1	1783.2	1783.3	1783.4	1783.5	1783.6	1783.7	1783.8	1783.9	1784.0	1784.1	1784.2	1784.3	1784.4	1784.5	1784.6	1784.7	1784.8	1784.9		1785.0
25	24,490	24,980	25,480	25,980	26,480	26,980	27,490	28,010	28,520	29,040	29,570	30,100	30,630	31,160	31,700	32,240	32,790	33,340	33,890	34,450	35,010	25
GATE ARRANGE- MENT	HEADWATER ELEVATION																				GATE ARRANGE- MENT	
	1785.0	1785.1	1785.2	1785.3	1785.4	1785.5	1785.6	1785.7	1785.8	1785.9	1786.0	1786.1	1786.2	1786.3	1786.4	1786.5	1786.6	1786.7	1786.8	1786.9		1787.0
25	35,010	35,570	36,140	36,710	37,280	37,850	38,430	39,020	39,600	40,190	40,790	41,380	41,980	42,590	43,190	43,800	44,410	45,030	45,650	46,270	46,890	25
GATE ARRANGE- MENT	HEADWATER ELEVATION																				GATE ARRANGE- MENT	
	1787.0	1787.1	1787.2	1787.3	1787.4	1787.5	1787.6	1787.7	1787.8	1787.9	1788.0	1788.1	1788.2	1788.3	1788.4	1788.5	1788.6	1788.7	1788.8	1788.9		1789.0
25	46,890	47,520	48,150	48,780	49,420	50,060	50,700	51,350	52,000	52,650	53,310	53,960	54,630	55,290	55,960	56,630	57,310	57,980	58,670	59,350	60,040	25

NOTTELY DAM



October 1999

RESERVOIR OPERATION OVERVIEW


Nottely is a multipurpose tributary project located on the Nottely River, a tributary to the Hiwassee River. The project was originally constructed without any hydropower facility, primarily to be used for storage augmentation for TVA's downstream Hiwassee and Apalachia projects on the Hiwassee River, as well as for TVA mainstream dams on the Tennessee River. The project was built during World War II, with dam closure in 1942. The single unit powerhouse was completed in 1956. Nottely is operated for many purposes, including flood control, augmentation of flows for navigation, hydropower production, water quality, recreation, and aquatic ecology. Nottely Reservoir has an annual pool variation of about 35 feet during normal years, but could be several feet more during drought or flood periods.

Table of Contents

Nottely Reservoir Vicinity Map	5
Figure 1: Construction of Dam, 1942 (Photo)	6
Figure 2: Single Unit Powerhouse, 1956 (Photo)	6
General Plans, Elevation, and Sections (TVA drawing 10N200):	
Figure 3: Site Plan	7
Figure 4: Section A1-A1	8
Figure 5: Section B1-B1	9
Figure 6: Section C1-C1	10
Figure 7: Section D1-D1	11
Figure 8: Section E1-E1	12
Figure 9: Plan	13
Figure 10: Section - Powerhouse	14
Location	15
Chronology	15
Project Cost	15
Streamflow	16
Reservoir	16
Tailwater	17
Head (Gross)	17
Reservoir Adjustments	17
Dams:	
Main Dam	18
Saddle Dam	18
Outlet Facilities	18-19
Figure 11: Upper End of Concrete Spillway (Photo)	20
Figure 12: Lower End of Concrete Spillway (Photo)	20
Power Facilities:	
Intake Facilities	21
Figure 13: Intake Tower and Footbridge (Photo)	22
Powerhouse	23
Figure 14: Powerhouse (Photo)	24
Excavated Tailrace Channel	25
Hydraulic Turbine	25
Generator	25-26
Generator and Turbine Modernization	26
Electric Controls	26
Transmission Plant	26
Figure 15: Single Line Diagram of Main Connections	27
Figure 16: Switchyard (Photo)	28
Transmission Plant Data	29
Reservoir and Power Data	30-31
Unit Operating Characteristics	32
Spill Compilations	33-35
Maximum and Minimum Elevations	36-37
Average Weekly CFS	38
Annual Operating Cycle	39
Reservoir Areas and Volumes	40
Reservoir Releases Improvements	41


Table of Contents (Continued)

Safety Modifications for Probable Maximum Flood 41
Construction Data:
 Personnel, Housing Facilities, and Quantities 42
 Construction Plant Layout and Schedule 43-44



TENNESSEE VALLEY AUTHORITY
MAPS AND SURVEYS BRANCH

NOTTELY RESERVOIR VICINITY MAP



JANUARY 1972




FIGURE 1 - Construction of Dam, 1942




FIGURE 2 - Single Unit Powerhouse, 1956

FIGURE 3






FIGURE 4




SECTION A1-A1

FIGURE 5




SECTION B1-B1

FIGURE 6




SECTION C1-C1

FIGURE 7



SECTION D1-D1

FIGURE 8



SECTION E1-E1

PLAN






FIGURE 9

FIGURE 10



SECTION - POWERHOUSE



NOTTELY PROJECT

SUMMARY OF PRINCIPAL FEATURES

NOTE:

Elevations are based on the U.S.C. & G.S. 1936 Supplementary Adjustment.

LOCATION

On Nottely River at river mile 21.0; in Union County, Georgia; 11 air miles southwest of Murphy, North Carolina; 2.3 river miles upstream from Georgia-North Carolina State line.

CHRONOLOGY

Initial appropriation by Congress	July 16, 1941
Authorized by TVA Board of Directors	July 17, 1941
Construction started	July 17, 1941
Dam closure	January 24, 1942
First storage release	October 1, 1942
Power unit authorized by TVA Board of Directors ...	September 25, 1951
Installation of unit started	December 3, 1952
Unit in commercial operation	January 10, 1956
Safety modifications for probable maximum flood construction completed	June 20, 1988
Reservoir releases improvements - completed	September 30, 1993
Generator and turbine modernization - completed	June 21, 1997

PROJECT COST

Initial project, no units	\$5,384,627
Addition of unit 1	2,654,778
Safety modifications for probable maximum flood	15,200,000
Reservoir releases improvements	1,900,000
Generator and turbine modernization	<u>2,195,310</u>
Total, including switchyard	\$27,334,715

STREAMFLOW

Drainage area at dam	214 sq. miles
Gaging station discharge records:	
Near Ivylog, Georgia, October 1936 to September 1942; drainage area	191 sq. miles
At Nottely Dam, September 1941 to date; drainage area	215 sq. miles
Near Ranger, North Carolina, February 1901 to December 1905, January 1914 to April 1917, October 1918 to September 1945; drainage area ...	272 sq. miles
Maximum known unregulated flood at dam site (Sept 1898) ...	27,000 cfs
Maximum regulated flood at dam site (May 1973)	8,120 cfs
Average unregulated flow at dam site (1903-2000)	413 cfs
Minimum daily natural flow at dam site (1925), approx.	35 cfs

RESERVOIR

Counties affected:

State of Georgia Union

Reservoir land at May 31, 1996:

Fee simple	3,631 ac.
Easements	<u>1,840 ac.</u>
Total	5,471 ac.
Transferred	2,047 ac.

Operating levels at dam:

Probable maximum flood elevation (PMF)	el. 1805.9
500-year flood elevation	el. 1785.5
100-year flood elevation	el. 1782.5
Winter flood guide level	el. 1735.0
Summer flood guide level	el. 1779.0
Maximum probable flood	el. 1796.7
Maximum used for design (57,000 cfs)	el. 1788.3
Top of gates (area 4310 ac.)	el. 1780.0

Backwater, length at top of gates level 20.2 miles

Shoreline, length at normal maximum pool level:

Main shore	98 miles
Islands	<u>8 miles</u>
Total	106 miles

Original river area (to el. 1780 crossing) 170 ac.

Storage (flat pool assumption):

Total volume:

At top of gates (el. 1780)	174,300 ac.-ft
At normal maximum pool (el. 1779)	170,300 ac.-ft
At normal minimum pool (el. 1735)	57,200 ac.-ft

RESERVOIR (continued)

Reservation for flood control on:

January 1 to January 12 (el. 1780-1745)	100,000 ac.-ft
March 15 (el. 1780-1755)	79,150 ac.-ft
Useful controlled storage (el. 1780-1735)	117,100 ac.-ft

TAILWATER

Maximum used for design	el. 1636.0
Maximum known flood (1898)	el. 1624.0
Full plant operation (1 unit)	el. 1613.0
Unit operating at best efficiency	el. 1613.0
Minimum level	el. 1605.6

HEAD (Gross)

Maximum static (el. 1780-1605.6)	174.4 ft
Normal maximum operating (el. 1780-1613)	167.0 ft
Average operating	145.0 ft
Minimum operating (el. 1690-1613)	77.0 ft

RESERVOIR ADJUSTMENTS

Clearing	2,485.3 ac.
Highways:	
Access	4.2 miles
State	2.8 miles
County and tertiary	<u>15.5 miles</u>
Total	22.5 miles
Bridges (highway)	5
Concrete box culverts	19
Families relocated	91
Graves removed	2
Utilities adjusted	8.2 miles

DAMS

MAIN DAM

Material and type Rockfill and impervious rolled earthfill embankment
 Length (including spillway) 2,300 ft
 Maximum height 184 ft
 Maximum width at base 720 ft
 Top of embankment el. 1794.0
 Top width 32 ft
 Highway 22 ft wide on dam
 Foundation Carolina gneiss

SADDLE DAM

Location 500 ft beyond right end of main dam
 Material and type Impervious rolled earthfill embankment with rockfill shoulder on upstream side
 Length 340 ft
 Maximum height 40 ft
 Top of embankment el. 1794.0
 Top width 20 ft
 Foundation Earth

OUTLET FACILITIES

SPILLWAY (See Figures 11 and 12)

Location At left (north) end of main dam
 Material and type Concrete chute with curved weir and ski-jump endsill

Weir:

Crest length, clear 300 ft
 Crest level el. 1775.0
 Top of gates el. 1780.0
 Gates (50) 5 ft high by 6 ft wide
 Gate operation Two traveling electric cranes on overhead footbridge

Chute:

Length 621 ft
 Width Converges from 325 ft at weir to 80 ft at outlet
 Height 14 ft
 Level of endsill el. 1670.5

OUTLET FACILITIES

SPILLWAY (See Figures 11 and 12)

Discharge capacity:

HW el. 1787.4	49,500 cfs
HW el. 1780.0	11,500 cfs
HW el. 1779.0	8,100 cfs
Highway	20 ft wide, on bridge upstream from weir
Foundation	Earth, except chute outlet on rock



FIGURE 11 - Upper end of concrete spillway chute, October 1999




Figure 12 - Lower end of concrete spillway chute, October 1999

POWER FACILITIES

INTAKE (See Figure 13)

Type Circular reinforced concrete dry tower
 Size:
 Inside diameter 25 ft
 Height 206 ft
 Trashrack 32 sections, 8 ft 0-1/4 in. wide
 by 10 ft 6 in. high
 Gross area at racks 2,700 sq. ft
 Gates Two 5-ft-8-in.-wide by 10-ft high
 hydraulically operated slide
 gates
 Service crane 15-ton overhead crane

CONDUIT

(Intake to Powerhouse)

Type Concrete- and steel-lined tunnel
 Size:
 Concrete section, inside diameter 15 ft
 Steel section, inside diameter 12 ft
 Lengths:
 Concrete section 409 ft
 Steel section 330 ft

FIGURE 13 - Intake tower and footbridge, October 1999




POWER FACILITIES (CONT.)

POWERHOUSE (See Figure 14)

Generating capacity, 1 unit 15,000 kW
Type of construction Semioutdoor; reinforced concrete
Principal outside dimensions 96.5 ft long by 41 ft wide
by 70 ft high
Draft tube:
Type Elbow, 2 openings
Horizontal length (centerline of turbine
to downstream face) 40 ft
Vertical distance from distributor centerline
to draft tube floor 26 ft
Net area at outlet opening 304 sq. ft
Derrick Stiff leg derrick, installed on powerhouse
structure; hook load 70 tons at 25-1/2-ft
radius

FIGURE 14 - Powerhouse, October 1999



POWER FACILITIES (CONT.)

EXCAVATED TAILRACE CHANNEL

Length, approx	1000 ft
Width	30 ft
Depth (maximum)	9 ft

HYDRAULIC TURBINE

Number	1
Manufacturer	Voith Hydro, Inc.
Type	Vertical Francis
Rated output	20,600 hp at 128-ft net head
Rated speed	180 rpm
Maximum runaway speed	334 rpm
Specific speed at rating	60.0
Value of sigma at rating	0.27
Diameter of runner at intake	84.489 in.
Diameter of runner at discharge	102.28 in.
Centerline to bottom of runner	42.96 in.
Centerline to top of runner	20.88 in.
Diameter of guide vane circle	128.375 in.
Diameter of lower pit	14.0 ft
Draft tube (see Powerhouse)	Elbow type
Governors	Woodward, cabinet actuator type

GENERATOR

Number	1
Manufacturer	Westinghouse Electric Corp.
Type	Enclosed, water-cooled, vertical-shaft
Rating	16,667 kVA, 15,000 kW, 698 A, 60 degrees C rise, 0.9pf, 13.8kV, 3 ph, 60Hz
Capacity	19,167 kVA, 17,250 kW, 803 A, 80 degrees C rise
Efficiency (guaranteed):	
At rated kVA, 1.0 pf	97.15 percent
At 75% kVA, 0.9 pf	96.5 percent
Flywheel effect	8,290,000 lb-ft ²
Thrust bearing	Kingsbury type, dia. 48 in., max. load 180 tons
Neutral equipment	50-kVA transformer, 0.45 ohm, 300 A resistor

POWER FACILITIES (CONT.)

GENERATOR (CONT.)

Exciters:

Main	115 kW, 125 V
Pilot	7 kW, 125 V
Weight of heaviest crane lift, rotor	70 tons
Diameter of air housing, less trim	360 in.
Top of pilot exciter:	
Above stator soleplates	146 in.
Above generator floor	140.5 in.

GENERATOR AND TURBINE MODERNIZATION

This project for Nottely was completed on June 21, 1997. The unit was disassembled. The principal components replaced were the wicket gate seals, the stainless steel wear rings, the runner, and wicket gate bushings (greaseless). Also, the turbine shaft was modified for a new water-lubricated guide bearing. The unit was then reassembled. Unit efficiency and capacity have been improved; refer to the latest "Operating Characteristics Curves" for details.

ELECTRIC CONTROLS

From Hiwassee hydro plant, by frequency-shift powerline carrier. Local controls for initial operation and maintenance.

TRANSMISSION PLANT

(See Figure 15 for single line diagram of main connections and Figure 16 for view of switchyard)

Step-up and intersystem transformer:

- 1 3-phase, 3-winding transformer, bank 1; rated 12.47
13.2-69 kV, 14,500 kVA self-cooled, 19,333 kVA
forced-air-cooled on 13.2- and 69-kV windings; 5000
kVA self-cooled, 6667 kVA forced-air-cooled on
12.47-kV windings; Moloney


69-kV circuit breakers:

- 1 600-A, 1,000,000-kVA, 8/20-Hz, Westinghouse
- 1 600-A, 685,000-kVA, 8/20-Hz, Westinghouse

Structures:

- 2 69-kV switchyard bay, 26 ft wide

FIGURE 15 - Single line diagram of main connections



POWER FACILITIES (CONT.)

EXCAVATED TAILRACE CHANNEL

Length, approx	1000 ft
Width	30 ft
Depth (maximum)	9 ft

HYDRAULIC TURBINE

Number	1
Manufacturer	Voith Hydro, Inc.
Type	Vertical Francis
Rated output	20,600 hp at 128-ft net head
Rated speed	180 rpm
Maximum runaway speed	334 rpm
Specific speed at rating	60.0
Value of sigma at rating	0.27
Diameter of runner at intake	84.489 in.
Diameter of runner at discharge	102.28 in.
Centerline to bottom of runner	42.96 in.
Centerline to top of runner	20.88 in.
Diameter of guide vane circle	128.375 in.
Diameter of lower pit	14.0 ft
Draft tube (see Powerhouse)	Elbow type
Governors	Woodward, cabinet actuator type

GENERATOR

Number	1
Manufacturer	Westinghouse Electric Corp.
Type	Enclosed, water-cooled, vertical-shaft
Rating	16,667 kVA, 15,000 kW, 698 A, 60 degrees C rise, 0.9pf, 13.8kV, 3 ph, 60Hz
Capacity	19,167 kVA, 17,250 kW, 803 A, 80 degrees C rise
Efficiency (guaranteed):	
At rated kVA, 1.0 pf	97.15 percent
At 75% kVA, 0.9 pf	96.5 percent
Flywheel effect	8,290,000 lb-ft ²
Thrust bearing	Kingsbury type, dia. 48 in., max. load 180 tons
Neutral equipment	50-kVA transformer, 0.45 ohm, 300 A resistor

POWER FACILITIES (CONT.)

GENERATOR (CONT.)

Exciters:

Main	115 kW, 125 V
Pilot	7 kW, 125 V
Weight of heaviest crane lift, rotor	70 tons
Diameter of air housing, less trim	360 in.
Top of pilot exciter:	
Above stator soleplates	146 in.
Above generator floor	140.5 in.

GENERATOR AND TURBINE MODERNIZATION

This project for Nottely was completed on June 21, 1997. The unit was disassembled. The principal components replaced were the wicket gate seals, the stainless steel wear rings, the runner, and wicket gate bushings (greaseless). Also, the turbine shaft was modified for a new water-lubricated guide bearing. The unit was then reassembled. Unit efficiency and capacity have been improved; refer to the latest "Operating Characteristics Curves" for details.

ELECTRIC CONTROLS

From Hiwassee hydro plant, by frequency-shift powerline carrier. Local controls for initial operation and maintenance.

TRANSMISSION PLANT

(See Figure 13 for single line diagram of main connections and Figure 14 for view of switchyard)

Step-up and intersystem transformer:

- 1 3-phase, 3-winding transformer, bank 1; rated 12.47
13.2-69 kV, 14,500 kVA self-cooled, 19,333 kVA
forced-air-cooled on 13.2- and 69-kV windings; 5000
kVA self-cooled, 6667 kVA forced-air-cooled on
12.47-kV windings; Moloney

69-kV circuit breakers:

- 1 600-A, 1,000,000-kVA, 8/20-Hz, Westinghouse
- 1 600-A, 685,000-kVA, 8/20-Hz, Westinghouse

Structures:

- 2 69-kV switchyard bay, 26 ft wide

FIGURE 16 - Switchyard, October 1999



July 2001

Nottely 29

TRANSMISSION PLANT DATA

Plant	Location	Phase	Serial Number	MVA Rating		Voltage kV	Cooling	Tap Changer	Oil Preservation System	Oil Volume Gal.	Configuration	Impedance %			Contract Number	Manuf	Yr of Manuf
				55 deg	65 deg							H-X	H-Y	X-Y			
Nottely	Bank 1	3	910896	14.5/19.33	N/A	69/13.2	OA/FA	DETC	Gas-Blanketed	4130	Wye/Delta	7.90	N/A	N/A	C53-22444	Moloney	1953

Note: H=High voltage winding
Y=Tertiary winding
X=Low voltage winding

RESERVOIR AND POWER DATA

Nottely			----- Best Efficiency -----				----- Maximum Sustainable -----		
Elevation (feet)	Area (acre*1000)	Volume (ac-ft*1000)	Gross Head (feet)	Plant Output (mW)	Turbine Discharge (cfs)	kW/CFS	Plant Output (mW)	Turbine Discharge (cfs)	kW/CFS
1780	4.32	174.3	167.4	17.2	1,390	12.44	20.0	1,630	12.25
1779	4.18	170.1	166.4	17.1	1,390	12.35	20.0	1,650	12.16
1778	4.05	165.9	165.4	17.0	1,390	12.26	20.0	1,660	12.06
1777	3.93	162.0	164.3	16.9	1,390	12.17	20.0	1,670	11.96
1776	3.83	158.1	163.3	16.8	1,390	12.08	20.0	1,690	11.86
1775	3.73	154.3	162.3	16.7	1,400	11.99	20.0	1,700	11.76
1774	3.65	150.6	161.2	16.6	1,400	11.90	20.0	1,710	11.66
1773	3.56	147.0	160.2	16.5	1,400	11.81	20.0	1,730	11.56
1772	3.48	143.5	159.2	16.4	1,400	11.72	19.9	1,740	11.46
1771	3.39	140.0	158.2	16.3	1,400	11.62	19.8	1,740	11.36
1770	3.31	136.7	157.1	16.2	1,410	11.53	19.7	1,750	11.26
1769	3.23	133.4	156.1	16.1	1,410	11.44	19.6	1,760	11.15
1768	3.15	130.2	155.1	16.0	1,410	11.34	19.5	1,760	11.05
1767	3.07	127.1	154.1	15.9	1,410	11.25	19.4	1,770	10.95
1766	2.99	124.1	153.1	15.8	1,420	11.16	19.3	1,780	10.85
1765	2.92	121.1	152.1	15.7	1,420	11.06	19.2	1,790	10.75
1764	2.85	118.3	151.0	15.6	1,420	10.97	19.1	1,790	10.65
1763	2.78	115.4	150.0	15.5	1,420	10.88	19.0	1,800	10.54
1762	2.71	112.7	149.0	15.4	1,430	10.81	18.9	1,800	10.49
1761	2.65	110.0	148.0	15.3	1,430	10.73	18.8	1,800	10.43
1760	2.59	107.4	147.0	15.2	1,430	10.66	18.7	1,800	10.38
1759	2.53	104.8	146.0	15.1	1,430	10.59	18.6	1,800	10.33
1758	2.47	102.3	145.0	15.0	1,430	10.52	18.5	1,800	10.27
1757	2.42	99.9	144.0	14.9	1,430	10.45	18.4	1,800	10.22
1756	2.36	97.5	143.0	14.8	1,430	10.38	18.3	1,800	10.16
1755	2.31	95.2	142.0	14.7	1,430	10.31	18.2	1,800	10.11
1754	2.26	92.9	141.0	14.6	1,430	10.24	18.1	1,800	10.06
1753	2.21	90.6	140.0	14.5	1,430	10.17	18.0	1,800	10.00
1752	2.17	88.4	139.0	14.4	1,420	10.11	17.8	1,790	9.94


NOTE: Energy in storage data not included

RESERVOIR AND POWER DATA

Nottely

Elevation (feet)	Area (acre*1000)	Volume (ac-ft*1000)	Gross Head (feet)	Best Efficiency			Maximum Sustainable		
				Plant Output (mW)	Turbine Discharge (cfs)	kW/CFS	Plant Output (mW)	Turbine Discharge (cfs)	kW/CFS
1751	2.12	86.3	138.1	14.2	1,410	10.05	17.6	1,780	9.89
1750	2.08	84.2	137.1	14.1	1,410	9.98	17.4	1,770	9.83
1749	2.04	82.1	136.1	13.9	1,400	9.92	17.2	1,760	9.77
1748	2.00	80.1	135.1	13.8	1,390	9.86	17.0	1,750	9.72
1747	1.96	78.1	134.2	13.6	1,390	9.80	16.8	1,740	9.66
1746	1.92	76.2	133.2	13.5	1,380	9.74	16.6	1,730	9.60
1745	1.89	74.3	132.2	13.3	1,370	9.68	16.4	1,720	9.55
1744	1.85	72.4	131.2	13.2	1,370	9.62	16.2	1,710	9.49
1743	1.81	70.6	130.3	13.0	1,360	9.56	16.1	1,700	9.43
1742	1.78	68.8	129.3	12.9	1,360	9.50	15.9	1,690	9.38
1741	1.74	67.0	128.3	12.8	1,350	9.44	15.7	1,680	9.32
1740	1.71	65.3	127.3	12.7	1,350	9.38	15.6	1,670	9.26
1739	1.68	63.6	126.4	12.6	1,350	9.31	15.4	1,660	9.20
1738	1.64	61.9	125.4	12.5	1,350	9.25	15.2	1,650	9.15
1737	1.61	60.3	124.4	12.4	1,340	9.19	15.1	1,640	9.09
1736	1.58	58.7	123.4	12.3	1,340	9.13	14.9	1,630	9.03
1735	1.55	57.2	122.5	12.2	1,340	9.07	14.8	1,620	8.98
1734	1.52	55.6	121.5	12.1	1,330	9.01	14.6	1,610	8.92
1733	1.49	54.1	120.5	12.0	1,330	8.95	14.4	1,610	8.86
1732	1.46	52.7	119.5	11.9	1,330	8.89	14.3	1,600	8.81
1731	1.43	51.2	118.6	11.8	1,320	8.83	14.1	1,590	8.75
1730	1.40	49.8	117.6	11.7	1,320	8.77	14.0	1,580	8.69

NOTE: Energy in storage data not included



NOTE:
 This curve is based on data from Holston model feet No. 3105, made on a 38.55 feet diameter model Francis runner of the James Leffel and Co., and modified in accordance with data obtained from an index test of the unit made on a 17.50 of about 100-foot head.

POWERHOUSE			
OPERATING CHARACTERISTICS OF 15,000 KW UNIT BASED ON INDEX TEST			
NOTTELY PROJECT, TENNESSEE VALLEY AUTHORITY, DIVISION OF DESIGN			
DESIGNED BY <i>J. R. ...</i>	RECOMMENDED BY <i>R. M. ...</i>	APPROVED BY <i>R. M. ...</i>	
KNOXVILLE	11-14-58	10' 11' 4"	47K902

Nottely Spill Compilation

YEAR	MAXIMUM AVERAGE DAILY DISCHARGE (TURBINE + SPILL)	DATE	NUMBER OF PERIODS	TOTAL DAYS	Volumes are average daily in day-second-feet, except as shown. Maximum spill, date of maximum, and number of days of spill in each spill period, in this order. "Total Days" is for calendar year and does not always equal the sum of the days in periods because of extension of periods into adjacent years. Water was spilled through the spillway and/or the Howell-Bunger Valve. All unmarked spill was through valve. Howell-Bunger valve was removed and installed at Chatuge in August 1954. Maximum hourly average discharge to date was 8,120 cfs at 2 p.m. on 5/28/73. *Spillway #Spillway and valve
1942	1780	10/2	2	50	*83---9/10---3; #1780---10/2---47
1943	1950	5/23 & 24	9	164	#1760---1/31---20; 1670---2/23---4; *860---3/24---13; *398---4/7---5; #1950---5/23---49; 1700---6/15---14; 1670---7/20---15; 1670---8/8---19; 1500---9/25---10; 1170---12/21---15
1944	1500	7/11	7	193	*742---4/2---5; *742---4/12---14; #1500---7/11---100; 860---8/8---16; 1200---9/15---15; 519---10/15---17; 942---12/6---23
1945	2104	9/30	5	56	1740---5/31---21; 1520---6/27---8; 585---7/28---2; 1180---9/6---10; 2104---9/30---15
1946	2550	1/13	10	218	2550---1/13---14; 954---2/1---6; 2550---2/13---15; 1090---3/10---16; 1520---3/19---5; 1280---4/16---37; 1000---7/3---39; 1320---7/23---73; 538---12/17---2; 998---12/24---9
1947	1690	4/19	5	252	1690---4/19---123; 1000---6/21---18; 656---7/6---5; 527---7/24---6; 1360---7/31---100
1948	2330	6/9	7	146	1490---1/29---15; 2330---6/9---57; 570---6/29---3; 1000---7/10---5; 1140---7/27---4; 1490---8/24---26; 1150---9/21---19
1949	1640	10/25	8	269	1510---1/8---137; 710---5/3---3; 1000---5/20---7; 950---6/4---16; 1050---8/13---30; 1640---10/25---53; 1000---11/11---22; 1250---12/21---38
1950	1500	4/11	9	218	710---2/16-19---41; 500---3/11&12---4; 1500---4/11---54; 1240---6/21&22---27; 1000---8/25-27---25; 500---9/9-11---7; 1100---9/22---25; 1000---12/9---12; 500---5/30---3
1951	2210	1/9	7	163	2210---1/9---23; 100---3/5---2; 1190---3/22---10; 990---6/5---32; 1180---6/21---3; 1000---6/27---8; 1150---7/18---85
1952	1500	4/16&17, 5/13	5	242	1000---2/5---42; 650---2/26---12; 1500---4/16---89; 1000---6/26---96; 1150---12/30---12
1953	1780	8/20	5	197	500---1/20---4; 800---2/3---5; 1500---3/17---29; 1250---6/18---43; 1780---8/20---99
1954	2210	5/6	5	156	1470---1/1---24; 1490---3/9---38; 1980---4/7---9; 2210---5/6---40; 740---6/15---53
1955	2950	5/23	2	201	*2950---5/23---101; *920---9/27---110
1956	1750	8/11	0	10	Turbine began operating January 10.
1957	1563	6/14	0	0	
1958	1395	7/5	0	0	

YEAR	MAXIMUM AVERAGE DAILY DISCHARGE (TURBINE + SPILL)	DATE	NUMBER OF PERIODS	TOTAL DAYS	Volumes are average daily in day-second-feet. except as shown. Maximum spill, date of maximum, and number of days of spill in each spill period, in this order. "Total Days" is for calendar year and does not always equal the sum of the days in periods because of extension of periods into adjacent years. Water was spilled through the spillway and/or the Howell-Bunger Valve. All unmarked spill was through valve. Howell-Bunger valve was removed and installed at Chatuge in August 1954. Maximum hourly average discharge to date was 8,120 cfs at 2 p.m. on 5/28/73. * Spillway #Spillway and valve
1959	1600	8/4	0	0	
1960	1729	9/14	0	0	
1961	1514	12/27	0	0	
1962	1816	2/26	0	0	
1963	1442	4/25	0	0	
1964	2183	5/3	2	7	*1025---4/29---4; *1864---5/3---3
1965	1552	6/3	0	0	
1966	1210	12/30	9	21	5---8/2---4; 5---8/10---3; 12---8/19---2; 9---8/26---3; 5---8/13---2; 4---9/14---1; 6---9/16---1; 25---9/22---3; 12---9/27---2 (through temporary Howell-Bunger valve for tests)
1967	1877	12/20	5	13	10---7/25---2; 25---8/4---4; 13---8/9---2; 23---8/29---3; 17---10/26---2 (through temporary Howell-Bunger valve for tests)
1968	1845	1/10	0	0	
1969	1212	11/15	0	0	
1970	1679	1/7	0	0	
1971	1382	11/4	0	0	
1972	1810	1/13	0	0	
1973	5363	5/28	1	3	*3740---5/28---3
1974	1599	5/21	0	0	
1975	1507	2/24	0	0	
1976	1868	5/29	0	0	
1977	1794	1/17	0	0	
1978	1664	1/14	0	0	
1979	1292	1/9	0	0	

YEAR	MAXIMUM AVERAGE DAILY DISCHARGE (TURBINE + SPILL)	DATE	NUMBER OF PERIODS	TOTAL DAYS	Volumes are average daily in day-second-feet. except as shown. Maximum spill, date of maximum, and number of days of spill in each spill period, in this order. "Total Days" is for calendar year and does not always equal the sum of the days in periods because of extension of periods into adjacent years. Water was spilled through the spillway and/or the Howell-Bunger Valve. All unmarked spill was through valve. Howell-Bunger valve was removed and installed at Chatuge in August 1954. Maximum hourly average discharge to date was 8,120 cfs at 2 p.m. on 5/28/73. *Spillway #Spillway and valve
1980	1599	3/2	0	0	
1981	978	12/18	0	0	
1982	1872	2/4	0	0	
1983	1830	5/22	0	0	
1984	1830	5/9	0	0	
1985	1408	1/21	0	0	
1986	1066	1/27	0	0	
1987	934	10/14	0	0	
1988	974	12/1	0	0	
1989	2338	6/21	1	2	*741---6/21---2
1990	1799	3/4	0	0	
1991	1707	5/8	1	12	153---5/30---12
1992	1970	12/24-25	0	0	
1993	1400	1/1	2	9	10---6/8---3; 33---6/15---6
1994	1470	1/20	1	1	13---2/21---1
1995	1553	10/11	1	3	50---10/18-20---3
1996	1450	12/20	0	0	
1997	1402	5/22	1	84	*1402---5/22---84
1998	1300	2/5	0	0	
1999	1356	12/8	0	0	
2000	1332	10/23	1	3	*34---6/14---3

TVA OPERATED RESERVOIR SYSTEM
ANNUAL MAXIMUM AND MINIMUM ELEVATIONS, IN ORDER OF MAGNITUDE
FROM DATE OF RESERVOIR CLOSURE THROUGH 2000

NOTTELY

MAXIMUM					MINIMUM				
ORDER	ELEVATION	YEAR	MONTH	DAY	ORDER	ELEVATION	YEAR	MONTH	DAY
1	1781.47	1973	MAY	28	1	1622.70 *	1942	JAN.	24
2	1780.50	1943	APR.	20	2	1638.60	1947	OCT.	6
3	1779.79	1976	JULY	5	3	1641.60	1954	JULY	30
4	1779.72	1989	JUNE	21	4	1642.40	1953	SEP.	19
5	1779.59	1944	APR.	28	5	1645.75	1952	SEP.	12
6	1779.28	1984	MAY	29	6	1675.50	1951	JAN.	25
7	1779.04	1964	MAY	2	7	1685.42	1948	OCT.	1
8	1778.44	1991	JULY	1	8	1698.20	1944	DEC.	27
9	1778.24	1979	JUNE	11	9	1701.96	1959	SEP.	25
10	1778.21	1980	MAY	25	10	1702.75	1945	JAN.	1
11	1778.09	1992	JULY	4	11	1706.18	1956	DEC.	12
12	1778.09	1998	JUNE	8	12	1709.51	1946	OCT.	3
13	1778.05	1997	JUNE	12	13	1709.75	1958	SEP.	19
14	1777.82	1996	JUNE	11	14	1715.78	1960	SEP.	26
15	1777.76	1990	MAY	8	15	1718.42	1962	DEC.	28
16	1777.22	1955	MAY	23	16	1720.04	1963	JAN.	1
17	1777.13	1946	JUNE	10	17	1721.79	1957	AUG.	17
18	1777.10 %	1994	JUNE	27	18	1724.80	1950	OCT.	13
19	1777.05	1993	JUNE	21	19	1725.25	1966	FEB.	7
20	1777.04	1977	MAY	4	20	1725.36	1965	OCT.	8
21	1776.86	1983	MAY	21	21	1728.38	1955	JAN.	1
22	1776.78	1942	SEP.	27	22	1729.24	1961	FEB.	7
23	1776.18	1967	SEP.	4	23	1729.48	1970	FEB.	4
24	1775.42	1956	JAN.	1	24	1730.05	1943	OCT.	3
25	1774.73	1949	AUG.	8	25	1732.20	1964	JAN.	1
26	1774.14	1975	MAY	5	26	1732.93	1969	NOV.	21
27	1773.86	1974	JUNE	11	27	1734.34	1971	JAN.	1
28	1773.19	1995	JULY	4	28	1734.92	1968	DEC.	17
29	1772.71	1971	AUG.	23	29	1738.07	1974	NOV.	27
30	1772.47	1999	JULY	19	30	1739.79	1977	FEB.	17
31	1772.01	1972	MAY	30	31	1740.46	1999	JAN.	7
32	1771.80	1962	APR.	29	32	1740.84	1998	DEC.	23
33	1770.20	1982	JUNE	7	33	1740.91	2000	JAN.	7
34	1770.02	1966	JULY	8	34	1740.95	1949	OCT.	30
35	1769.43	2000	JULY	5	35	1741.75	1985	JAN.	25
36	1768.97	1963	MAY	6	36	1741.77	1997	DEC.	19
37	1768.46	1987	JULY	8	37	1741.78	1995	JAN.	6
38	1767.69	1957	APR.	12	38	1741.83	1967	FEB.	17
39	1766.80	1945	MAY	30	39	1742.17	1981	FEB.	7
40	1766.61	1965	APR.	27	40	1742.58	1996	JAN.	5
41	1766.51	1960	APR.	28	41	1742.84	1975	DEC.	25
42	1766.28	1968	MAY	20	42	1743.44	1979	JAN.	10
43	1765.75	1958	MAY	25	43	1743.82	1976	DEC.	14
44	1765.60	1988	JUNE	6	44	1744.16	1980	JAN.	10
45	1765.55	1981	JUNE	8	45	1744.26	1978	NOV.	10
46	1765.44	1952	MAR.	28	46	1744.69	1994	DEC.	21
47	1765.03	1978	JUNE	26	47	1746.25	1972	JAN.	1

TVA OPERATED RESERVOIR SYSTEM
ANNUAL MAXIMUM AND MINIMUM ELEVATIONS, IN ORDER OF MAGNITUDE
FROM DATE OF RESERVOIR CLOSURE THROUGH 2000

NOTTELY

MAXIMUM					MINIMUM				
ORDER	ELEVATION	YEAR	MONTH	DAY	ORDER	ELEVATION	YEAR	MONTH	DAY
48	1764.42	1950	APR.	7	48	1746.32	1987	JAN.	15
49	1763.50	1961	JULY	5	49	1746.44	1986	FEB.	14
50	1763.16	1970	JUNE	23	50	1746.61	1973	JAN.	17
51	1762.91	1948	MAY	7	51	1746.66	1989	DEC.	25
52	1761.70	1969	APR.	21	52	1746.76	1983	JAN.	20
53	1761.33	1985	JULY	11	53	1746.83	1988	JAN.	15
54	1760.36	1986	JUNE	1	54	1746.97	1982	JAN.	18
55	1760.11	1953	MAR.	13	55	1747.40	1984	FEB.	10
56	1759.15	1951	MAY	18	56	1748.73	1993	DEC.	31
57	1758.32	1947	APR.	18	57	1749.47	1990	DEC.	21
58	1747.88	1959	JUNE	29	58	1750.37	1992	JAN.	23
59	1740.20	1954	FEB.	22	59	1750.65	1991	JAN.	24

AVERAGE WEEKLY CFS

MAXIMUM, MINIMUM, MEDIAN, AND MEAN
Adjusted Flow by Weeks
Nottely
Years = 1903-2000


AVERAGE WEEKLY CFS


WEEK ENDING	WEEK NO.	MAXIMUM YR	MINIMUM YR	MEDIAN	MEAN
JAN 7	1	1,490 1937	136 1940	425	490
JAN 14	2	1,640 1946	147 1981	420	483
JAN 21	3	1,980 1954	160 1914	421	519
JAN 28	4	1,990 1996	155 1940	508	548
FEB 4	5	1,940 1957	169 1986	474	564
FEB 11	6	2,190 1946	150 1934	484	570
FEB 18	7	2,760 1990	150 1934	495	610
FEB 25	8	2,150 1961	154 1988	520	584
MAR 4	9	1,970 1917	145 1988	527	606
MAR 11	10	1,590 1952	166 1986	546	635
MAR 18	11	2,590 1990	214 1981	506	669
MAR 25	12	1,890 1952	177 1988	564	634
APR 1	13	1,940 1977	168 1988	540	701
APR 8	14	2,920 1936	197 1986	570	679
APR 15	15	1,990 1979	157 1999	552	594
APR 22	16	1,280 1998	151 1986	519	546
APR 29	17	980 1929	130 1986	513	524
MAY	18	1,430 1929	124 1986	468	528
MAY 13	19	1,320 1929	116 1986	463	491
MAY 20	20	2,050 1976	121 1988	404	445
MAY 27	21	1,530 1909	92 1988	390	452
JUN 3	22	1,980 1973	69 1988	360	427
JUN 10	23	1,390 1909	42 1988	342	393
JUN 17	24	780 1909	38 1988	331	367
JUN 24	25	1,370 1989	76 1986	295	330
JUL	26	952 1963	52 1988	290	327
JUL 8	27	1,250 1941	42 2000	281	351
JUL 15	28	2,690 1916	38 2000	292	352
JUL 22	29	1,860 1938	17 2000	271	336
JUL 29	30	1,810 1938	65 1925	277	314
AUG 5	31	1,210 1971	42 1986	264	299
AUG 12	32	1,060 1978	50 1925	259	288
AUG 19	33	1,630 1920	0 1999	241	292
AUG 26	34	3,710 1967	40 1925	211	290
SEP 2	35	1,040 1906	30 1925	210	252
SEP 9	36	1,230 1928	25 1925	200	237
SEP 16	37	570 1906	30 1925	190	212
SEP 23	38	800 1907	25 1925	195	224
SEP 30	39	1,360 1929	47 1986	202	254
OCT 7	40	2,890 1964	43 1986	197	283
OCT 14	41	840 1906	70 1904	192	222
OCT 21	42	943 1975	66 1986	190	236
OCT 28	43	707 1997	70 1904	215	233
NOV 4	44	1,450 1918	46 2000	212	258
NOV 11	45	1,060 1977	75 1931	220	255
NOV 18	46	1,370 1929	100 1904	230	277
NOV 25	47	2,680 1906	80 1904	230	319
DEC 2	48	1,450 1948	95 1933	233	324
DEC 9	49	1,230 1914	109 1987	320	378
DEC 16	50	1,720 1961	105 1958	316	390
DEC 23	51	1,640 1918	116 1987	307	401
DEC 31	52	2,260 1932	120 1935	398	469

AVERAGE FLOW: 1903 - 2000 = 413 CFS

RIVER SYSTEM OPERATIONS

ANNUAL OPERATING CYCLE





ELEV FT	1942 AREA AC	VOLUME				
		1942 AC-FT	1949 AC-FT	1955 AC-FT	1961 AC-FT	1965 AC-FT
1,785	4,910	199,500	198,800	197,900	197,400	197,300
1,780	4,310	176,500	175,800	174,900	174,400	174,300
1,775	3,750	156,500	155,800	154,900	154,400	154,300
1,770	3,290	138,900	138,200	137,300	136,800	136,700
1,760	2,560	109,700	109,000	108,100	107,600	107,400
1,750	2,060	86,600	86,000	84,900	84,400	84,200
1,740	1,710	67,700	67,200	66,000	65,500	65,300
1,730	1,420	52,100	51,600	50,400	49,900	49,800
1,720	1,160	39,200	38,800	37,500	37,100	37,100
1,710	910	28,800	28,500	27,200	26,800	26,800
1,700	713	20,700	20,400	19,200	19,000	19,000
1,690	563	14,300	14,100	12,900	12,700	12,700
1,680	403	9,520	9,430	8,340	8,190	8,140
1,670	293	6,040	5,950	5,020	4,940	4,860
1,660	213	3,520	3,420	2,650	2,620	2,530
1,650	145	1,750	1,640	1,000	1,040	1,000
1,640	82	613	491	235	315	306
1,630	17	127	34	6	103	101
1,620	5	20	0	0	11	9
1,612	0	0	0	0	0	0

NOTES:

Reservoir areas were measured on TVA land maps, scale 1"=500' at elevations 1785 and 1780. These maps were prepared by the Maps and Surveys Branch. Areas at 1640, 1680, 1720 & 1760 were measured on TVA topographic maps, scale 1"=2,000'. Contours were made to conform to elevations on TVA sediment range cross sections which are located at one to three mile intervals within the reservoir.

The 1949 and subsequent volumes were determined by the constant factor method for computing sediment.

All elevations are referred to the 1936 Supplementary Adjustment of the U.S.C. & G.S.

Area of original river within reservoir to elevation 1780=170 acres.

Drainage area above dam=214 square miles.

Dam closure January 24, 1942.

NOTTELY RIVER MILE 21.0

RESERVOIR AREAS
AND VOLUMES

NOTTELY PROJECT
TENNESSEE VALLEY AUTHORITY
DIVISION OF WATER CONTROL PLANNING

SUBMITTED

RECOMMENDED

APPROVED

Robert B. McLean

Paul C. Spotts

Paul G. Davis

KNOXVILLE

12-28-62

18

DA

1

32IN796R2

RESERVOIR RELEASES IMPROVEMENTS

The aeration and minimum flow equipment at Nottely Dam is part of the implementation of TVA's Lake Improvement Plan (LIP) approved by the Board of Directors in 1991. One of the goals of the Lake Improvement Plan is to improve the dissolved oxygen (DO) levels and minimum flows of the releases of 16 dams. Minimum flow releases of 55 cfs at Nottely were obtained by the installation of a small hydroturbine unit which is operated whenever the main unit is off. At Nottely testing showed the target minimum DO content of the release (4 mg/L) to be best achieved by the installation of air injection equipment. Blower and compressor systems inject air at the large and small hydroturbines respectively. The blower system consists of two blowers (250 hp each), controls, piping, and valves designed to inject air into the water flow through the large unit. The air compressor system consists of two air compressors, controls, piping, and valves designed to inject air into the flow through the small unit. The air compressors are rated at 25 hp each.

SAFETY MODIFICATIONS FOR PROBABLE MAXIMUM FLOOD

Chronology

Safety analysis studies for Chatuge Dam for the probable maximum flood (PMF) were started on July 29, 1976, and completed in May 1984. Final design was completed in January 1988. Onsite construction began in July 1986, and was completed on June 20, 1988.

Cost of Modifications

Design costs for the capital safety modifications to Chatuge Dam were \$1,520,000. Construction costs were \$13,680,000. The total project cost was \$15,200,000. This total does not include costs for dam safety evaluation studies which resulted in the modifications.

Controlling Features

The embankments at Nottely were modified in order to safety pass the probable maximum flood. The embankments were raised to elevation 1807 by the addition of rockfill. A new bridge was built with a 30 ft. width of asphalt roadway. These PMF modifications will prevent overtopping and erosion of the embankments and thus prevent breach and failure of the dam.

CONSTRUCTION DATA

PERSONNEL

	<u>Dam and Tunnel</u>	<u>Single-Unit Addition</u>
Peak employed	2,100	121
Total man-hours	1,831,960	305,555
Number of injuries	26	2
Days lost	3,939	539
Fatalities	0	0
Accident frequency	14.2	6.55
Accident severity	2,150	1,764


HOUSING FACILITIES
(Initial Project)

Permanent houses built	None
Demountable houses	58
Trailers	50
Tents (160 total capacity)	40
Washhouses	4

Public buildings constructed included a cafeteria and hospital.

QUANTITIES

	<u>Initial Project</u>	<u>Single-Unit Addition</u>
Dam and power facilities:		
Unclassified excavation ...	207,360 cu. yd	15,000 cu. yd
Rock excavation	8,353 cu. yd	-
Rolled earthfill	854,300 cu. yd	-
Dumped rockfill	698,000 cu. yd	-
Concrete	17,700 cu. yd	4,050 cu. yd
Highways:		
Excavation	650,000 cu. yd	-






CONSTRUCTION PLANT LAYOUT

STAGES	NO.	ITEM OR EQUIPMENT	1941				1942				1943														
			J	A	S	O	N	D	J	F	M	A	M	J	J	A	S	O	N	D	J	F	M		
CONST SERVICES AND CONST PLANT	A	Access road	—	—	—																				
	C	Construction utilities-water-air-power	—	—	—																				
	D	Construction-roads & bridges	—	—	—	—																			
	E	Shop & job buildings	—	—	—																				
	F	Construction plant	—	—	—																				
	G	Cofferdam & temporary channel excavation	—	—	—																				
DIVERSION TUNNEL		Excavation-unclassified			—	—					—														
		Excavation-rock			—	—																			
		Concrete lining			—	—			—	—															
		Grouting									—	—													
		Steel liner																							
INTAKE STRUCTURE		Concrete tower				—	—					—													
		Access bridge						—	—	—	—														
		Gates & operating equipment									—	—													
		Intake crane																						—	
		Trashracks																						—	
OUTLET STRUCTURE	6	Concrete										—	—												
	12	Gates & operating equipment																							
DAM STRUCTURES	26	Foundation excavation			—	—	—	—																	
	29	Earth embankment			—	—	—	—																	
	30	Rock fill			—	—	—	—																	
	32	Operators building																						—	
SPILLWAY	3	Excavation-unclassified				—	—				—	—													
	6	Concrete						—	—	—	—														
	12	Crest control equipment																						—	
		Highway bridge							—	—			—	—											
		Steel sheet piling																							
GENERAL	91	Land acquisition	—	—	—	—	—																		
	92	Reservoir clearance	—	—	—	—	—																		
	94	Highway & railroad relocation	—	—	—	—	—																		
	95	Family removal & cemetery relocation				—	—																		
	96	Utilities				—	—																		
	97	Filling reservoir							—	—	—	—													
	98	Tunnel diversion									—	—													
	99	Clean-up & removal																						—	

CONSTRUCTION SCHEDULE


00ZMO1 C 18 | 2 3 4 5 6 7 8 9 10 11 12

A




B

C




D


E




F



G



H



- NOTES:
- COMPONENT UNIT NUMBERING SCHEME:
 NAME - UNIT - FUNCTION - SYSTEM - SYMBOL NO.
 MIN. SP. DAM. 329 STRUCT.
 - UNITS ARE LISTED IN WHOLE ON THIS DRAWING WHEN IT IS PRACTICAL. OTHER COMPONENT UNITS ONLY LIST THE SYMBOL NUMBER TO FIT ON THIS PAGE. FOR EXAMPLE TO HAVE THE COMPLETE UNIT NUMBER FOR AN ISOLATION VALVE ADD THE PREFIX "SP-DAM-329-" TO THE SYMBOL NUMBER.
 - COMPONENT UNIT NUMBERS USE THE FOLLOWING SYSTEM AND FUNCTION CODES:
 SYSTEM NUMBER - SYSTEM NAME - FUNCTION CODE - FUNCTION CODE NAME
 119 - SUITCASE GENERATOR SYSTEM DAM - DAM STRUCTURE
 300 - FACILITIES & GROUNDS BLDG - SUITCASE GENERATOR
 303 - CRANE & HOISTS CRN - CRANE
 323 - INTAKE SYSTEM INT - INTAKE TOWER
 328 - DAM STR - TRASH RACK
 329 - SPILLWAY STR - SPILLWAY GATE

4. FOR PROBABLE MAXIMUM FLOOD MODIFICATIONS, SEE DRAWINGS 10W200-328-1 AND 10W200-329-1.

REVISION	DATE	BY	CHKD	APP'D	DESCRIPTION
1	10/20/03	J.P.M.	J.P.M.	J.P.M.	ISSUE FOR CONSTRUCTION

MAIN DAM WORKS

GENERAL PLAN
ELEVATION AND SECTION

DESIGNED BY	DRAWN BY	CHECKED BY	APPROVED BY	DATE	SCALE
J.P.M.	J.P.M.	J.P.M.	J.P.M.	10/20/03	1"=200'




NOTELY PROJECT
TENNESSEE VALLEY AUTHORITY
POSSIL AND HYDRO ENGINEERING

AUTOCAD R 2000 10/20/03 18 | 10W200 R 18


ELECTRONICALLY RESTORED DRAWING
THIS DRAWING HAS BEEN COMPLETELY REDRAWN
AND SUPERSEDES (10W200.R18)

TAKE COMPLETED BY: REV NO. PLOT FACTOR: 2400 W_TVA G.A.D. DRAWING DO NOT ALTER MANUALLY


A
B
C
D
E
F
G
H




KEY PLAN
SCALE 1"=20'




ELEVATION A-A & B-B
ELEVATION B-B SHOWN WITH
NTH-SP-HST-328-GTE-1-OP-1
NTH-SP-HST-328-GTE-2-OP-2




ELEVATION D-D
HAND RAILING NOT SHOWN



SYN ABT & LEGS
SCALE 1/2"=1'-0"



K-K
SCALE 3/4"=1'-0"



H-H
SCALE 3/4"=1'-0"

NOTES:


1. ALL GREASE FITTINGS TO HAVE FIGURE 8 GREASE CROOKS INSIDE & RADIAL GROOVES ON FLANGED END. FITTINGS TO HAVE ASA CLASS 1.1 FIT IN HOLE & GLASS ROD FIT ON AXLES WITH CLASSES FOR ASA STL. 84. 1-185A, PRESTRESSED LIMITS & FITS FOR CHEMICAL PARTS. BRASS DOMES TO HOLD BUSHINGS FROM TURNING IN HOLE. ALL BOLT HEADS & NUTS TO BE AMERICAN STD. REGULAR SEAM-FINISHED HEXAGON. ALL THREAD TO BE AMERICAN STD. COARSE THREAD SERIES, CLASS 2A FIT FOR BRASS & CLASS 2B FIT FOR ALUM. NUTS TO BE USED ON ALL SPROCKETS.
2. FOR MANUFACTURER'S DETAILS OF GANTRY CRANE SEE ENCL. 54W320 FILE, TYP. CONTRACT NO. 60034-35337.
3. THIS FIELD TO SURVIVE WATERSIDE & INSTALL AT GOVERNMENT LOCATIONS FOR: 1) TYPING DOWN LIFTING BEAM ON CRANE DECK FOR STORAGE; 2) HOLDING GATE IN TYPING POSITION SHOWN IN A-A & B-B; 3) PREVENTING CRANE MOVEMENT WHEN NOT IN USE.

COMPONENT UNIT NUMBERING SCHEME:

PLANT	UNIT	FUNCTION	SYSTEM	SEQUENCE NO.
NTH	OP	HST	328	GTE-1-OP-1

3. UNITS ARE LISTED IN WHOLE ON THIS DRAWING.

4. COMPONENT UNIT NUMBERS USE THE FOLLOWING SYSTEM AND FUNCTION CODES:
SYSTEM NUMBER - POSITION NAME FUNCTION CODE - FUNCTION CODE NUMBER
328 - SPILLWAY HST - SPILLWAY GATE HOIST



P-P
SCALE 3/4"=1'-0"

Q-Q
SCALE 3/4"=1'-0"

DESIGNED BY	18 SH 54W320	CHECKED BY	
DRAWN BY		DATE	
SCALE	1/4"=1'-0"	EXCEPT AS NOTED	
SPILLWAY			
2 TON GANTRY CRANE ARRANGEMENT & DETAILS			
NOTED BY		DATE	
APPROVED BY		DATE	
NOTELY PROJECT TENNESSEE VALLEY AUTHORITY FOSSIL AND HYDRO ENGINEERING			
AUTOCAD	R2000	11-3-98	18 SH 54W320 R 3


ELECTRONICALLY RESTORED DRAWING
THIS DRAWING HAS BEEN COMPLETELY REDRAWN
AND SUPERSEDES (SAN 500, 82)

TASK COMPLETED BY

REV NO

PLOT FACTOR: 18
W_TVA

C.A.S. DRAWING
DO NOT ALTER MANUALLY



NOTE:
FIELD TO SLOPE
BORROW AREAS
& 2% FOR DRAINAGE

NOTE A1:
DOWNSTREAM BERM AT EL. 1775 SHALL
BE CONCRETE WITH COARSE FILTER
MATERIAL AS REQUIRED TO ALLOW
ACCESS ALONG THIS BERM FOR PLANT
VEHICLES.

NOTE B1:
FIELD TO LOCATE ACCESS ROAD
APPROXIMATELY AS SHOWN WITH
A MAXIMUM GRADE OF 1%.

NOTE C1:
FIELD SHALL EXTEND EXISTING
PIEZOMETERS 3.0' ABOVE OVERTOP
SLOPE OF RAISED DAM FIELD TO
PROVIDE THE SAME TYPE OF MATERIAL
USED IN THE ORIGINAL
INSTALLATION. SEE DETAIL A3
SPECIAL CARE TO BE TAKEN IN
REMOVING DOWNSTREAM FACE OF DAM
AND IN PLACING NEW EMBKT.
AROUND PIEZOMETERS.

NOTE D1:
TOP OF RAISED EMBANKMENT
EL. VARIES 1807.5 TO 1809.0
FINAL GRADING OF TOP OF
EMBANKMENT, SEE ROADWAY
PROFILE 1004201, 202.

NOTE E1:
FOR DETAILS OF EXISTING
EMBANKMENT, SEE 21E200
AND 21E202.

NOTES:
1. FOR GENERAL NOTES SEE 21E200-3.
2. FOR ADDITION OF SLUICE GENERATOR TO BEHIN IN 1993,
SEE 10W404-1 AND 2.

COMPARISON DRAWINGS
21E200-2 & 21E200-3

DATE: 11/18/84
DRAWN BY: J. BOYD
CHECKED BY: C. VANCE
SCALE: 1"=30'

MAIN EMBANKMENT











**INCREASE HEIGHT OF DAM
PLAN, SECTIONS & DETAILS**

NOTITELY PROJECT
TENNESSEE VALLEY AUTHORITY
FOSSIL AND HYDRO ENGINEERING

AUTOCAD R12
3-28-84
21E205-1


PLOT FACTOR: 360
E.TVA
C.O. DRAWING
DO NOT ALTER MANUALLY


GENERALS



NOTES:
Rubber seals shall be made in one piece between joints of roadway. Straight seals to be made 1/2" larger than indicated length to allow for compression & fitting.
Bolts, nuts & washers shall be Class 1.1 in hubs & class A in rims. All bushings shall be 1/16" thick.
All bushings shall be of bronze.
All steel bolts to be 304, unless otherwise noted.
All bolt heads & nuts to be American Std regular semi-finished hexagon unless otherwise noted.
All lifts shall be in accordance with latest edition of ASA Std D4.1 Preferred Limits and Fits for Steel and Iron.
All threads shall be American Standard coarse thread series, Class 2B fit for nuts, Class 2B fit for nuts, unless otherwise noted.
Lifting beam shall be welded steel.
Each lifting hook and gate hook shall be tested separately with a load of 3000' before assembly.
All machine elements on lifting beam shall appear freely. Lifting beam to be balanced with counterweight as shown.
All machined dimensions to be held to .01" unless otherwise noted.
For Manufacturer's details of steel see Project Data - 701. For TWA Contract No. 60052-352E-1. For Manufacturer's details of Lifting Beam see Lucky Alloy Products, Inc. TWA Contract No. 60052-352E-1.

SPILLWAY					
GATES & LIFTING BEAMS ARRANGEMENT & DETAILS					
NOTTELY PROJECT TENNESSEE VALLEY AUTHORITY DIVISION OF DESIGN					
SUBMITTED	RECOMMENDED	APPROVED			
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>			
KNOXVILLE	10-19-50	16 SH 4	54N510R		
DESIGNED BY AS CONTRACTOR					





FOR 1991 REVISION SEE, 58N203-1 & 58N203-2

SPILLWAY

STRUCTURAL STEEL
GATE GUIDES & HOIST TRACK


NOTTLEY PROJECT
TENNESSEE VALLEY AUTHORITY
DIVISION OF DESIGN

SUBMITTED <i>J. E. Wain</i>	RECOMMENDED <i>[Signature]</i>
KNOXVILLE 9-28-59	18 SH + 58N202-R1


REVISION NUMBER 13 CONTRACT

NO.	DESCRIPTION	DATE
1	ISSUED FOR PERMIT	9/28/59
2	ISSUED FOR CONSTRUCTION	10/1/59
3	ISSUED FOR CONSTRUCTION	10/1/59
4	ISSUED FOR CONSTRUCTION	10/1/59
5	ISSUED FOR CONSTRUCTION	10/1/59
6	ISSUED FOR CONSTRUCTION	10/1/59
7	ISSUED FOR CONSTRUCTION	10/1/59
8	ISSUED FOR CONSTRUCTION	10/1/59
9	ISSUED FOR CONSTRUCTION	10/1/59
10	ISSUED FOR CONSTRUCTION	10/1/59

009M1P 0 18 2 3 4 5 6 7 8 9 10 11 12




PLAN A-A




PLAN B-B


NOTE: AN EXISTING MG-SET PAD AND REINFORCEMENT SHALL BE REMOVED. AFTER PAD IS REMOVED, FLOOR SHALL BE LEVELLED USING 1/2" CONC. SLAB OF CONCRETE. FOR LOCATION OF NEW EQUIPMENT SEE SECTION E-E




PLAN C-C




PLAN D-D



SECTION E-E



KEY PLAN
SCALE: 1"=50'



SECTION F-F

FEB 11 2006

NO. 1	REV. 1	REV. 2	REV. 3	REV. 4	REV. 5	REV. 6	REV. 7	REV. 8	REV. 9	REV. 10	REV. 11	REV. 12	REV. 13	REV. 14	REV. 15	REV. 16	REV. 17	REV. 18	REV. 19	REV. 20	

POWERHOUSE

GENERAL ARRANGEMENT
PLANS & SECTIONS

NOTELY PROJECT
TENNESSEE VALLEY AUTHORITY
POWER AND HYDRO ENGINEERING

AUTOCAD PLOT FILE: 10-20-02 18 c 41W600 R 7

THIS DRAWING HAS BEEN COMPLETELY REDRAWN AND SUPERSEDES (41N60) 06

PLOT FACTOR: 96
W_TVA
C.A.D. DRAWING
DO NOT ALTER MANUALLY