

Westinghouse Non-Proprietary Class 3

PWROG Project ISI Interval Extension for Non-Alloy 82/182 RV Nozzle Welds

Nathan Palm
Bruce Bishop
Stephen Parker
Paul Stevenson





Meeting Agenda

- | | |
|--|------|
| ● Introduction | 1:00 |
| ● Review of Project Objectives | 1:05 |
| ● Recap of June 22nd Meeting | 1:15 |
| ● Objectives for this Meeting | 1:30 |
| ● Results of Change-in-Failure Frequency Calculations | 1:40 |
| ● Results of Pilot Plant Evaluations | 2:15 |
| ● Proposed Resolution of NRC Concerns Raised at Last Meeting | 2:50 |
| ● Plant Specific Implementation | 3:15 |
| ● Summary and Conclusions | 3:35 |
| ● Future PWROG Actions | 3:45 |
| ● Additional Questions | 3:50 |
| ● Adjourn | 4:00 |

Introduction and Review of Project Objectives



- PWROG has a current effort to develop a technical basis to extend the ISI interval for Non-Alloy 82/182 RV nozzles
 - Includes primary inlet, outlet, and SI nozzles
 - Does not include BMI, HV, and CRDM/CEDM nozzles
- Objectives of the PWROG effort include:
 - Develop a technical basis for ISI interval extension for similar metal (Category B-J) and dissimilar metal (Category B-F) welds that do not contain Alloy 82/182
 - Develop a framework for implementing the extended ISI interval
 - Submit topical report for NRC review and approval



Recap of June 22 Meeting - Background

- Meeting held to inform Staff of PWROG efforts
- Discussed motivation and benefits associated with extending the ISI interval
 - Consistent with extended interval for RV
 - Savings in cost, outage time, and dose
 - May eliminate need to pull core barrel
- Reviewed service experience for these welds
 - Survey conducted of participating PWR plants
 - Very few instances of recordable indications
 - No known reportable indications


Recap of June 22 Meeting – Technical Approach




- Nozzle welds can be categorized into 4 types
 - Similar Metal, with and without a safe-end
 - Dissimilar Metal, with and without a safe-end
- Use Westinghouse SRRA Code to evaluate change in failure frequency associated with extension in ISI interval for each weld type
 - Proposed SRRA inputs and basis discussed
- Compare change-in-risk to R.G. 1.174 criteria
- Evaluate effect on risk-informed ISI program (if applicable)

Recap of Nozzle / Weld Types


Type A:




Type C:



Type B:



Type D:



Objectives for this Meeting


- Provide an update on the status of the PWROG effort
- Present the results of the detailed change-in-failure frequency calculations
- Present the results of the pilot plant calculations demonstrating the evaluation of effects on RI-ISI programs
- Present proposed resolution of NRC comments from last meeting
- Discuss plant specific implementation plan and future PWROG actions
- Obtain NRC feedback

Change-in-Failure Frequency Calculations




- Geometries and operating conditions reviewed for all plants participating in PWROG effort
- Sensitivity runs performed to determine limiting configurations / conditions for each weld/nozzle type
- Full set of runs performed for limiting configuration
 - Seismic Loading
 - Elevated fatigue stress due to snubber lock-up
 - Seismic loading with failure of snubbers to restrain motion
- Bounding change-in-failure frequency values determined for 40 and 60 years of operation and three LOCA leak rates (break sizes)


Change-in-Failure Frequency Calculations – Process



Change-in-Failure Frequency Calculations – Process (cont.)



Change-in-Failure Frequency Calculations – Process (cont.)



Change-in-Failure Frequency Calculations – Results



Type A – B&W Similar Metal Bounding Change in Failure Frequencies / year			
	LOCA Size	Without Leak Detection	With Leak Detection
Outlet Nozzle – 40 Year Results	SLOCA	1.36E-09	5.65E-11
	MLOCA	3.77E-11	1.75E-11
	LLOCA	1.74E-11	4.60E-12
Inlet Nozzle – 40 Year Results	SLOCA	7.88E-10	3.06E-11
	MLOCA	1.66E-11	3.36E-12
	LLOCA	1.76E-11	3.10E-12

Type B – CE Similar Metal Bounding Change in Failure Frequencies / year			
	LOCA Size	Without Leak Detection	With Leak Detection
Outlet Nozzle – 40 Year Results	SLOCA	1.23E-09	5.66E-11
	MLOCA	4.13E-11	2.19E-11
	LLOCA	4.13E-11	2.19E-11
Inlet Nozzle – 40 Year Results	SLOCA	1.29E-09	9.72E-11
	MLOCA	4.02E-11	1.49E-11
	LLOCA	1.99E-11	3.28E-12

Change-in-Failure Frequency Calculations – Results (cont.)



Type C – Westinghouse Dissimilar Metal – No Safe-End Bounding Change in Failure Frequencies / year			
	LOCA Size	Without Leak Detection	With Leak Detection
Outlet Nozzle – 40 Year Results	SLOCA	6.79E-08	4.58E-09
	MLOCA	6.78E-08	3.20E-09
	LLOCA	1.94E-07	3.20E-09
Inlet Nozzle – 40 Year Results	SLOCA	7.54E-08	3.56E-09
	MLOCA	7.27E-08	1.53E-09
	LLOCA	8.15E-08	1.40E-09

Type D – Westinghouse Dissimilar Metal – Safe-End Bounding Change in Failure Frequencies / year			
	LOCA Size	Without Leak Detection	With Leak Detection
Outlet Nozzle – 40 Year Results	SLOCA	6.09E-08	9.45E-09
	MLOCA	7.09E-08	8.06E-09
	LLOCA	7.03E-08	8.03E-09
Inlet Nozzle – 40 Year Results	SLOCA	9.80E-08	3.98E-08
	MLOCA	8.09E-08	3.20E-08
	LLOCA	8.05E-08	3.20E-08

Pilot Plant Evaluations

- Two pilot plants evaluated for acceptability of extension in ISI interval and effects on piping risk-informed inservice inspection program:
 - Three Mile Island Unit 1 – EPRI Piping RI-ISI Program – Type A
 - Beaver Valley Unit 1 – PWROG Piping RI-ISI Program – Type C
- Both plants have been evaluated for implementation of the RV ISI interval extension
 - Three Mile Island Unit 1 – Individual plant submittal
 - Beaver Valley Unit 1 – WCAP-16168 pilot plant
- Effect on RI-ISI program is in the Δ Risk Evaluation

Three Mile Island Unit 1 – Change-in-Risk Regulatory Evaluation



- Bounding Change-in-Failure Frequencies combined with TMI-1 CCDF and CLERP values for all LOCA sizes
 - 40 year values used
 - No credit for leak detection
- Δ CDF and Δ LERF values summed for each LOCA size and multiplied by total number of nozzles (details on next slide)
 - Δ CDF = $1.94\text{E-}11$ / year
 - Δ LERF = $2.15\text{E-}12$ / year
- Δ CDF and Δ LERF values meet guidelines of R.G. 1.174 for an acceptably small change-in-risk

TMI Unit 1 – Change-in-Risk Regulatory Evaluation – Results



Change-in-Risk Calculations – Three Mile Island Unit 1					
Break Size	Bounding Change in Failure Frequency (No Leak Detection)	CCDP	Δ CDF	CLERP	Δ LERF
Outlet Nozzle					
SLOCA	1.36E-09	1.83E-03	2.49E-12	2.53E-04	3.44E-13
MLOCA	3.77E-11	2.23E-03	8.41E-14	2.55E-04	9.61E-15
LLOCA	1.74E-11	3.93E-02	6.84E-13	8.06E-04	1.40E-14
# of Outlet Nozzles	2	Total Δ CDF	6.51E-12	Total Δ LERF	7.35E-13
Inlet Nozzle					
SLOCA	7.88E-10	1.83E-03	2.36E-12	2.53E-04	3.26E-13
MLOCA	1.66E-11	2.23E-03	8.96E-14	2.55E-04	1.03E-14
LLOCA	1.76E-11	3.93E-02	7.82E-13	8.06E-04	1.60E-14
# of Inlet Nozzles	4	Total Δ CDF	1.29E-11	Total Δ LERF	1.41E-12
All Nozzles					
Total Change-in-Risk Results		Total Δ CDF	1.94E-11	Total Δ LERF	2.15E-12

TMI Unit 1 – Δ Risk Evaluation Process for RI-ISI Program



- EPRI RI-ISI Method allows 4 different change-in-risk methods
 - Qualitative
 - Bounding without credit for increase in POD
 - Bounding with credit for increase in POD
 - Markov Method
- TMI-1 RI-ISI program used the Markov Method
- Two methods evaluated for effect of interval extension
 - Markov Method
 - Additive with Bounding change-in-failure frequencies

TMI Unit 1 – RI-ISI Program Δ Risk Evaluation – Markov Model



- 10-yr and 20-yr ISI effectiveness factors calculated for RV nozzle welds
- Change-in-risk for ISI interval extension calculated using difference in effectiveness factors
- Change-in-risk for ISI interval extension added to RC system change-in-risk for RI-ISI (details on next slide)
 - $\Delta\text{CDF} = 7.58\text{E-}09$ / year
 - $\Delta\text{LERF} = 1.24\text{E-}09$ / year
- RC system change-in-risk values satisfy requirements of EPRI RI-ISI TR ($\Delta\text{CDF} \leq 1\text{E-}7/\text{yr}$, $\Delta\text{LERF} \leq 1\text{E-}8/\text{yr}$)

TMI Unit 1 – RI-ISI Program Δ Risk Evaluation – Markov Model – Results



$\Delta CDF = \lambda_f P_I \langle R F \rangle (\Delta I) C C D P$ (per nozzle)	1.40E-10 / yr
$\Delta L E R F = \lambda_f P_I \langle R F \rangle (\Delta I) C L E R P$ (per nozzle)	1.94E-11 / yr
Number of RV Nozzles	6
Total Nozzle ΔCDF	8.41E-10 / yr
Total Nozzle $\Delta L E R F$	1.16E-10 / yr
RC System ΔCDF from RI-ISI	6.74E-09 / yr
RC System $\Delta L E R F$ from RI-ISI	1.12E-09 / yr
New RC System ΔCDF	7.58E-09 / yr
New RC System $\Delta L E R F$	1.24E-09 / yr

TMI Unit 1 – RI-ISI Program Δ Risk Evaluation – Additive Method



- Δ CDF and Δ LERF determined for all nozzles
 - Similar to regulatory change-in-risk evaluation
 - Credit for leak detection
- Total Δ Risk for nozzle ISI interval extension added to RC system and total plant Δ Risk from RI-ISI program element selection (details on next slide)
 - Δ CDF = $6.74\text{E-}09$ / year
 - Δ LERF = $1.12\text{E-}09$ / year
- RC system Δ Risk values satisfy requirements of EPRI Piping RI-ISI program topical report

TMI Unit 1 – RI-ISI Program Δ Risk Evaluation – Additive Method – Results



	Δ CDF / yr	Δ LERF / yr
Nozzle Change-in-Risk Results	4.31E-13	5.96E-14
RC System Change-in-Risk	6.74E-09	1.12E-09
New RC System Change-in-Risk	6.74E-09	1.12E-09
Plant Change-in-Risk	4.08E-08	5.36E-09
New RC Plant Change-in-Risk	4.08E-08	5.36E-09

Beaver Valley Unit 1 – Change-in-Risk Regulatory Evaluation



- Bounding Change-in-Failure Frequencies combined with BV1 CCDF and CLERP values for all LOCA sizes
 - 40 year values used
 - No credit for leak detection
- Δ CDF and Δ LERF values summed for each LOCA size and multiplied by total number of nozzles (details on next slide)
 - Δ CDF = $2.53\text{E-}09$ / year
 - Δ LERF = $6.37\text{E-}14$ / year
- Δ CDF and Δ LERF values meet guidelines of R.G. 1.174 for an acceptably small change-in-risk

Beaver Valley Unit 1 – Change-in-Risk Regulatory Evaluation – Results



Change-in-Risk Calculations – Beaver Valley Unit 1					
Break Size	Bounding Change in Failure Frequency (No Leak Detection) / year	CCDP	Δ CDF / year	CLERP	Δ LERF / year
Outlet Nozzles					
SLOCA	6.79E-08	1.38E-05	9.37E-13	7.61E-12	5.16E-19
MLOCA	6.78E-08	1.68E-03	1.14E-10	4.70E-08	3.18E-15
LLOCA	1.94E-07	2.15E-03	4.18E-10	5.30E-08	1.03E-14
# of Outlet Nozzles	3	Total Δ CDF	1.60E-09	Total Δ LERF	4.05E-14
Inlet Nozzles					
SLOCA	7.54E-08	1.93E-04	1.46E-11	2.90E-10	2.19E-17
MLOCA	7.27E-08	1.68E-03	1.22E-10	4.70E-08	3.42E-15
LLOCA	8.15E-08	2.15E-03	1.75E-10	5.30E-08	4.32E-15
# of Inlet Nozzles	3	Total Δ CDF	9.36E-10	Total Δ LERF	2.33E-14
All Nozzles					
Total Change-in-Risk Results		Total Δ CDF	2.53E-09	Total Δ LERF	6.37E-14

Beaver Valley Unit 1 – Δ Risk Evaluation Process for RI-ISI Program



- Δ CDF and Δ LERF determined for all nozzles
 - Similar to regulatory change-in-risk evaluation
 - Credit for leak detection
- Total change-in-risk for nozzle ISI interval extension added to RC system and total plant Δ Risk from RI-ISI program element selection.
- Total change-in-risk compared to plant and system criteria for acceptable Δ Risk

Beaver Valley Unit 1 – RI-ISI Program ΔRisk Evaluation – Results



Effect on Beaver Valley RI-ISI Program				
	Beaver Valley Unit 1 with Operator Action		Beaver Valley Unit 1 without Operator Action	
	ΔCDF / yr	ΔLERF / yr	ΔCDF / yr	ΔLERF / yr
RC System (Existing RI-ISI Program)	-2.58E-13	4.52E-19	-2.58E-13	4.52E-19
Additional Risk from ISI Int. Extension	5.58E-11	1.40E-15	5.58E-11	1.40E-15
Total RC System Change-in-Risk	5.55E-11	1.40E-15	5.55E-11	1.40E-15
Acceptable System Change-in-Risk	0.0E+00	1.0E-09	0.0E+00	1.0E-09
Total Plant (Existing RI-ISI Program)	-3.94E-11	-7.88E-13	-2.02E-10	-9.36E-13
Additional Risk from ISI Int. Extension	5.58E-11	1.40E-15	5.58E-11	1.40E-15
Total Plant Change-in-Risk	1.64E-11	-7.87E-13	-1.46E-10	-9.35E-13
Acceptable Total Change-in-Risk	0.0E+00	0.0E+00	0.0E+00	0.0E+00

Beaver Valley Unit 1 – RI-ISI Program

Δ Risk Evaluation



- For its first risk-informed application, NRC requested the PWROG method for piping ISI to be risk neutral.
 - For the pilot plant application in WCAP-14572, Revision 1-NP-A, risk neutral was conservatively set as $\Delta\text{Risk} \leq 0.0$.
 - However, this was not required in the subsequent versions of Regulatory Guides 1.174 and 1.178 for RI applications.
- Later NRC approved RI-ISI applications/methodologies defined risk neutral to be consistent with current calculation capabilities as $\Delta\text{CDF} \leq 1\text{E-}7/\text{yr}$ and $\Delta\text{LERF} \leq 1\text{E-}8/\text{yr}$ per system.
- Beaver Valley Unit 1 satisfies these ΔRisk requirements with no additional examinations that would increase man-REM exposure levels.


Proposed Resolution of NRC Concerns Raised at Last Meeting



- Embedded Flaws / Flaw Distributions
- Inspection Scheduling / Distribution
- Probability of Detection
- Cast Austenitic Stainless Steel

Embedded Flaws \ Flaw Distribution

- SRRA Code considers surface flaws only
- Based on flaw density and weld sizes, one surface flaw considered per each weld
- Deterministic analyses, performed in accordance with ASME Section XI, Nonmandatory Appendices A and C, have shown that growth of embedded flaws is insignificant
- ISI results should be reviewed to confirm that no more than 1 surface flaw is present in each weld



Inspection Scheduling / Distribution

- RV ISI interval extension plans were provided to NRC by PWROG (OG-06-356 & OG-09-454)
- RV nozzle exams will be performed at same time as RV ISI
- 31 Plants with Alloy 82/182 welds can not use ISI interval extension for nozzles
- Separate implementation plan is not needed to ensure a uniform distribution of RV nozzle inspections requested by NRC

Probability of Detection (POD)

- POD used in SRRA calculations for RV nozzle welds is consistent with that used for PWROG RI-ISI applications for ultrasonic (UT)
- Lower POD = Lower Δ Risk, Higher POD = Higher Δ Risk for regulatory evaluations (R.G. 1.174)
- For piping RI-ISI program Δ Risk evaluations, POD should be consistent
- WCAP will include results of sensitivity studies

Cast Austenitic Stainless Steel (CASS)

- Only applicable to Type C and D nozzles
- No specific considerations made for CASS materials in SRRA runs for failure probabilities without ISI
- Low POD issues exist for CASS regardless of inspection interval (ASME XI 10 years or PWROG 20 years)
- Assuming a higher POD results in a larger calculated change-in-failure frequency and Δ Risk
- Deterministic analyses show that even large flaws are unlikely to grow to critical dimensions in 20+ years

Plant Specific Implementation Plan

- No plant specific SRRA calculations – Bounding change-in-failure frequency values would be used instead
- Plant specific CCDP and CLERP values would be used
- ISI results should be reviewed to confirm that no more than 1 surface flaw is present in each weld
- Plants would provide results of risk calculations similar to those shown for pilot plants
- Submit relief request, revise existing relief request, or implement through update to RI-ISI program

Summary and Conclusions

- Bounding change-in-failure frequencies have been calculated for each nozzle / weld type and LOCA sizes for both 40 and 60 years of operation
- Pilot plant calculations show that R.G. 1.174 change-in-risk guidelines are satisfied
- Piping RI-ISI program requirements may require additional piping inspections to meet respective Δ Risk requirements
- NRC comments from last meeting have been considered and accounted for in pilot plant applications
- Proposed plant-specific implementation plan is simple and straight-forward for PWROG utilities to use and NRC to review