PMVogtleCOLPEm Resource

From: Simms, Tanya
Sent: Thursday, March 25, 2010 3:53 PM
To: PMVogtleCOLPEm Resource
Cc: Joshi, Ravindra
Subject: Telcon Summary - Telcon with Vogtle 3/25/10

On March 25, 2010, NRC staff (Tanya Simms, Om Chopra, and Robert Johnson) participated in a telephone conference call with Vogtle representatives and observers (see below) regarding the staff's detailed review of the Vogtle Units 3 and 4 COL application. The purpose of the call was to provide clarity for the requests for additional information (RAI) #4525.

The discussion focused on the description of the frequency of testing and inspection in the inspection, testing and monitoring program to detect degradation of inaccessible or underground control and power cables that support equipment and other systems as reviewed in FSAR chapter 8, Section 8.2.

At the conclusion of the call, Vogtle indicated that they had a clearer perspective of the staffs request and would view NUREG/CR-7000 in formulating their response along with industry guidance.

Bob Hirmanpour - NuStart
Amy Aughtman -Southern
Gary Becker - Southern
Ken Pigg - Progress
Jamie LaBorde - SCANA
Jim Fender – SCANA
Andy Underwood - SCANA
Ray Burski -FPL
Sunil Kabra - Shaw
Tom Cognetti -FPL
Jim Stoner - Duke
Mike Melton - Westinghouse
John Disosway – Dominion
Keith Bush – Shaw Group
Jim Hesler – Bechtel
Bob Prunty – Bechtel
Bruce Kobel – Bechtel

Hearing Identifier: Vogtle_COL_Public
Email Number: 441

Mail Envelope Properties (192BB59294514E41B5305C3C8286760809F76FCDDC)

Subject: Telcon Summary - Telcon with Vogtle 3/25/10
Sent Date: 3/25/2010 3:53:10 PM
Received Date: 3/25/2010 3:53:01 PM
From: Simms, Tanya

Created By: Tanya.Simms@nrc.gov

Recipients:
"Joshi, Ravindra" <Ravindra.Joshi@nrc.gov>
Tracking Status: None
"PMVogtleCOLPEm Resource" <PMVogtleCOLPEm.Resource@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	**Size**	**Date & Time**
MESSAGE	1305	3/25/2010 3:53:01 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received: