

PMVogtleCOLPEm Resource

From: Simms, Tanya
Sent: Thursday, March 25, 2010 4:29 PM
To: PMVogtleCOLPEm Resource
Cc: Joshi, Ravindra
Subject: Telcon Summary - Telcon with Vogtle 3/18/10

On March 18, 2010, NRC staff (Tanya Simms, Ravindra Joshi, and Jeffrey Poehler) participated in a telephone conference call with Vogtle representatives and observers (see below) regarding the staff's detailed review of the Vogtle Units 3 and 4 COL application. The purpose of the call was to address the Metamic Coupon Monitoring Program Standard Open Item.

The discussion focused on additional details of the methodology for the tests listed in COL information item 9.1-7. The staff is mindful that a complete program is not available at this time, but additional information can be provided to address this concern. Licensed reactors have been using this program and the applicant may be able to locate similarities in those programs to assist them in their write-up.

At the conclusion of the call, Vogtle indicated that they had a clearer perspective of the staffs request and would view other design center responses and schedule a new phone call to discuss a proposed response.

Bob Hirmanpour – NuStart
Amy Aughtman – Southern
Wes Sparkman - Southern
Julie Giles - SCANA
James Fender - SCANA
Jamie Laborde- SCANA
Jim Thornton - Duke
Ken Karcher – Progress
Chase Thomas - Progress
Ray Burski – FPL
Kris Cummings - Westinghouse
Scott Altmayer - Westinghouse

Hearing Identifier: Vogtle_COL_Public
Email Number: 443

Mail Envelope Properties (192BB59294514E41B5305C3C8286760809F8366838)

Subject: Telcon Summary - Telcon with Vogtle 3/18/10
Sent Date: 3/25/2010 4:28:50 PM
Received Date: 3/25/2010 4:30:09 PM
From: Simms, Tanya

Created By: Tanya.Simms@nrc.gov

Recipients:

"Joshi, Ravindra" <Ravindra.Joshi@nrc.gov>
Tracking Status: None
"PMVogtleCOLPEm Resource" <PMVogtleCOLPEm.Resource@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	1335	3/25/2010 4:30:09 PM

Options

Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received: