

**NRCREP Resource**

---

**From:** Robert M. Brady, PE [robert.brady@schirmereng.com]  
**Sent:** Tuesday, March 30, 2010 5:30 PM  
**To:** NRCREP Resource  
**Subject:** Response from "Comment on NRC Documents"

10/29/2009  
74FK68872  
6

Below is the result of your feedback form. It was submitted by

Robert M. Brady, PE ([robert.brady@schirmereng.com](mailto:robert.brady@schirmereng.com)) on Tuesday, March 30, 2010 at 17:30:18

---

Document\_Title: Comments Related to NUREG-1934 (draft)

Comments: (1) Section 2.6, first bullet, Page 2-18: HVAC drawings are important and have not been mentioned. An understanding of the mechanical ventilation arrangement, systems, and equipment for the plant will most likely be needed.

(2) Figure 3-1. Page 3-2: Item No. 7 in Table 3-1 is missing.

organization: Schirmer Engineering, an AON company

address1: 5720 S. Arville Street

address2: Suite 115

city: Las Vegas

state: NV

zip: 89118

country: USA

phone: 702-257-1320

---

RECEIVED

2010 MAR 31 AM 10:46

RULES AND DIRECTIVES  
BRANCH  
USNRC

SUNSI Review Complete  
Template = ADM-013

E-RFDS = ADM-03  
Cell = J. Stroup (dsw4)