


NRC FORM 699 (9-2003)		U.S. NUCLEAR REGULATORY COMMISSION		DATE 04/01/2010
CONVERSATION RECORD				TIME 10:00am
NAME OF PERSON(S) CONTACTED OR IN CONTACT WITH YOU Glenn Adams		TELEPHONE NO. 612-330-6777	TYPE OF CONVERSATION <input type="checkbox"/> VISIT <input type="checkbox"/> CONFERENCE <input checked="" type="checkbox"/> TELEPHONE <input type="checkbox"/> INCOMING <input checked="" type="checkbox"/> OUTGOING	
ORGANIZATION NSPM - Northern States Power Company, a Minnesota Corporation (Prairie Island, TN-40HT)				
SUBJECT PINGP ISFSI (TN-40HT License Amendment Request, LAR)				
SUMMARY (Continue on Page 2)				
List of Participants				
NRC - Dr. Pamela Longmire, JoAnn Ireland, Dr. Robert Einziger, Geoffrey Hornseth; Clyde Morell; & Dr. Zhian Li				
NSPM - Glenn Adams, Oley Nelson, Lee Samson, Lynne Gunderson, & Darlene Stimart				
Transnuclear - Peter Shih, Bill Bracey, & Steve Streutker				
NSPM requested this conference call (telecon) to seek clarification on the outstanding issues associated with the suspended review of the TN-40HT storage cask system LAR. In preparation for the telecon NSPM transmitted draft RAI responses. The applicant was again reminded that SFST policy does not permit informal review of draft RAI responses and that the appropriate venue for discussion of them would be a public meeting. Discussion topics: 1 - Equivalency for non-ASTM materials used in the TN-40 HT cask; 2 - Adoption of NUREG-6407 classification criteria; and 3 - Leak testing the entire confinement boundary (including the base metal) during fabrication.				
Non-ASTM materials: Applicant discussed adoption of a definition of "equivalence" (for use of Non-ASTM materials) from docket 72-1004. Staff explained that that is not a form of precedence. Potential success paths discussed included: expanding the written criteria for equivalence, using criteria recently "evolving" on the Holtec docket for HI-STAR 180 and for specific components needing ASTM alternatives, stating the specific foreign standard and addressing how they achieve the appropriate quality levels required of the component.				
NUREG-6407: NSPM proposes to adopt the NUREG-6407 classification criteria, which can be accomplished without any change to the NSPM Quality Assurance Topical Report. Staff stated that the approach appears to be a path forward.				
Helium leak testing: NSPM proposes to expand the present scope of helium leak testing to address the entire cask, including lids and base metal. Staff stated that the approach appears to be a path forward.				
No commitments were made by parties participating in this telecon. The called ended about 11:00 am.				
<i>Continue on Page 2</i>				
ACTION REQUIRED				
Public Meeting scheduled for April 20, 2010 (2:00 pm - 4:00 pm.) EBB Room 1E03				
Docket No.: 72-10 TAC No.: L24203				
NAME OF PERSON DOCUMENTING CONVERSATION Pamela Longmire, Ph.D.		SIGNATURE 		DATE 04/01/2010
ACTION TAKEN				
TITLE OF PERSON TAKING ACTION		SIGNATURE OF PERSON TAKING ACTION		DATE