



JAMES R. MORRIS, VICE PRESIDENT

Duke Energy Carolinas, LLC
Catawba Nuclear Station / CNO1VP
4800 Concord Road
York, SC 29745

803-831-4251
803-831-3221 fax

March 30, 2010

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

Subject: Duke Energy Carolinas, LLC (Duke)
Catawba Nuclear Station, Units 1 and 2
Docket Nos.: 50-413 and 50-414
Commitment Change Evaluation Report for 2009

Attached is a summary of commitment change evaluations completed during the 2009 calendar year for Catawba Nuclear Station. These evaluations and subsequent commitment changes were made based on the guidance defined in NEI 99-04, *Guidelines for Managing NRC Commitments*, and have no adverse effect on compliance with NRC rules and regulations.

Questions regarding this report should be directed to Toni Pasour at 803-701-3566.

Sincerely,

A handwritten signature in black ink, appearing to read 'J. R. Morris', written over a horizontal line.

J. R. Morris

Attachment

IEH7
NRR

U. S. Nuclear Regulatory Commission
March 30, 2010
Page 2

xc:

L. A. Reyes, Regional Administrator
U.S. Nuclear Regulatory Commission, Region II
Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, GA 30303

J. H. Thompson (addressee only)
NRR Project Manager (CNS)
U.S. Nuclear Regulatory Commission
One White Flint North, Mail Stop 8 G9A
11555 Rockville Pike
Rockville, MD 20852-2738

G. A. Hutto
Senior Resident Inspector (CNS)
CN01NC

Catawba Nuclear Station
 Annual Commitment Change Summary Report for 2009
 Docket Nos. 50-413 and 50-414

NRC Notification Required	Number	Source Document	Original Commitment	Modified Commitment
Yes	2009-C-001	Duke Power response to NRC Generic Letter 89-13, Service Water System Problems Affecting Safety-Related Equipment dated January 26, 1990	Inspections of nuclear safety related service water piping internal coatings will be performed one year following the initial coating application. Subsequent inspections will be performed at three to five year intervals.	Inspections of nuclear safety related service water piping internal coatings will be performed 18 months following the initial coating application. Subsequent inspections will be performed at three to six year intervals.