

PMSTPCOL PEmails

From: Eudy, Michael
Sent: Friday, April 02, 2010 11:45 AM
To: 'Stephens, Scot'
Cc: Williams, Stephen; Kellner, Robert; Roach, Edward; STPCOL
Subject: DRAFT: RAI 4492 - The RAI Document is Ready for Review
Attachments: RAI 4492.doc

Importance: High

Scot,

This new RAI is ready for your review. Please let me know if you need to discuss with or technical staff before we issue it. Thanks.

Michael A. Eudy - Project Manager
U.S. Nuclear Regulatory Commission
NRO/DNRL/NGE1&2
301-415-3104

Hearing Identifier: SouthTexas34Public_EX
Email Number: 2060

Mail Envelope Properties (9E28710E0B702149AEC66397286364402343A4A851)

Subject: DRAFT: RAI 4492 - The RAI Document is Ready for Review
Sent Date: 4/2/2010 11:44:31 AM
Received Date: 4/2/2010 11:44:34 AM
From: Eudy, Michael

Created By: Michael.Eudy@nrc.gov

Recipients:

"Williams, Stephen" <Stephen.Williams@nrc.gov>
Tracking Status: None
"Kellner, Robert" <Robert.Kellner@nrc.gov>
Tracking Status: None
"Roach, Edward" <Edward.Roach@nrc.gov>
Tracking Status: None
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"Stephens, Scot" <scstephens@STPEGS.COM>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	253	4/2/2010 11:44:34 AM
RAI 4492.doc	32762	

Options

Priority: High
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 4492 Revision 3

South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013
SRP Section: 12.02 - Radiation Sources
Application Section: 12.2

QUESTIONS for Health Physics Branch (CHPB)

12.02-***

In the response to RAI 11.02-7 (Letter U7-C-STP-NRC-090219, ADAMS Document Number ML100050183), STP provided additional information concerning the maximum expected radioactivity concentration, radioactivity inventory, and external dose rates for the STP 3 and 4 Condensate Storage Tanks (CST), as well as additional information about CST design features to mitigate releases and the spread of contamination. The response discussion included the statement; "The MUWC System contains lines that are used to transfer condensate quality water between the CST and systems in the Radwaste Building, Turbine Building and Reactor Building. All of the piping is routed in trenches or tunnels (there is no buried pipe). These trenches and tunnels provide the capability to identify and collect any leakage from the lines handling CST water and to transfer this water to the LWMS for processing." However, the response did not include a proposed COL FSAR revision to; 1) include the CST as a radiation source in Chapter 12, 2) include information concerning a tank containing radioactive material being located outdoors, or 3) include the CST design feature information about CST piping being routed in trenches or tunnels.

In order to ensure that radiation sources associated with STP 3 & 4 are adequately characterized in the COL FSAR, and to demonstrate compliance with 10 CFR 20.1201, 20.1301, 20.1302, and 20.1406, the staff requests that the applicant provide the following additional information concerning the Condensate Storage Tank:

1. Revise Chapter 12, Tables 12.2-5a, 12.2-5b, and 12.2-5c of the STP 3 & 4 COL FSAR identifying the CST as a radiation source, including source geometry and shielding information.
2. Revise Chapter 12 of the STP 3 & 4 COL FSAR to include the CST radioactive source term information provided in the above referenced response letter.
3. Revise Chapter 12 of the STP 3 & 4 COL FSAR to include the CST design feature information about CST piping being routed in trenches or tunnels, with leak collection and return to the LWMS, that was provided in the above referenced response letter.
4. Revise the applicable Chapter 12 STP 3 & 4 COL FSAR drawings to identify the location of the CST, including identifying the tank as a radiation source.
5. Provide additional information in the STP 3 & 4 COL FSAR concerning the design features of the dike that will surround the CST to prevent runoff. For example, will it be earthen, concrete, lined, routing of tank leakage piping, specific volume held by the installed dike, etc.

6. Provide additional information in the STP 3 & 4 COL FSAR concerning any planned additional radiation protection control requirements, or provisions, for control and monitoring of radioactive materials or radioactive tanks located outdoors.
7. Provide a markup of the proposed FSAR revision in the response.