

PMSTPCOL PEmails

From: Norato, Michael
Sent: Thursday, April 01, 2010 3:35 PM
To: STPCOL
Subject: FW: STP 6.2 reg basis and conclusion inserts

From: Makar, Gregory
Sent: Monday, March 29, 2010 10:16 PM
To: Kallan, Paul
Cc: McKirgan, John; Norato, Michael; Wagage, Harry
Subject: STP 6.2 reg basis and conclusion inserts

Paul,

Please insert the following into the Regulatory Basis section (6.2.1.3) and the Conclusions (6.2.1.6). I didn't have this completed yet when I sent you the revised tech evaluation and references. If you have any questions about what I did or where this goes, we can talk about it tomorrow.

Greg

Add the following to 6.2.1.3 Regulatory Basis:

The review and acceptability of STD DEP 6.C-1 is based on compliance with 10 CFR 50.46(b)(5), as it related to debris protection for ECCS strainers, and on conformance to the guidance in RG 1.82, Rev. 3 and Topical Report NEDO-32686-A ("Utility Resolution Guidance for ECCS Suction Strainer Blockage").

Add the following to 6.2.1.6 Conclusions

Pending resolution of Open Items 6.2-X and 6.2-X, and Confirmatory Items 6.2-X and 6.2-Y, the staff concludes that STP DEP 6.C-1 conforms to the guidance in RG 1.82, Rev. 3 and Topical Report NEDO-32686-A, and, therefore, complies with 10 CFR 50.46(b)(5) as it relates to debris protection for ECCS strainers.

Hearing Identifier: SouthTexas34Public_EX
Email Number: 2063

Mail Envelope Properties (ED827D914C9CA74BA644EA1C796CCD74D89587EF)

Subject: FW: STP 6.2 reg basis and conclusion inserts
Sent Date: 4/1/2010 3:35:17 PM
Received Date: 4/1/2010 3:35:28 PM
From: Norato, Michael

Created By: Michael.Norato@nrc.gov

Recipients:
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	1250	4/1/2010 3:35:28 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: