

PMSTPCOL PEmails

From: Norato, Michael
Sent: Thursday, April 01, 2010 3:33 PM
To: STPCOL
Subject: FW: Reg basis for STP 6.2

From: Makar, Gregory
Sent: Monday, March 22, 2010 8:51 AM
To: McKirgan, John; Wagage, Harry; Norato, Michael
Cc: Sastre, Eduardo
Subject: Reg basis for STP 6.2

John, Mike, Harry,

I've been looking at the licensing basis for our review in Section 6.2 for STP, and I'd like to suggest that we add to what's currently there in Section 6.2.1.3 (Regulatory Basis). It currently refers to SRP Section 6.2.1 (Containment Functional Design), but not 6.2.2 (Containment Heat Removal Systems). SRP 6.2.1 does not refer to requirements that I just added to my SER input and that may have been used throughout the section. For example, I used the following from SRP 6.2.2:

10 CFR 50.46(b)(5) - ECCS long-term cooling
GDC 35 – emergency core cooling
GDC 38 – containment heat removal (which I include because of downstream effects on heat exchangers)

I will send my revised CIB2 SER input (coatings/chemical/downstream components) separately to Mike for concurrence to forward it to Projects, which needs to send it to OGC by tomorrow.

My suggestion is that, in parallel, we talk about the regulatory basis and if/how we revise that section of the SER.

Thanks,
Greg

Hearing Identifier: SouthTexas34Public_EX
Email Number: 2069

Mail Envelope Properties (ED827D914C9CA74BA644EA1C796CCD74D89587E4)

Subject: FW: Reg basis for STP 6.2
Sent Date: 4/1/2010 3:32:45 PM
Received Date: 4/1/2010 3:32:46 PM
From: Norato, Michael

Created By: Michael.Norato@nrc.gov

Recipients:
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	1240	4/1/2010 3:32:46 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: