

13

**Kuntz, Robert**

**From:** Dozier, Jerry *NRR*  
**Sent:** Tuesday, October 27, 2009 10:24 AM  
**To:** NRR\_DLR\_RER1 Distribution; NRR\_DLR\_RER2 Distribution; Kuntz, Robert; Pelton, David; Wrona, David; Shea, James; Brittner, Donald  
**Subject:** FW: OpE Item on Crystal River Containment - update  
**Importance:** High

---

**From:** Bernardo, Robert  
**Sent:** Tuesday, October 27, 2009 8:39 AM  
**To:** Bagchi, Goutam; Lee, Brian; Dozier, Jerry; Medoff, James; Lee, Samson; Tabatabai, Omid  
**Cc:** Farzam, Farhad  
**Subject:** OpE Item on Crystal River Containment - update

**\*\*\*NOTE: THIS SUMMARY IS OFFICIAL USE ONLY -- MAY CONTAIN SENSITIVE INTERNAL INFORMATION\*\*\***  
**DO NOT FORWARD ANY PORTIONS OUTSIDE OF NRC WITHOUT FIRST OBTAINING PERMISSION FROM ORIGINATOR**

The following OpE item is being passed along from the OpE Clearinghouse Screening Summary for October 26, 2009

**9.) Crystal River 3 - Containment Separation Issue - update**

Containment Separation Issue: The licensee has qualified the use of an NDE technique to identify concrete delamination. The official containment NDE inspection started Sunday Oct 25 and is expected to take 1 to 2 weeks to complete. The NDE technique will be validated by a sampling of core borings. Last week's NDE results were obtained using procedures and equipment that were not yet qualified. These preliminary unofficial results have not identified any delamination/cracking outside the area of the containment opening (i.e., bounded by two buttresses on either side of the opening - see Crystal River Containment/ Reactor Building Sketch in PITA).

*Bob Bernardo*  
Reactor Systems Engineer  
US Nuclear Regulatory Commission  
NRR/ADRO/DIRS/IOEB  
Mail Stop: O-7C02A  
301-415-2621  
[Robert.Bernardo@nrc.gov](mailto:Robert.Bernardo@nrc.gov)

**\*\*\*NOTE: THIS SUMMARY IS OFFICIAL USE ONLY -- MAY CONTAIN SENSITIVE INTERNAL INFORMATION\*\*\***  
**DO NOT FORWARD ANY PORTIONS OUTSIDE OF NRC WITHOUT FIRST OBTAINING PERMISSION FROM ORIGINATOR**

*B12*