

## Changes to & Departures from Design Certification Material [FSAR]

DCD	Applicability		Rule	Change Standard
Tier 1 Information	Generic	All	VIII.A.1	1 of 7 amendment criteria in § 52.63(a)(1)
	Plant- specific	NRC	VIII.A.3 [§52.63(a)(4)]	adequate protection or compliance exception, and special circumstances
		Applicant or Licensee	VIII.A.4 [§52.63(b)(1) and §52.98(f)]	§ 52.7 and special circumstances outweigh < standardization
Tier 2 Information	Generic	All	VIII.B.1	1 of 7 amendment criteria in § 52.63(a)(1)
	Plant- specific	NRC	VIII.B.3	adequate protection or compliance exception, and special circumstances
		Applicant Licensee	VIII.B.4	§ 52.7 and no significant decrease in safety
		Applicant Licensee	VIII.B.5	New § 50.59 and not Tier 1, 2*, TS, or license amendment
		Applicant Licensee	VIII.B.6	Tier 2* requires NRC approval or license amendment
Generic Tech. Spec. (GTS) or other Operational Requiremt	Generic	All	VIII.C.1	§ 50.109, VIII.A, or VIII.B
	Plant- specific	NRC	VIII.C.3	special circumstances
		Applicant	VIII.C.4	10 CFR 52.7
		A party	VIII.C.5	§ 2.309 + special circumstances
		Licensee	VIII.C.6	GTS have no further effect

Revised December 9, 2008