

CCNPP3COLA PEmails

From: Arora, Surinder
Sent: Monday, April 19, 2010 2:10 PM
To: 'Poche, Robert'; 'cc3project@constellation.com'
Cc: CCNPP3COL Resource; McKirgan, John; Jackson, Christopher; Colaccino, Joseph; Hearn, Peter; Biggins, James; Vrahoretis, Susan; Hair, Christopher
Subject: DRAFT RAI 239 SPCV 4537
Attachments: DRAFT RAI 239 SPCV 4537.doc

Rob,

Attached is DRAFT RAI No. 239 (eRAI No. 4537). You have until May 3, 2010 to review it and decide whether you need a conference call to discuss any questions in this RAI before the final issuance. After the phone call or on May 3, 2010, the RAI will be finalized and sent to you for response. You will then have 30 days to provide a technically complete response or an expected response date for the RAI.

Thanks.

SURINDER ARORA, PE
PROJECT MANAGER,
Office of New Reactors
US Nuclear Regulatory Commission

Phone: 301 415-1421
FAX: 301 415-6406
Email: Surinder.Arora@nrc.gov

Hearing Identifier: CalvertCliffs_Unit3Cola_Public_EX
Email Number: 1248

Mail Envelope Properties (B46615B367D1144982B324704E3BCEED21A9668B20)

Subject: DRAFT RAI 239 SPCV 4537
Sent Date: 4/19/2010 2:09:41 PM
Received Date: 4/19/2010 2:09:44 PM
From: Arora, Surinder

Created By: Surinder.Arora@nrc.gov

Recipients:

"CCNPP3COL Resource" <CCNPP3COL.Resource@nrc.gov>
Tracking Status: None
"McKirgan, John" <John.McKirgan@nrc.gov>
Tracking Status: None
"Jackson, Christopher" <Christopher.Jackson@nrc.gov>
Tracking Status: None
"Colaccino, Joseph" <Joseph.Colaccino@nrc.gov>
Tracking Status: None
"Hearn, Peter" <Peter.Hearn@nrc.gov>
Tracking Status: None
"Biggins, James" <James.Biggins@nrc.gov>
Tracking Status: None
"Vrahoretis, Susan" <Susan.Vrahoretis@nrc.gov>
Tracking Status: None
"Hair, Christopher" <Christopher.Hair@nrc.gov>
Tracking Status: None
"Poche, Robert" <Robert.Poche@constellation.com>
Tracking Status: None
"cc3project@constellation.com" <cc3project@constellation.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	638	4/19/2010 2:09:44 PM
DRAFT RAI 239 SPCV 4537.doc		30202

Options

Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 239 (eRAI 4537)
DRAFT
4/19/2010

Calvert Cliffs Unit 3
UniStar
Docket No. 52-016
SRP Section: 09.04.04 - Turbine Area Ventilation System
Application Section: 9.4.4

QUESTIONS for Containment and Ventilation Branch 1 (AP1000/EPR Projects) (SPCV)

09.04.04-3

Open Item, TBVS Compliance with GDC 2

Follow Up Question on Response to RAI 35:

In response to RAI 35, Question 09.04.04-1, the applicant stated that there 'are no safety-related SSCs in the turbine building that directly provide a reactor trip; therefore GDC 2 is not applicable.' The staff notes that the scope of GDC 2 extends beyond just safety-related SSCs 'that directly provide a reactor trip' and includes all items important to safety. As a result, the staff can not conclude the design meets the requirements of GDC 2. The staff requests the applicant provide enough information in the FSAR to conclude the system meets the requirements of GDC 2.